

SPECIFICATION CHANGE NO.

MILITARY SEA TRANSPORTATION SERVICE, PACIFIC
N.S.C.

DATE OF ORIGIN

1

OAKLAND, CALIFORNIA 94625

8/19/69

SHIP

USNS POPE (T-AP 110)

SPECIFICATION NO.

MSTSP 70-11

ITEM NO.

ITEM 501, EXTENSION OF ANNOUNCING SYSTEM: (WV)

SPECIFIC ITEM NO.

501

ADDENDUM NO.

1

DESCRIPTION OF WORK

Contractor to furnish 1 each contactor enclosure, and 1 each circuit breaker enclosure, in lieu of GFE.

Contactor shall be heavy duty type and be operated from 115V AC, 60 Hertz source and capable of continuous operation. Contacts shall be double-pole, double-throw and rated no less than 50 amperes. Contactor shall also contain two pairs of auxiliary double-pole, double-throw contacts. Contactor shall be installed in a marine type drip-proof enclosure.

Circuit breaker enclosure, with door, in marine type drip-proof enclosure. Enclosure shall contain two Westinghouse type EH two-pole circuit breakers rated at 25 amperes for use on 120V AC, 60 Hertz. Circuit breakers shall be calibrated for 40 degrees C and be connected to a copper buss with a minimum capacity of 70 amperes.

Normally Available:

Myers Safety Switch Co.
San Francisco

Material only.

RECEIVED
SEP 18 1969
USNS POPE T-AP110

cd

POPE