

3 March 1966

From: Commanding Officer, Military Department, USNS GEN. JOHN POPE (T-AP 110)
To: Distribution List

Subj: Material Inspection of Troop Spaces held this date

1. The following is a report on the condition of the Troop Spaces during the Material Inspection held on 3 March 1966:

COMPT 2-2 Scuttlebutt 11-2-40-1 has a faulty handle (2nd rpt), VERY GOOD.

COMPT 2-3 VERY GOOD.

COMPT 3-2 EXCELLENT.

COMPT 3-3 Many lights burned out throughout compt. and shower/washroom. 4 bunks have no canvas. Commode stopped up. Faucet leaking. Fresh water leak in pipe at Fr. 80 (3rd rpt). VERY GOOD.

COMPT 4-1 No comment.

COMPT 4-2 Empty G.I. cans.

COMPT 4-3 Spout leaking at scuttlebutt 40-4-67-1.

COMPT 4-4 Fresh water leak in hot water line aft. port section.

COMPT 4-5 No comment.

COMPT 4-6 Small leak in air conditioner. Empty G.I. cans.

COMPT 2-7 Check air conditioner, seems to be on but not cooling. EXCELLENT. Most improved compartment.

COMPT 3-7 No air in 3 vents at after end of compartment. 1 light burned out. Secure gear on top bunks. VERY GOOD.

FWD.UPPER HEAD Overhead pipe leaking on stbd. side. Shower drain stopped up on port side. 5 sink drain stoppers missing. 2 lights burned out. VERY GOOD.

FWD.LOWER HEAD 1 commode will not flush. 1 commode seat broken. VERY GOOD.

AFT.UPPER HEAD 1 leaking shower head (2nd rpt.). 3 missing shower heads (2nd rpt). 1 leaking urinal drain. VERY GOOD.

AFT.LOWER HEAD 6 faucets leaking. pipe leaking under wash basins. 1 pipe leaking under commodes. 2 showers leaking. 2 showers inoperative. 1 commode inoperative. 4 lights burned out. VERY GOOD.

L.REC.RM. Class in progress.

S.REC.RM. GOOD.


W. B. COBB

DISTRIBUTION:

→ Master
Chief Engineer (2)
First Officer
Troop Office for distribution to Troop Officers (5)
COMILDEPT
Medical Office
File