

CHECK OFF LIST FOR
FIRE DRILL (SCENE)

USS USNS	DATE	TIME STARTED	TIME DISCOVERED	LOCATION
METHOD BY WHICH BRIDGE WAS ALERTED	INVESTIGATOR ARRIVED	REPAIR PARTY ARRIVED	EXTINGUISHING AGENT USED	TIME FIRE OUT

NOTE: The time will be taken from the time the alarm is sounded to the time the repair party arrives at the scene and establishes communications. If the elapsed time exceeds the following limits, the drill will be declared unsatisfactory:

T-AP, T-AKV 5 minutes
T-AK, T-AGM, T-AG, T-AOG, T-LST 3 minutes

	Weight	Assigned
1. Initial action by personnel discovering fire	6	
2. Action by investigator	3	
3. Closures	4	
4. Securing of appropriate circuits	2	
5. Sufficient equipment provided	3	
6. Zone Area Officer's performance	4	
7. Repair Party organization	3	
8. Knowledge of Portable and Built-in equipment	4	
9. Fire Fighting procedures	8	
10. Establishment and patrolling of Fire Boundaries	3	
11. Use of OBA's	5	
12. Utilization of Back-up hose	4	
13. Condition of Built-in equipment	2	
14. Frequency and accuracy of SITREPS	3	
15. Condition of portable equipment	3	
16. Leadership	10	
17. Observance of safety precautions	5	
18. Minimum of noise and confusion	3	
TOTAL	75	

NUMERICAL GRADE _____

OBSERVER _____