

SHIP CONSTRUCTION FIRE PREVENTION CHECKSHEET
12ND MINS 983 (REV. 11-63)

DATE May 12th, 1969.

SHIP NUMBER		NAME OF SHIP				INSPECTED BY					
TAP 112		General WEIGEL				Al Constantine, Fire Inspector.					
ITEM INSPECTED		YES	NO	ITEM INSPECTED		YES	NO	ITEM INSPECTED		YES	NO
SHIPYARD FIRE BILL	POSTED	X		EXIT DRILL	HELD			SHIPBOARD STORAGE		X	
FIRE WATCH	ASSIGNED	X		STANDPIPES	ADEQUATE	X		FLAMMABLE LIQUIDS	DOCK STORAGE		
	INSTALLED	X			UNOBSTRUCTED	X			LOCKER PROVIDED	X	
ALARM SYSTEMS	AUDIBLE ALARM	X		DECK OPENINGS	COAMING PROVIDED				SAFETY CANS USED		
	VISIBLE ALARM	X		STAGING	FIRE RETARDANT TREATED			EQUIPMENT UNCRATING	DOCKSIDE		
EXIT FACILITIES	ADEQUATE	X		HOSE LINES	CLEAR OF DECK	X			ABOARD SHIP		
	ROUTE MARKED	X		EMERGENCY LIGHTING SYSTEM	INSTALLED	X		MATERIAL STORAGE	PASSAGeways CLEAR	X	
	OPENINGS MARKED	X			PORTABLE LANTERNS PRESENT				ORDERLY	X	
EXTINGUISHERS	UNOBSTRUCTED	X		OXYGEN AND FUEL GASES	LOCATED TOPSIDE			RUBBISH CONTAINERS	PROVIDED	X	
	ADEQUATE	X			CYLINDERS PROPERLY SECURE	X			PICKUP REGULAR	X	
	UNOBSTRUCTED	X			VALVE WRENCH PRESENT	X					

REMARKS

First Officer Shoroth was contacted for permission to conduct Fire Prevention Inspection. Quartermaster Jackson was assigned to accompany this tour.

Inspected main deck, lower decks, engine room, aft control room, storage areas, aboard shop facilities, etc.

It was noted Fire suppression equipment was up to date and their fire hose connected in an orderly manner.

The overall cleanliness and housekeeping on the Weigel is commendable.

Copies to - :

Capt. Mayer

Cmdr. Reynolds

Capt. Duecsek

Capt. Wilkins

Ship Supt. (Lt. Wertz)

Commanding Officer Capt. Haskell

ORAL RECOMMENDATIONS TO

DATE

REVIEWED BY

John A. Orren

DATE

5/12/69