

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY X

U. S. S. Gen John Pope T-AP110

PLANT NO. 7

AT ANCHOR _____

TIME: ZONE DESCRIPTION

**AHEAD
OR
SET CLOCKS BACK**

MINUTES AT

DATE 6-21-72 19 66

	Wed. 6-22-66											TUE 6-21-66												
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	7	8	7		7	7	8	8	8	8	7	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	1	2	2		2	2	2	2	2	2	1	2	2	3	1.5	1.5	2
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	1	1	1	1	1	1	1	2"	2"	2.5"		2"	2	2	2	2	2	2	2	4	5"	1"	1"	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	280	280	280	260	260	260	260	250	266	248		235	240	240	245	276	276	250	275	290	250	292	292	280
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	184	185	185	190	190	190	180	185	180	200		180	180	180	180	180	180	180	180	195	200	180	180	180
1ST EFFECT SHELL PRESSURE, *HG	10"	10"	10"	10"	10"	10"	10"	12	11	14		10"	10"	10"	10"	10"	10"	10"	10"	12	16	13	10	10"
2D EFFECT COIL DRAIN, TEMPERATURE, °F	156	160	160	158	158	158	158	156	156	152		160	162	162	162	160	160	160	160	160	140	156	156	156
2D EFFECT SHELL PRESSURE, *HG	17"	17"	17"	17	17	17	17	17	17	18.5		17"	17"	17"	17"	17	17	17	17	17	20	17	16	16"
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	152	152	148	148	148	150	150	150	140		150	150	150	152	154	154	154	154	152	130	148	148	150
3D EFFECT SHELL PRESSURE, *HG																								
CONDENSATE TO COOLER, TEMPERATURE, °F	152	152	152	152	152	152	152	152	152	152		152	152	152	152	152	152	152	152	152	152	152	152	152
CONDENSATE FROM COOLER, TEMPERATURE, °F	100	100	102	102	102	102	102	101	101	97		98	98	98	98	102	102	102	102	101	94	101	101	100
BRINE OVERBOARD, TEMPERATURE, °F	134	134	134	134	134	134	134	140	140	134		128	128	128	128	136	136	136	136	144	144	144	144	138
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	92	94	94		94	94	94	94	94	94	94	94	92	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	87	86	86	85	85	85	86	87	87	87		85	85	85	85	85	85	85	85	86	87	87	87	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	87	86	86	85	85	85	86	88	88	88		85	86	86	86	86	86	86	86	87	87	87	87	87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	120	120	120	120	120	120	122	120	122	115		118	118	118	120	116	116	116	116	122	118	120	120	120
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	135	134	134	134	134	134	136	134	136	127		134	134	134	136	132	132	132	132	138	128	135	135	135
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	162	162	152	152	152	154	152	154	146		154	154	154	158	152	152	152	152	156	142	154	154	154
CIRC. WATER OVERBOARD, TEMPERATURE, °F	114	114	114	110	110	110	112	112	112	107		110	114	114	114	104	104	104	104	114	108	112	112	114
CIRC. PUMP SUCTION PRESSURE, #G	10	10	10	10	10	10	10	10"	10	16		10	10	10	10	10	10	10	10	10"	10"	10"	10"	16
CIRC. PUMP DISCHARGE PRESSURE, #G	8	8	8	8	8	8	8	10	10	10		8	8	8	8	8	8	8	8	10	10	10	10	10
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22	22	22	22	21	21	22		22	22	32	32	32	32	32	32	21	22	21	21	21
BRINE PUMP DISCHARGE PRESSURE, #G	34	35	35	35	35	35	35	35	36	37		34	34	34	34	34	34	34	34	36	34	34	34	36
FEED PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	1	1	1		1	1	1	1	1	1	1	1	1	1	1	1	1
FEED PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	24		22	23	23	23	23	23	23	23	22	22	22	22	22
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	5"	5"	0		4	4	4	4	4	4	4	4	1"	2"	5"	5"	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	57	56	56	56	56	56	56	55	55	58		55	54	54	56	56	56	56	56	60	63	63	63	63
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	15	10		10	10	10	10	10	10	10	10	10	28	40	10	
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
Fresh Water Salinity.	20	20	20	20	20	20	20	20	20	20		20	20	20	20	30	30	30	30	50	1.5G	20	20	20
AIR EJECTOR DRAINS, SALINITY—E. P. M.	.06	.06	.06	.06	.06	.06	.06	.35	.35	.35		.06	.06	.06	.06	.06	.06	.06	.06	.18	.18	.18	.18	.18
1ST EFFECT DRAINS, SALINITY—E. P. M.	.05	.05	.05	.05	.05	.05	.05	.03	.03	.03		.04	.04	.04	.04	.05	.05	.05	.05	.02	.02	.02	.02	.02
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

#1

DISTILLED WATER RECORD

Wed. 6-22-66

REMARKS

Tue 6-21-66

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS	FEED TANKS*
0000		25100	5185
0100		24900	
0200		24700	
0300	05879100	24500	5600
0400		24300	
0500		24100	5600
0600		23900	
0700	05884800	23700	11100
0800			
0900			
1000			
1100	05890300	5500	41
1200	05858200		
1300			
1400			
1500	05864100	5900	
1600			
1700			
1800	05868100		
1900	05864100	4000	
2000			
2100			
2200	05872100	4000	
2300	05873500		1400
2400			

0000-0400
#1 unit dist. to #1 part - feed
@ 0345 shifted dist. to #3 center line

SIGNED R. Shippard

1200-1600
~~Water to After Peak~~
#1 unit dist. to After peak Tank
@ 1350 shifted dist. to #3 center line
Filled #1 No. 2000 Tank

SIGNED R. Shippard

0400-0800
#1 & 2 EVAP. DIST TO #3 CENTER
Added @ 2/0 RINE (80Z)
PER 1000 DIST.

SIGNED E. J. Magallanes

1600-2000
#1 & 2 EVAP. DIST. TO #3 CENTER
SECURED #1 EVAP @ 1800
#1 BRINE pump kicked off.
called FLEET. STARTED @ 1820
BRINE Pump Kicked off again @ 1930

SIGNED E. J. Magallanes

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

0800-1200
Water to #3
Added Chlorine @ hr. 803 per 1000 gal.

SIGNED _____

2000-2400
Brine pump off @ 20:00
Brine pump off - off line 20:45
OK Line 21:00
Water to #3 till 22:00
Water to #1 Port @ 22:00

SIGNED Jas. B. McIntyre

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED	6-6-66	6-6-66	6-6-66
HOURS BROUGHT FORWARD	257		
HOURS THIS DATE	23		
HOURS TO DATE	280		
GALLONS BROUGHT FORWARD	406000		
GALLONS THIS DATE	32100		
GALLONS TO DATE	438100		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY X

U. S. S. Gen. John Pope TAP 110

PLANT NO. II

AT ANCHOR _____

TIME: ZONE DESCRIPTION _____ SET CLOCKS **AHEAD
OR
BACK** _____ MINUTES AT _____ DATE 6-21-22 19 66

	Wed. 6-22-66										THU 6-21-66						FRI 6-21-66							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	9		8	8	8	8	8	8		8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	1	2	1		2	2	2	2	2	2		2	1.5	1.5	1	1	2
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	0.5	0.5	0.5		1	1	1	1	1	1		1	0.5	0.5	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	275	275	275	280	280	280	280	285	293	290		275	275	275	275	276	275		275	280	280	280	280	275
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	180	182	180	180	180	180	180	180	180	180		180	180	180	180	180	180		180	180	180	180	180	180
1ST EFFECT SHELL PRESSURE, "HG	10"	10"	10"	10"	10"	10"	10"	11	12	11		13"	13"	13"	12"	13"	13"		12	12	12	12	12	12"
2D EFFECT COIL DRAIN, TEMPERATURE, °F																								
2D EFFECT SHELL PRESSURE, "HG	20"	20"	20"	20"	20"	20"	20	19	19	19		20"	20"	20"	20"	20"	20"		20"	20	20	20	20	20"
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	150	152	152	150		150	150	150	150	150	150		150	150	150	150	150	150
3D EFFECT SHELL PRESSURE, "HG	25"	25"	25"	25"	25"	25"	25"	25"	27	26		25"	26"	26"	26"	26"	26"		26	26	26	26	26	26"
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	140	140	140	140	140	140	140		138	138	138	138	138	138		138	138	140	140	140	140
CONDENSATE FROM COOLER, TEMPERATURE, °F	100	102	102	102	102	102	102	104	104	104		100	100	100	100	102	102		102	102	103	103	103	102
BRINE OVERBOARD, TEMPERATURE, °F	136	136	134	134	134	134	134	138	138	138		128	128	128	126	136	136		136	140	140	140	140	140
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	90	90	98		90	90	90	90	98	98		98	98	98	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	87	86	86	85	85	85	86	88	87	87		85	85	85	85	85	85		85	87	87	87	87	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	87	86	86	85	85	85	86					85	85	85	85	85	85		85					87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	105	114	115	115	115	115	116	120	120	123		115	115	115	115	120	120		120	120	120	119	119	115
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	132	132	134	132	132	132	132	133	132	136		130	130	130	130	134	134		134	132	132	132	132	132
FEED TO 1ST EFFECT, TEMPERATURE, °F	154	160	160	156	156	156	154	154	154	156		150	152	152	152	152	152		152	152	154	154	154	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	105	105	105	105	106	106	106		104	104	104	104	112	112		112	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3		3	3	3	3	3	3		3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18		18	18	18	18	18	18		18	18	19	19	19	19
BRINE PUMP SUCTION PRESSURE, #G	20	20	20	20	20	20	20	19	19	19		20	20	20	20	20	20		20	20	20	20	20	20
BRINE PUMP DISCHARGE PRESSURE, #G	19	19	19	19	19	19	19	18	18	18		18	18	18	18	18	18		18	19	19	19	19	19
FEED PUMP SUCTION PRESSURE, #G	8	8	8	8	8	8	8	8	8	8		8	8	8	8	8	8		8	8	8	8	8	8
FEED PUMP DISCHARGE PRESSURE, #G	37	35	35	35	35	35	35	37	37	37		38	38	36	38	38	38		38	38	38	38	38	37
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	5"	5"	5"		5	5	5	5	5	5		5	5"	5"	5"	5"	5"
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	44	48	48	48	48	48	48	48	48	48		47	47	47	47	47	47		47	50	50	50	50	47
F. W. PUMP DISCHARGE PRESSURE	14	14	14	14	14	14	14	14	14	14		14	14	14	14	14	14		14	15	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05		1.05	1.05	1.05	1.05	1.05	1.05		1.05	1.05	1.05	1.05	1.05	1.05
Fresh Water Salinity	20	20	20	20	20	20	20	20	40	20		20	20	20	20	30	30		30	20	20	20	20	20
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05		0.06	0.06	0.06	0.06	0.06	0.06		0.06	0.06	0.06	0.06	0.06	0.06
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05		0.05	0.05	0.05	0.06	0.05	0.05		0.05	0.05	0.05	0.05	0.05	0.05
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD

Wed. 6-22-66

REMARKS

Tue. 6-21-66

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100			
0200			
x 0300	01594000	249	5500
0400			
0500			
0600			
x 0700	01599500	5500	
0800			
0900			
1000			
x 1100	01604500	5000	
1200	01572000		
1300			
1400			
x 1500	01577600	5600	
1600			
1700			
1800			
x 1900	01583000	5400	
2000			
2100	01586400	3400	
2200			
x 2300	01588500		2100
2400			

#2 unit dist. to #1 port. feed
@ 0300 shifted dist to #3 center line

Water to After Peak.
#2 unit dist. to After peak Tank
@ 1350 shifted dist. to #3 center line.
Filled #2 Nocevap Tank

SIGNED

R. Sheppard

SIGNED

R. Sheppard

0400-0800

#1 & 2 EVAP Dist. To
#3 CENTER.
Added @ 2/BRINE (80Z)
PER 1000 GALS Dist.

1600-2000

#1 & 2 EVAP. Dist To #3 CENTER
Secured #1 EVAP @ 1800
#1 BRINE Pump Kick off.
CALLED ELECT. STARTED @
1820. BRINE Pump Kick off again @ 1930

SIGNED

E. J. Magallanes

SIGNED

E. J. Magallanes

0800-1200

Water to #3
Added Chlorine each hr 80z per 1000 gal.
Filled Hagerap tank
Brine pump Kicked out 10:20
Fire drill on no help.
Fresh Water pump off & circulating.

2000-2400

Water to #3 @ 21:30
Water to #1 Std @ 21:30
Water to #1 Port @ 22:00

SIGNED

Jas B. McIntyre

SIGNED

Jas B. McIntyre

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED	6-6-66	6-6-66	6-6-66
HOURS BROUGHT FORWARD	307		
HOURS THIS DATE	23		
HOURS TO DATE	320		
GALLONS BROUGHT FORWARD	402100		
GALLONS THIS DATE	32500		
GALLONS TO DATE	434700		
CHECKED (Signature)			

APPROVED

(Engineer Officer, U. S. N.)

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.