

REMARKS

1200-1600 WATCH

Port Watch Out #1 Boiler in on Link @ 1255 Wheel Clearance @ 1259
Disengaged Tacking Gear @ 1300 open M.S. B&S & started warming up main unit @ 1304
Time check & tested engine telegraph @ 1305 Stby @ 1356 FOM 10008580 CTR.
14548550 Shifted main sea suet to low. Bells as per Bell Book
Bilges at safe level. Made routine rounds on mach & E.R. spaces.

WATCH ENGR'S SIGNATURE

Henry Bunney

1600-2000 WATCH

Departure at 1600 CTR. 14553580 - FOM-P-6666510 - S-FOM-3343090
at 1610 went up to 18 nozzles at 1755-2 due to loss of F.O. suction at 1813
LL at 1940 #1 Engines were lit-off.

WATCH ENGR'S SIGNATURE

Jim Jones

2000-2400 WATCH

Pumped out #4 P&S Holes; Bilges Pumped; Burners changed; F.O. Suet. Strainer
cleaned and changed. Bypassing F.O. Control Valves as it will not operate properly; leak in
bottom burner with line past burner. Made rounds. Pumped up both settlers 4 ft. DT.
Underway on 18 nozzles, mach. in operation as before.

WATCH ENGR'S SIGNATURE

H. Edwards 3 1/2

2400-0400 WATCH

Underway on 18 Nozz Mach in operation as before. Changed & cleaned
center F.O. burners & std dish strainer. Secured #1 L.P. Evap & rods for repairs
lit off #1 L.P. Evap & rods. Checked steering E.R. Gear. Pumped Bilges. Made
Routine inspections of mach & Eng spaces.

WATCH ENGR'S SIGNATURE

Henry Bunney

0400-0800 WATCH

Steaming as before on 18 nozzles. shifted and cleaned
bottom burner in #1 & 2 boilers. Pumped out bilges, shifted
F.O. suction to inboard settler. worked on gages leaking from fire
sides. #1 boiler on Contions blow through. Continued Evap.

WATCH ENGR'S SIGNATURE

Jim Jones

0800-1200 WATCH

STEAMING AS BEFORE on 18 nozzles; Blew tubes 0810-0825; changed burners
shifted to outboard settler @ 0830; Pumped up inboard settler. Outboard settler topped
off. F.O. Control Valves on Auto. Pumped out #4 Hole P&S. Made rounds and inspections.

WATCH ENGR'S SIGNATURE

H. Edwards 3 1/2

CHIEF ENGINEER

BOILER WATER READINGS

STB'D FS PORT WS-FS

HOURS 72 HOURS 72-72

AKL AYL

T-AKL T-AYL

SAL. SAL.

PHOS. PHOS.

R-ph R-ph

CHIEF ENGR'S SIGNATURE

H. Edwards

USNS		VOYAGE NO.		FROM		TO		TYPE OF VESSEL		DATE							
Gen John Pope Taylor		G-A		OAKLAND CALIF		OKINAWA		P2-52-R2		11-24-25-61							
		WATCH						WATCH									
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200			1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200		
RUNNING TIME		240	240	260	260	260	240										
DETENTION TIME																	
REVOLUTION COUNTER (END OF WATCH)		1468 9760	1471 3750	1473 9900	1476 5590	1479 1340	1481 5360										
TOTAL REVOLUTIONS (FOR WATCH)		22930	23990	26150	25690	25760	24020										
AVERAGE RPM		95.1	99.9	100.6	98.8	99.0	100.1										
F.O. METER (END OF WATCH)		1002 4070	1002 6610	1002 9460	1003 2286	1003 5060	1003 7710										
F.O. CONSUMED		2520	2540	2850	2820	2780	2650										
MACHINERY PARTICULARS	PRESSURES	THROTTLE	415	430	430	435	440	435	MACHINERY PARTICULARS (CONT'D)	TEMPERATURES (CONT'D)	AFT. H. P. ROTOR BEARING	136	135	135	137	138	138
		H.P. AHEAD	410	430	425	435	435	430			FORWARD L. P. ROTOR BEARING	135	135	125	135	135	135
		L.P. AHEAD	18	18	21	22	22	22			AFT. L.P. ROTOR BEARING	128	125	125	128	128	128
		VACUUM	29"	29"	29"	29"	29"	29"			HOTTEST GEAR BEARING FORWARD	158	158	158	158	130	157
		L.O. TO TURBINES	12	12	12	12	12	12			HOTTEST GEAR BEARING AFT	148	148	148	148	140	145
		AUX. STEAM	150	150	150	150	150	150			AUX. COND. CONDENSATE	86	86	90	90	100	100
		BACK PRESSURE	10	10	9	10	10	9			1ST STAGE FEED WATER HEATER	154	154	158	156	158	155
		GLAND STEAM	2	2	2	2	2	2.5			D. C. FEED WATER HEATER	237	23	238	238	240	240
		H.P. BLEEDER	72	72	70	72	74	72			2ND STAGE FEED WATER HEATER	237	23	238	238	240	240
		I.P. BLEEDER	-	-	7	-	-	-									
L.P. BLEEDER	15	15	11"	12"	12"	11"											
MACHINERY PARTICULARS	TEMPERATURES	STEAM AT THROTTLE	680	680	690	680	680	680	BOILER PARTICULARS	TEMPERATURES	F.O. TO BURNERS	190	180	192	190	190	190
		L.P. EXHAUST	90	90	96	96	96	96			F. O. BACK PRESSURE	10	10	10	10	10	10
		CONDENSATE	86	90	90	90	90	92			PRESSURE P AIR TO FURNACE S	5.8 5.0	6.0 5.0	6.0 5.0	5.2 4.5	5.0 4.5	4.8 3.4
		CIRC. WATER IN	65	65	65	69	68	72			UPTAKE						
		CIRC. WATER OUT	75	76	78	79	80	82			MAIN STEAM	680	680	690	680	680	670
		L.O. TO COOLERS	128	128	128	129	128	130			SUPER HEAT	435	435	430	450	450	440
		L.O. FROM COOLERS	110	109	108	110	110	109			F.O. TO BURNERS	200	200	210	210	210	200
		TEMPERATURE THRUST BEARING	118	120	120	119	120	120			F.O. TEMP. IN SETTLING TANKS	102 105	103 105	110 110	110 105	100 100	102 102
		FORWARD H.P. ROTOR BEARING	125	125	125	127	125	125			PORT BOILER UPTAKE	340	335	330	350	345	360
											STBD. BOILER UPTAKE	325	330	325	320	330	340
MACHINERY PARTICULARS	TEMPERATURES							MISCELLANEOUS		ENGINE ROOM TEMPERATURE	75	76	76	76	76	80	
										FIRE ROOM TEMPERATURE	75	76	76	76	76	80	
										NOZZLES IN USE	18	18	18	18	18	18	
										NO. OF BURNERS IN USE	6	6	6	6	6	6	
										BURNER TIP SIZE	53 70	53 70	53 70	53 70	53 70	53 70	
										CO2 % PORT BOILER		-	-	21 1/2%	21 1/2%	-	
										CO2 % STBD. BOILER		-	-	21 1/2%	21 1/2%	-	
							OIL LEVEL MAIN SUMP	1'2"	1'2"	1'2"	1'2"	1'2"	1'2"				

GENERATORS											FUEL - WATER AND LUBE OIL			
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS		
1200 TO 1600	1	1200	435		9	118	110		62	1050	1050	235	METER AT NOON	10037710
	2	1200	435		7	120	118		58	1050	1050	235	METER PREVIOUS NOON	10021450
1600 TO 2000	1	1200	430		9	130	118		62	1000	1000	240	CONSUMED BY METER	16160
	2	1200	430		7	118	110		58	1000	1000	240	ON HAND AT START OF DAY	17496
2000 TO 2400	1	1200	430		9	118	110		62	850	850	240	RECEIVED DURING DAY	-0-
	2	1200	430		7	130	112		58	1150	1050	240	EXPENDED DURING DAY	731
2400 TO 0400	1	1200	435		9	120	110		62	950	950	240	REMAINING ON BOARD	16765
	2	1200	435		7	128	116		58	1000	1000	240	ON HAND AT START OF DAY	1045
0400 TO 0800	1	1200	450		9	128	110		62	1200	1000	240	EVAPORATED OR RECEIVED	104
	2	1200	450		7	120	116		58	1200	1000	240	ON HAND	871
0800 TO 1200	1	1200	435		9	120	120		62	1050	1050	240	CONSUMED	278
	2	1200	435		7	130	114		58	1150	1050	240	LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)	

L.O. CENTRIFUGE - HOURS OPERATED					
1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
4	4	4 1/2	4 1/2	4 1/2	4

SUMMARY			
RUNNING TIME	1500	PERCENT OF SLIP	10.4
DETENTION TIME	-0-	BBL FUEL/MI	8.33
TOTAL REVOLUTIONS	146560	WIND DIRECTION	
AVERAGE R.P.M.	97.7	STATE OF SEA	
TOTAL MILES BY ENGINE	546	STATE OF WEATHER	
TOTAL MILES BY OBSERVATION	489		

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ. MACH. IN OPERATION *1+2 Boilers 1+2 F.W. Blowers 1+2 F.O.S. P.M.P.S. 1+2 M.N. Feed P.M.P.S. M.N. AIR COMPRESSOR. M.N. & M.AUX AIR EJECTORS. M & M.AUX CONDENSATE PUMPS. M.N. & M.AUX C.B.B. PUMPS L.O. PURIFIER. L.O.S. PUMP 1+2 AUX GENERATORS PORT STEERING GEAR. TESTED OVERSPEED TRIP & LOW L.O. ALARM ON M.N. TURBINE & THRUST. FIRE DRILL @ 1331 SEC. @ 1335 BOAT DRILL @ 1336 SEC. @ 1347 STBY @ 1331 L.H. @ 1349 CHECKED STEERING E.R. GEAR. PUMPED BILGES. MADE ROUTINE INSPECTIONS OF MACH. & ENGS SPACES.

WATCH ENGR'S SIGNATURE

Henry Bunn

1600-2000 WATCH

STEAMING AS BEFORE ON 18 NOZZLES. SHIFTED & CLEANED F.O. STRAINER PORT. SHIFTED TO IN BOARD SETTLER. HIT OFF CONTAMINATED ENAP. CHECKED ALL MACHINERY & SPACES.

WATCH ENGR'S SIGNATURE

Jim Jones

2000-2400 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; MADE ROUNDS & CHECKED ALL RUNNING MACH; PUMPED SETTLERS; CHANGED AND CLEANED STRA F.O. STRAINER; ON INBOARD SETTLER. J.B. ENAP. CHECKED STEERING GEAR, TOOK WATER SOUNDINGS AND CHECKED IN CONDENSATE LINE LEAK IN TROOP COMPARTMENT 4-4; BILGES PUMPED.

WATCH ENGR'S SIGNATURE

J.F. Edwards

2400-0400 WATCH

UNDERWAY ON 18 NOZZ. MACH AS BEFORE. CHANGED & CLEANED CENTER F.O. BURNERS & STAD DISCH STRAINER. RETARDED CLOCKS 20 MINS. @ 0100 CLEANED INSPECTED L.O. STRAINERS ON MAIN UNIT. CHECKED STEERING E.R. GEAR. PUMPED BILGES. HELD ENGS CASUALTY DRILL B-1 LOSS OF FUEL OIL PRESSURE WATCH INST & BRIDGE NOTIFIED 0300-0320. MADE ROUTINE INSPECTIONS OF MACH. & ENGS SPACES.

WATCH ENGR'S SIGNATURE

Henry Bunn

0400-0800 WATCH

STEAMING AS BEFORE 18 NOZZLES. 0500 TO 0530 HELD CASUALTY DRILL FIRE ROOM. B-1 LOSS OF F.O. PRESSURE. 4 MEN PRESENT. AT 0500 RETARDED CLOCK (20 MIN) CHEMICAL TEST OF FEED TANKS #1 PORT. 41 G.P.G. #1 L.H. 41 G.P.G. MAIN COND. 41 G.P.G. PUMPED BILGES AND CARGO HOLES. CHECKED ALL MACH. AND MACH. SPACES.

WATCH ENGR'S SIGNATURE

Jim Jones

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; BLEW TUBES @ 0905; NOTIFIED PLUMBERS OF LEAK IN COMP. 4-4; NOTIFIED ELECTRICIAN OF STOPPED BLOWER IN COMP. 4-3 @ 0900. F.O. BEING GRAVITATED TO TANKS 1 S, 2 P+S, 4 & 5 P+S AND 6 P+S FROM 4 & DP @ 1000. PUMPED UP SETTLERS FROM 4 & DP 1000-1020 HELD CASUALTY DRILL IN FIRE ROOM B-1 LOSS OF F.O. PRESS. 4 MEN PRESENT. MADE ROUNDS AND CHECKS OF ALL RUNNING MACH. STARTED PUMPING OUT #4 HOLD P+S. @ 1045; STARBOARD BOILER SAFETY LIFTED @ 460" @ 1147; CHANGED TOP BURNERS.

WATCH ENGR'S SIGNATURE

J.F. Edwards

CHIEF ENGINEER

BOILER WATER READINGS

WS STB'D FS PORT WS - FS
 96 HOURS 96 HOURS 96 - 96
 AKL 8.18 AKL 8.76
 T-AKL 14.60 T-AKL 12.26
 SAL. 2.49 SAL. 3.73
 PHOS. 4.5 PHOS. 4.5
 R.ph 10.0 R.ph 10.0

CHIEF ENGR'S SIGNATURE

[Signature]

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ. MACH IN OPERATION #1+2 BOILERS 1+2 F.D. BLOWERS 1+2 F.O.S. PUMPS 1+2 MN. F.P. PUMPS. L.O.S. PUMP. L.O. PURIFIER. MN+ AUX AIR EJECTORS. MN+ AUX CIRC PUMPS. MN+ AUX CONDENSATE PUMP. 1+2 AUX GENERATORS. TESTED OVERSPEED TRIP LOW L.O. ALARM ON MN. TURBINE & THROT. CHECKED STEERING E.R. GEAR. PUMPED BILGES. DAILY TEST OF STBY L.O. PUMP FOR 1/2 HR. MADE ROUTINE INSPECTIONS OF MACH & ENGS SPACES.

MN COND. .41 GPG

WATCH ENGR'S SIGNATURE-

Henry Bunney

1600-2000 WATCH

STEAMING AS BEFORE ON 18 NOZZLES. AT 1555 BLEW TUBES IN #1+2 BOILERS. SHIFTED AND CLEANED BOTTOM BURNER IN #1+2 BOILERS. AT 1800 SHIFTED TO INBOARD SETTLER. CHECKED ALL OPERATING MACH.

Main Cond. .41 G.P.G.

WATCH ENGR'S SIGNATURE-

J.M. Jones

2000-2400 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; ADDED 3 GALS L.O. TO #2 FEED PUMP; CHANGED AND CLEANED L.O. STRAINERS ON GEN.; PUMPED UP SETTLERS FROM 4 & D.P.; MADE ROUNDS AND CHECKED ALL RUNNING MACH.; FINISHED PUMPING UP SETTLERS CHANGING F.O. TRANSFER PUMP SUCT. TO 4 P.T.S. CHANGED AND CLEANED F.O. SUCT. STRAINER. PUMPED OUT #4 HOLD P.; JR. ENGR. CHECKED STEERING GEAR AND TOOK WATER SAMPLES;

MN COND. .41 GPG

WATCH ENGR'S SIGNATURE-

J.F. Edwards

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE CHANGED & CLEANED CENTER F.O. BURNERS & STBD DISCH STRAINER. SECURED & CLEANED L.O. PURIFIER @ 2400 BACK ON THE LINE @ 0030. INSPECTED & CLEANED MN L.O. DISCH STRAINER. BROKE OUT CHIEF ELECT TO MAKE REPAIRS ON DOUGH MIXER Bk 1ST ASST @ 0100. CROSSED AUX PLANT OVER TO MAIN @ 0110. CHECKED STEERING E.R. GEAR. PUMPED BILGES. DAILY TEST OF STBY L.O. PUMP FOR 1-HR. MADE ROUTINE INSPECTIONS OF MACH & ENGS SPACES.

MN COND. .41 GPG

WATCH ENGR'S SIGNATURE-

Henry Bunney

0400-0800 WATCH

STEAMING AS BEFORE ON 18 NOZZ. SHIFTED AND CLEANED BOTTOM BURNER IN #1+2 BOILERS. PUMPED BILGES & CARGO HOLES. SHIFTED F.O. SUCTION TO OUTBOARD SETTLER. GREASED UNIVERSAL JOINTS ON MACH SHAFTS TO SETTLERS. TIGHTENED UP CASING PACKING GLANDS ON SEW BLOWERS. CHECKED ALL OPERATING MACH.

Main Cond. .41 G.P.G.

WATCH ENGR'S SIGNATURE-

J.M. Jones

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; BLEW TUBES @ 0810, PUMPED SETTLERS TAKING F.O. FROM 4 P.T.S. DP.; CHANGED AND CLEANED GEN L.O. STRAINERS; CHANGED TOP BURNERS; JR. CHECKED STEERING GEAR. MADE ROUNDS AND CHECKED ALL RUNNING MACH.; GREASED MN. CIRC AND BILGE PUMPS

MN COND. .41 GPG

WATCH ENGR'S SIGNATURE-

J.F. Edwards

CHIEF ENGINEER

BOILER WATER READINGS

WS STB'D P.S. PORT WS - FS
 120 HOURS 120 HOURS 120 - 120
 AKL 5.84 AKL 8.70
 T-AKL 8.76 T-AKL 12.85
 SAL. 2.49 SAL. 3.31
 PHOS. 30 PHOS. 35
 R.ph 10 R.ph 10

CHIEF ENGR'S SIGNATURE-

J.M. Jones

USNS		VOYAGE NO.		FROM		TO		TYPE OF VESSEL		DATE											
Gen John Pope TAF-110		6-A		OAKLAND CALIF		OKINAWA		P2 R2-R2		11-26-27-41											
		WATCH								WATCH											
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200			1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200						
RUNNING TIME		240	240	260	260	260	240	MACHINERY PARTICULARS (CONT'D)	TEMPERATURES (CONT'D)	AFT. H. P. ROTOR BEARING						137	135	135	135	135	135
DETENTION TIME										FORWARD L. P. ROTOR BEARING						133	135	133	134	130	133
REVOLUTION COUNTER (END OF WATCH)		1498	1500	1502	1505	1507	1510			AFT. L. P. ROTOR BEARING						129	125	127	128	125	127
TOTAL REVOLUTIONS (FOR WATCH)		23400	23520	25490	25430	25140	23250			HOTTEST GEAR BEARING FORWARD						158	160	160	160	160	160
AVERAGE RPM		97.5	98.0	98.0	97.8	96.6	96.9			HOTTEST GEAR BEARING AFT						148	148	147	148	148	147
F.O. METER (END OF WATCH)		1005	1005	1006	1002	1006	1006			AUX. COND. CONDENSATE						96	105	102	98	106	102
F.O. CONSUMED		2560	2520	2810	2720	2670	2620			1ST STAGE FEED WATER HEATER						155	158	156	155	156	156
										D. C. FEED WATER HEATER						238	240	238	238	240	238
										2ND STAGE FEED WATER HEATER						155	158	156	155	156	156
										ROTOR BEARING						137	135	135	135	135	135
MACHINERY PARTICULARS	PRESSURES	THROTTLE		430	430	430	430	430	430	F.O. TO BURNERS		190	190	190	190	180	180	190			
		H.P. AHEAD		430	430	430	430	430	430	F.O. BACK PRESSURE		10	10	10	10	10	11				
		L.P. AHEAD		21	22	21	21	21	21	PRESSURE AIR TO FURNACE		4.5	5.0	4.8	5.2	5.2	4.6				
		VACUUM		28.8"	28.5"	28.25"	28.8"	27"	28.4"	UPTAKE											
		L.O. TO TURBINES		12	12	12	12	12	12	MAIN STEAM		680	680	680	680	695	700				
		AUX. STEAM		150	150	150	150	150	145	SUPER HEAT		440	430	430	430	430	430				
		BACK PRESSURE		9	9	9	9	9	9	F.O. TO BURNERS		195	190	180	195	200	195				
		GLAND STEAM		2	3	3	3	2	3	F.O. TEMP. IN SETTLING TANKS		112	112	110	108	105	120				
		H.P. BLEEDER		72	80	70	73	72	70	PORT BOILER UPTAKE		315	320	325	335	340	325				
		L.P. BLEEDER		14	10	13.5"	13.5"	14"	14"	STBD. BOILER UPTAKE		310	310	312	330	330	315				
MACHINERY PARTICULARS	TEMPERATURES	STEAM AT THROTTLE		680	680	690	680	695	700	ENGINE ROOM TEMPERATURE		83	80	80	79	80	79				
		L.P. EXHAUST		102	100	102	102	102	102	FIRE ROOM TEMPERATURE		83	80	80	79	80	79				
		CONDENSATE		96	96	96	98	96	96	NOZZLES IN USE		18	18	18	18	18	18				
		CIRC. WATER IN		72	72	75	73	73	75	NO. OF BURNERS IN USE		6	6	6	6	6	6				
		CIRC. WATER OUT		85	86	84	85	84	84	BURNER TIP SIZE		53/70	53/70	53/70	53/70	53/70	53/70				
		L.O. TO COOLERS		128	128	126	128	127	126	CO2 % PORT BOILER						19.9					
		L.O. FROM COOLERS		109	108	106	109	106	106	CO2 % STBD. BOILER						20.4					
		TEMPERATURE THRUST BEARING		118	120	117	118	120	117	OIL LEVEL MAIN SUMP		1'2"	1'2"	1'2"	1'2"	1'2"	1'2"				
		FORWARD H.P. ROTOR BEARING		129	130	137	128	125	127												

GENERATORS													FUEL - WATER AND LUBE OIL						
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL		BOILER WATER		LUBE OIL		
1200 TO 1600	1	1200	430	680	9	122	112		62	1150	1150	230	METER AT NOON	10068850	ON HAND AT START OF DAY	85			
	2	1200	430	680	7	133	120		58	1050	1050	230	METER PREVIOUS NOON	10052950	EVAPORATED OR RECEIVED	42			
1600 TO 2000	1	1200	430	680	9	120	110		62	1000	1000	230	CONSUMED BY METER	15900	ON HAND	85			
	2	1200	430	680	7	130	118		58	1000	1000	230	ON HAND AT START OF DAY	16069	CONSUMED	42			
2000 TO 2400	1	1200	430		9	120	110		62	900	900	230	RECEIVED DURING DAY	-0-	ON HAND AT START OF DAY	3390			
	2	1200	430		7	132	118		58	1100	1000	230	EXPENDED DURING DAY	239	RECEIVED	-0-			
2400 TO 0400	1	1200	430		9	120	110		62	900	900	230	REMAINING ON BOARD	15330	ON HAND	3370			
	2	1200	430		7	132	118		58	1100	1000	230	ON HAND AT START OF DAY	903	CONSUMED	20			
0400 TO 0800	1	1200	430	695	9	120	110		62	1000	1000	230	EVAPORATED OR RECEIVED	180	1525				
	2	1200	430	695	7	132	118		58	1000	1000	230	ON HAND	978	ON HAND 1520				
0800 TO 1200	1	1200	430	700	9	120	110		62	1100	1100	230	CONSUMED	105	5				
	2	1200	430	700	7	132	118		58	1000	950	230	LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)						
L.O. CENTRIFUGE - HOURS OPERATED																			
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200												
		4	4	4 1/2	4 1/2	4 1/2	4												
SUMMARY																			
		RUNNING TIME		1500		PERCENT OF SLIP		Pos. 16.2											
		DETENTION TIME		-0-		BBL FUEL/MI		1.37 1.54											
		TOTAL REVOLUTIONS		14425		WIND DIRECTION		050°											
		AVERAGE R.P.M.		96.2		STATE OF SEA		Heavy swell											
		TOTAL MILES BY ENGINE		838		STATE OF WEATHER		65°											
		TOTAL MILES BY OBSERVATION		478															

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ MACH IN OPERATION #1 & 2 BOILERS. 1 & 2 F.A. BLOWERS. 1 & 2 F.O.S. PUMPS. 1 & 2 M.N. FEED PUMP. MAIN AIR EJECTOR. AMN COND PUMP. M.N. CIRC PUMP. L.O. PURIFIER. L.O.S. PUMP. FIRE & SAN. PUMP. 1 & 2 AUX GENERATORS. AUX AIR EJECTOR. COND. PMP. & AUX CIRC PMP. OVER to MAIN. Tested OVERSPEED TRIP LOW L.O. ALARM ON M.N. TURBINE & THRUST. Checked STEERING GEAR. PUMPED Bilges. Shifted F.O. SUCT to PORT INBD STRAINER @ 1500. Secured heating STEAM @ 1530. As 1st ASST. MADE ROUTINE INSPECTIONS OF MACH. & ENGR SPACES. M.N. COND. .41 GPG.

WATCH ENGR'S SIGNATURE.

1600-2000 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. Blew Tubes on #1 & 2 BOILERS WITH PERMISSION FROM BRIDGE. Changed AND CLEANED Bottom F.O. BURNERS & PORT DISCH STRAINER. PUMPED #4 hold P.S. JR. MADE STEERING GEAR ROUNDS FROM REPEATING TOWN M.T. Pumped UP SAME. SCUTTLE BUTT IN TROOP CAMP 4-6 SUGAR, HEATING BAKY.

M.N. COND. .41 GPG

WATCH ENGR'S SIGNATURE.

2000-2400 WATCH

STEAMING AS BEFORE ON 18 NOZZES; Filled SCUTTLERS FROM 4 P.S. DP. ADDED 6 GALS L.O. TO #2 FEED PUMP; Secured TUBES IN 3-7 TROOP HEAD (OVERFLOWING) BRUSHES SPARKING EXCESSIVELY ON #1 GEN. CALLED CHIEF ENGR. AND CH. ENGR.; STEAM ON TO HEATING COILS 3K DP; STEERING GEAR CHECKED B, JR. MADE ROUNDS AND CHECKED ALL RUNNING MACH; RETARDED CLOCKS 20 MIN. @ 2300.

M.N. COND. .41 GPG

WATCH ENGR'S SIGNATURE.

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. Changed & CLEANED CENTER F.O. BURNERS & STBD DISCH STRAINER. Retarded CLOCKS 20 MINS @ 0100. Shifted & CLEANED MAIN L.O. STRAINER. DAILY Test of STBY L.O. PUMP FOR 1-HR. Checked STEERING GEAR. PUMPED Bilges. MADE ROUTINE INSPECTIONS OF MACH & ENGR SPACES.

M.N. COND. .41 GPG

WATCH ENGR'S SIGNATURE.

0400-0800 WATCH

STEAMING AS BEFORE ON 18 NOZZ. at 0500 Retarded CLOCKS (20 min) Shifted and Cleaned main L.O. strainer. Changed & Cleaned bottom burner in #1 & 2 boilers. Pumped bilges and cargo hold. Shifted to anchor & settler. Checked all machinery. Made routine inspection of outside spaces.

Main Cond. .41 G.P.G.

WATCH ENGR'S SIGNATURE.

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZES; Pumped up SCUTTLERS FROM 4 P.S. DP; CHANGED AND CLEANED F.O. SUCT. STRAINER; CHANGED AND CLEANED GEN. L.O. STRAINERS; CHANGED AND CLEANED TOP BURNERS; Blew TUBES @ 0805; JR. CHECKED STEERING GEAR AND STEPPED UP VARNAB IN TROOP CAMP. 3-7. Collected CH. PLUMBER & CH. ENGR. MADE ROUNDS AND CHECKED ALL RUNNING MACH.

M.N. COND. .41 GPG

WATCH ENGR'S SIGNATURE.

CHIEF ENGINEER

BOILER WATER READINGS

STB'D-FS - PORT WS - FS

HOURS 12.4 HOURS 12.4 - 12.4

AKL 9.34 AKL 8.18

T-AKL 14.60 T-AKL 12.26

SAL. 3.31 SAL. 3.31

PHOS. 40 PHOS. 35

R.ph 10.5 R.ph 10.5

CHIEF ENGR'S SIGNATURE.

USNS GEN JOHN POPE T-110 6-A OAKLAND CALIF OIKINAWA P2-52-R2 11-27-28-66

WATCH							WATCH						
	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
MACHINERY PARTICULARS													
TEMPERATURES													
PRESSURES													
MISCELLANEOUS													
MACHINERY PARTICULARS (CONT'D)													
TEMPERATURES (CONT'D)													
PRESSURES (CONT'D)													
MISCELLANEOUS (CONT'D)													

GENERATORS													FUEL - WATER AND LUBE OIL						
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL		BOILER WATER		LUBE OIL		
1200 TO 1600	1	1200	430	690	9	121	111		62	1050	1050	230	METER AT NOON	10084880	ON HAND AT START OF DAY	86			
	2	1200	430	691	7	132	119		58	1150	1150	230	METER PREVIOUS NOON	10068850	EVAPORATED OR RECEIVED	57			
1600 TO 2000													CONSUMED BY METER	1600	ON HAND	106			
	1	1200	430	695	9	120	110		62	1250	1250	230	ON HAND AT START OF DAY	15330	CONSUMED	36			
	2	1200	430	696	7	130	120		58	1250	1250	230	RECEIVED DURING DAY	-0-	ON HAND AT START OF DAY	3320			
													EXPENDED DURING DAY	986	RECEIVED	-0-			
2000 TO 2400													REMAINING ON BOARD	14544	ON HAND	20			
	1	1200	430	695	9	120	110		62	950	950	230	ON HAND AT START OF DAY	978	CONSUMED	3350			
	2	1200	430	696	7	130	120		58	1250	1250	230	EVAPORATED OR RECEIVED	150		1520			
													ON HAND	903	ON HAND	1518			
2400 TO 0400													CONSUMED	226		2			
														LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)					
L.O. CENTRIFUGE - HOURS OPERATED																			
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200												
		4	4	4 1/2	4 1/2	4 1/2	4												
SUMMARY																			
		RUNNING TIME		1500		PERCENT OF SLIP		pos. 10.4											
		DETENTION TIME		-0-		BBL FUEL/MI		1.45											
		TOTAL REVOLUTIONS		144480		WIND DIRECTION		070'											
		AVERAGE R.P.M.		96.3		STATE OF SEA		AV. swell											
		TOTAL MILES BY ENGINE		839		STATE OF WEATHER		66'											
		TOTAL MILES BY OBSERVATION																	

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ. MACH IN OPERATION #1+2 Boilers 1+2 F.D. Blowers 1+2 MN F.D. Pumps 1+2 FES. Pumps MAIN AIR Ejector. MN. FIRE PUMP 2 MN COND. PMP. L.O. purifier. L.O.S. PUMP 1+2 AUX GENERATORS. AUX AIR Ejector. COND. & FIRE PUMPS OVER TO MAIN FIRE & SAN PUMP. Tested OVERSPEED TRIP & LOW L.O. ALARM ON MN TURBINE & THROTT. PUMPED Bilges. Checked Steering E.R. Gear. Made Routine INSPECTIONS of MACH & ENGR SPACES.

WATCH ENGR'S SIGNATURE

George Bunnay

1600-2000 WATCH

Steaming as before on 18 NOZZ. At 1600 blew tubes on #1+2 boilers, at 1700 shifted to outboard settler. At 1740, W.T. Down closed from bridge. Pumped bilges and Cargo hold. Checked all operating mach. Checked & inspected S.E. Room. Shifted and cleaned Port F.O. strainer.

WATCH ENGR'S SIGNATURE

John Jones

2000-2400 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; SHIFTED TO INBOARD SETTLER @ 2300; Pumped up Settlers from 3 & 4 DP.; Added 2 Gals L.O. To #1 F.D. Pump, and 4 Gals L.O. To #2 F.D. Pump. Checked STEERING GEAR. Made Rounds and checked all Running MACH. CHANGED AND CLEANED GEN. L.O. STRAINERS. RETARDED Clocks @ 2300.

WATCH ENGR'S SIGNATURE

J.F. Edwards

MN COND. .41 GPG

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. CHANGED & CLEANED CENTER F.O. BURNERS & STD DISCH STRAINER. Retarded Clocks 20 MINS @ 0100. Shifted & CLEANED MAIN L.O. STRAINER. Daily test of stby L.O. pump for 1-hr. Held ENGR'S CASUALTY drill B-2 water in Fuel oil Watch Inst & Bridge Notified 0130-0200. Checked Steering E.R. Gear. PUMPED Bilges. Leaking Nipple in Cushion Chamber RETURN LINE ON Suct Side #1 MN F.D. pump fix rest notified. Made Routine INSPECTIONS of MACH & ENGR SPACES.

WATCH ENGR'S SIGNATURE

George Bunnay

0400-0800 WATCH

Steaming as before on 18 NOZZ at 0420 retarded Clocks (20 min) 0500 to 0530 held Casualty drill B-2 water in F.O. instructed the watch and notified the bridge. 0600 shifted F.O. suction to outboard settler. CHANGED AND CLEANED bottom burner in #1+2 boilers. Checked S.E. room. Carried out Standing and Night orders.

WATCH ENGR'S SIGNATURE

John Jones

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZLES; Blew Tubes @ 0815; Seamed #1 MN F.D. Pump @ 0835 To Renew Nipple in Cushion Chamber Suct. line; #1 MN F.D. Pump back on line @ 0935; CHANGED AND CLEANED TOP BURNERS; CHANGED AND CLEANED F.O. SUCT. STRAINER. Pumped up Settlers from 3 & 4 DP.; CASUALTY DRILL B-2 water in Fuel Oil 1000-1120 4 MEN PRESENT. Made Rounds and checked all Running MACH.; Added 2 Gals L.O. #2 MN F.D. pump; GEN. L.O. STRAINER CHANGED AND CLEANED.

WATCH ENGR'S SIGNATURE

J.F. Edwards

MN. COND. .41 GPG

CHIEF ENGINEER

BOILER WATER READINGS

WS STE'D F.O. PORT WS - F.S

148 HOURS 148 HOURS 148 - 148

AKL 7.01 AKL 6.42

T-AKL 10.57 T-AKL 11.68

SAL. 2.90 SAL. 3.31

PHOS. 50 PHOS. 35

R.ph 10.5 R.ph 10.5

CHIEF ENGR'S SIGNATURE

J.F. Edwards

USNS GEN John Pope Tag-120 VOYAGE NO. 6-A FROM OAKLAND CALIF TO OKINAWA TYPE OF VESSEL P2-S2-R2 DATE 11-28-29-61

WATCH							WATCH						
	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
RUNNING TIME	240	240	260	260	240	240	MACHINERY PARTICULARS (CONT'D)	AFT. H. P. ROTOR BEARING	135	135	135	135	135
DETENTION TIME								FORWARD L. P. ROTOR BEARING	132	130	132	132	132
REVOLUTION COUNTER (END OF WATCH)	1527 3030	1529 6610	1532 2100	1534 7620	1537 2910	1539 6290		AFT. L. P. ROTOR BEARING	128	125	129	128	127
TOTAL REVOLUTIONS (FOR WATCH)	23370	23580	25490	25520	25290	23380		HOTTEST GEAR BEARING FORWARD	160	160	160	160	160
AVERAGE RPM	97.5	98.0	98.0	98.1	97.2	97.4		HOTTEST GEAR BEARING AFT	145	145	147	145	147
F.O. METER (END OF WATCH)	1008 7490	1009 0030	1009 2800	1009 5700	1009 8460	1010 1160		AUX. COND. CONDENSATE	P 105 S 104	102	102	98	105 104 103
F.O. CONSUMED	2610	2540	2770	2700	2760	2700		1ST STAGE FEED WATER HEATER	152	156	160	158	156
MACHINERY PARTICULARS	PRESSURES	THROTTLE	430	430	440	430		D. C. FEED WATER HEATER	242	240	240	238	240
		H.P. AHEAD	430	430	435	430		2ND STAGE FEED WATER HEATER	1050				
		L.P. AHEAD	20	20	21	21		F.O. TO BURNERS	P 177 S 180	175	190 190	185 180	175 186 195
		VACUUM	28.2	28"	28"	28"		F.O. BACK PRESSURE	15	15	13	12	12 10
		L.O. TO TURBINES	12	12	12	12		PRESSURE AIR TO FURNACE	P 5 S 3	5.0 3.0	4.8 3.1	5.2 4.6	5.2 3.3 5.6 3.6
		AUX. STEAM	140	135	140	140		SALINITY	.41	.41		.41	.41
		BACK PRESSURE	9	9	9	9		MAIN STEAM	690	698	680	690	695 695
		GLAND STEAM	2	2	2.5	2.5		SUPER HEAT	430	430	440	440	430 435
		H.P. BLEEDER	72	72	74	72		F.O. TO BURNERS	P 200 S 190	200 200	190 200	185 190	190 200 185 200
		L.P. BLEEDER	13	13"	13"	13"		F.O. TEMP. IN SETTLING TANKS	P 110 S 110	110 115	104 111	104 106	100 100 102 124
MACHINERY PARTICULARS	TEMPERATURES	STEAM AT THROTTLE	690	690	680	640	BOILER PARTICULARS	PORT BOILER UPTAKE	330	325	316	330	335 328
		L.P. EXHAUST	102	102	102	102		STBD. BOILER UPTAKE	315	320	316	320	330 321
		CONDENSATE	95	96	99	98		ENGINE ROOM TEMPERATURE	84	84	84	84	84 86
		CIRC. WATER IN	74	72	75	75		FIRE ROOM TEMPERATURE	84	84	84	84	84 86
		CIRC. WATER OUT	86	86	86	86		NOZZLES IN USE	18	18	18	18	18 15
		L.O. TO COOLERS	126	126	127	129		NO. OF BURNERS IN USE	6	6	6	6	6 6
		L.O. FROM COOLERS	106	106	107	107		BURNER TIP SIZE	53 53 53 53	53 53 53 53	53 53 53 53	53 53 53 53	53 53 53 53
		TEMPERATURE THRUST BEARING	116	115	117	116		CO2 % PORT BOILER					19 19 19 19
		FORWARD H.P. ROTOR BEARING	130	125	127	128		CO2 % STBD. BOILER					20 20 20 20
								OIL LEVEL MAIN SUMP	1'2"	1'2"	1'2"	1'2"	1'2" 1'2"

GENERATORS													FUEL - WATER AND LUBE OIL						
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL		BOILER WATER		LUBE OIL		
1200 TO 1600	1	1200	430	690	9	120	110		62	1250	1250	230	METER AT NOON	10101160		ON HAND AT START OF DAY	106		
	2	1200	430	690	7	133	120		58	1150	1050	230	METER PREVIOUS NOON	10084880		EVAPORATED OR RECEIVED	55		
													CONSUMED BY METER	16280		ON HAND	115		
1600 TO 2000	1	1200	430	690	9	120	110		62	1100	1100	230	ON HAND AT START OF DAY	14544		CONSUMED	46		
	2	1200	430	690	7	132	120		58	1100	1000	230	RECEIVED DURING DAY	767		ON HAND AT START OF DAY	3350		
													EXPENDED DURING DAY	13777		RECEIVED	-0-		
2000 TO 2400	1	1200	440	680	9	120	110		62	1000	1000	230	REMAINING ON BOARD			ON HAND	3340		
	2	1200	440	680	7	132	120		58	1100	1050	230	ON HAND AT START OF DAY	203		CONSUMED	10		
													EVAPORATED OR RECEIVED	154			1518		
2400 TO 0400	1	1200	430	690	9	120	110		62	950	950	230	ON HAND	900		ON HAND	1515		
	2	1200	430	690	7	132	120		58	1000	1000	230	CONSUMED	157			3		
													LOW PRESS. EVAPORATORS (No. of hrs. operated)(Fresh water made gals.)						
													L.O. CENTRIFUGE - HOURS OPERATED						
0400 TO 0800	1	1200	430	690	9	120	110		62	1150	1150	230	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200	
	2	1200	430	690	7	132	120		58	1000	1000	230	4	4	4 1/3	4 1/3	4 1/3	4	
0800 TO 1200	1	1200	430	690	9	120	110		62	1250	1250	230	SUMMARY						
	2	1200	430	690	7	132	120		58	1000	1000	230	RUNNING TIME	1500	PERCENT OF SLIP	Pos. 9.07			
													DETENTION TIME	0	BBL FUEL/MI	1.42 1.56			
	1	1200	430	690	9	120	110		62	1250	1250	230	TOTAL REVOLUTIONS	144795	WIND DIRECTION	170			
	2	1200	430	690	7	132	120		58	1000	1000	230	AVERAGE R.P.M.	96.5	STATE OF SEA	924 swell			
	1	1200	430	690	9	120	110		62	1250	1250	230	TOTAL MILES BY ENGINE	540	STATE OF WEATHER	92			
	2	1200	430	690	7	132	120		58	1000	1000	230	TOTAL MILES BY OBSERVATION	491					

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ. MACH. IN OPERATION #1 & 2 Boilers 1 & 2 F.W. Blowers 1 & 2 F.O.S. PUMPS. 1 & 2 M.N. F.W. PUMPS. MAIN AIR EJECTOR. M.N. CIRC. PMP. 2 M.N. COND. PMP. L.O. PURIFIER. L.O.S. PUMP. FIRE & SAN. PMP. AUX. AIR EJECTOR. AUX. CIRC. & COND. PMPs OVER TO MAIN. TESTED OVERSPEED TRIP. LOW L.O. ALARM ON M.N. TURBINE & THROTT. CHECKED STEERING E.R. GEAR. PUMPED Bilges. Shifted F.O. Suct. to PORT INBD @ 1540. MADE ROUTINE INSPECTIONS OF MACH & ER SPACES. Added 2 GAL L.O. to #2 M.N. FEED PUMP.

WATCH ENGR'S SIGNATURE

George Bunnag

1600-2000 WATCH

STEAMING AS BEFORE ON 18 NOZZ. 1600 to 1625 blew tubes on #1 & 2 boilers. Added 1 gal. oil to #2 feed pump. Shifted and cleaned bottom burner in #1 & 2 boilers. Checked all mach. inspected outside spaces. trouble call from troop Comp. 3-2 - stopped up Commode J. Eng. Checked out same. Chief Eng. said leave till morning.

WATCH ENGR'S SIGNATURE

Jim Jones

2000-2400 WATCH

STEAMING AS BEFORE ON 18 NOZZES; FINISHED PUMPING UP SETTLERS FROM 3 P+S; CHANGED AND CLEANED GEN. L.O. STRAINERS; MADE ROUNDS AND CHECKED ALL RUNNING MACH.; JR. CHECKED STEERING GEAR AND TOOK WATER SOUNDINGS. BRUSHES ON #1 GEN. SPARKING, CLEANED COMMUTATOR, SPARKING - CLEANED UP.

WATCH ENGR'S SIGNATURE

J. Edwards

M.N. COND. 41 GPG

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. CHANGED & CLEANED CENTER F.O. BURNERS & STD DISCH STRAINER. Shifted & CLEANED MAIN L.O. STRAINER. Retarded Clocks 20 mins @ 0100. Daily test of stby L.O. pump for 1-hr. Checked steering E.R. Gear. Pumped Cargo holds Bilges. MADE ROUTINE INSPECTIONS OF MACH & ENGS SPACES.

WATCH ENGR'S SIGNATURE

George Bunnag

0400-0800 WATCH

STEAMING AS BEFORE ON 18 NOZZES; AT 0400 retarded Clocks (20) min. CHANGED AND CLEANED bottom burner in #1 & 2 boilers. at 0501 stby. 0527 LH. shifted and cleaned main L.O. strainers. 0600 trouble call from troop Comp. # 4-3. Ventilation out. Checked all operating mach. at 0700 shifted F.O. Suct. to outboard settlers.

WATCH ENGR'S SIGNATURE

Jim Jones

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZES; BLOW TUBES @ 0815; CHANGED AND CLEANED TOP BURNERS; CHANGED AND CLEANED F.O. Suct STRAINER; Pumped up Settlers from 3 P+S; TOOK 2 M.N. DRAG ON 4 P+S & 4; CHANGED AND CLEANED GEN. L.O. STRAINER; PUMPED OUT 1st hold # 3 S & # 4 S; MADE ROUNDS AND CHECKED ALL RUNNING MACH.; NOTIFIED ELECTRICIAN OF STOPPED Supply Vent. IN Troop Comp. 4-3.

WATCH ENGR'S SIGNATURE

J. Edwards

M.N. COND. 183 GPG.

CHIEF ENGINEER

BOILER WATER READINGS

WS STB'D FS PORT WS - FS.
172 HOURS 172 HOURS 172 - 172
AKL 7.01 AKL 7.39
T-AKL 11.68 T-AKL 11.10
SAL. 2.49 SAL. 3.31
PHOS. 38 PHOS. 38
R-ph 10.0 R-ph 10.0

CHIEF ENGR'S SIGNATURE

J. Edwards

502-508-509-

USNS GEN JOHN POPE TAP-110 VOYAGE NO. 6-A FROM OAKLAND CALIF TO OKINAWA TYPE OF VESSEL P2-52-A2 DATE 11-29-66 Met. Day 1 Dec. 66

WATCH							WATCH						
	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
RUNNING TIME	240	240	240	240	240	240	MACHINERY PARTICULARS (CONT'D)	AFT. H. P. ROTOR BEARING	135	135	135	135	135
DETENTION TIME								FORWARD L. P. ROTOR BEARING	132	130	131	130	131
REVOLUTION COUNTER (END OF WATCH)	1541	1544	1546	1548	1551	1553	TEMPERATURES (CONT'D)	AFT. L.P. ROTOR BEARING	128	125	127	125	125
TOTAL REVOLUTIONS (FOR WATCH)	23330	22880	23150	22890	22910	23030		HOTTEST GEAR BEARING FORWARD	160	160	160	160	159
AVERAGE RPM	97.2	95.3	96.5	95.3	95.4	96.0	MACHINERY PARTICULARS	HOTTEST GEAR BEARING AFT	145	146	145	145	145
F.O. METER (END OF WATCH)	1010	1010	1010	1011	1011	1011		AUX. COND. CONDENSATE	97	109	102	99	105
F.O. CONSUMED	2630	2580	2630	2610	2630	2740	TEMPERATURES	1ST STAGE FEED WATER HEATER	159	156	155	158	159
THROTTLE	430	435	435	435	430	435		D. C. FEED WATER HEATER	238	242	236	235	240
H.P. AHEAD	430	430	430	430	430	430	PRESSURES	2ND STAGE FEED WATER HEATER	10500				
L.P. AHEAD	21	22	22	22	23	23		F.O. TO BURNERS	185	175	182	185	185
VACUUM	28"	28"	28.2"	28.2"	28.2	28.2	TEMPERATURES	F.O. BACK PRESSURE	10	10	10	10	10
L.O. TO TURBINES	12	12	12	12	12	12		APR TO FURNACE	5.5	5.0	4.6	4.8	5.3
AUX. STEAM	140	140	140	140	140	135	PRESSURES	SALINITY	4.2	3.0	3.0	3.6	3.3
BACK PRESSURE	9	9	8	9	9	9		MAIN COND.	.41	.41	.41	.41	.41
GLAND STEAM	2.5	3.5	3	3	3.5	3	TEMPERATURES	MAIN STEAM	690	695	690	680	700
H.P. BLEEDER	72	60	74	74	70	70		SUPER HEAT	448	435	435	440	430
I.P. BLEEDER	-	7			7		PRESSURES	F.O. TO BURNERS	205	195	195	195	200
L.P. BLEEDER	13	11	13	13	11	13		F.O. TEMP. IN SETTLING TANKS	104	104	113	112	112
STEAM AT THROTTLE	690	695	690	680	700	690	MISCELLANEOUS	PORT BOILER UPTAKE	335	330	326	330	335
L.P. EXHAUST	104	104	102	102	102	102		STBD. BOILER UPTAKE	325	315	317	330	335
CONDENSATE	97	96	97	99	98	98	TEMPERATURES	ENGINE ROOM TEMPERATURE	85	82	81	80	80
CIRC. WATER IN	73	74	76	73	72	74		FIRE ROOM TEMPERATURE	85	82	81	80	80
CIRC. WATER OUT	85	86	84	86	84	84	PRESSURES	NOZZLES IN USE	18	18	18	18	18
L.O. TO COOLERS	126	126	126	126	126	126		NO. OF BURNERS IN USE	6	6	6	6	6
L.O. FROM COOLERS	108	108	106	107	106	106	MISCELLANEOUS	BURNER TIP SIZE	52	53	53	53	53
TEMPERATURE THRUST BEARING	115	116	117	116	116	116		CO2 % PORT BOILER				19.4	19.4
FORWARD H.P. ROTOR BEARING	129	125	127	128	125	128	PRESSURES	CO2 % STBD. BOILER				20.4	20.4
								OIL LEVEL MAIN SUMP	1'2"	1'2"	1'2"	1'2"	1'2"

GENERATORS													FUEL - WATER AND LUBE OIL					
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL		BOILER WATER		LUBE OIL	
1200 TO 1600	1	1200	430	690	9	120	110		62	1150	1150	230	METER AT NOON	1011680	ON HAND AT START OF DAY	115		
	2	1200	430	690	7	132	120		58	1000	1000	230	METER PREVIOUS NOON	1010160	EVAPORATED OR RECEIVED	20		
1600 TO 2000	1	1200	435	695	9	120	110		62	1150	1150	230	CONSUMED BY METER	15820	ON HAND	102		
	2	1200	435	695	7	132	120		58	1000	950	230	ON HAND AT START OF DAY	13777	CONSUMED	33		
2000 TO 2400	1	1200	435	690	9	120	110		62	1000	1000	230	RECEIVED DURING DAY	-0-	ON HAND AT START OF DAY	3340		
	2	1200	435	690	7	132	120		58	1200	1100	230	EXPENDED DURING DAY	701	RECEIVED	-0-		
2400 TO 0400	1	1200	435	680	9	120	110		62	1050	1000	230	REMAINING ON BOARD	13076	ON HAND	3320		
	2	1200	435	680	7	132	118		58	1100	1100	230	ON HAND AT START OF DAY	900	CONSUMED	20		
0400 TO 0800	1	1200	430	700	9	120	110		62	1000	1000	230	EVAPORATED OR RECEIVED	167	1515			
	2	1200	430	700	7	132	118		58	1250	1150	230	ON HAND	874	ON HAND	1512		
0800 TO 1200	1	1200	435	690	9	120	110		62	1150	1100	230	CONSUMED	193	3			
	2	1260	435	690	7	132	120		58	1300	1300	230	LOW PRESS. EVAPORATORS (No. of hrs. operated)/(Fresh water made gals.)					
L.O. CENTRIFUGE - HOURS OPERATED													SUMMARY					
	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200	RUNNING TIME		PERCENT OF SLIP		BBL FUEL/MI							
	4	4	4	4	4	4	1440		16.3		1.37							
							-0-		1.64		1.64							
							136420		315		315							
							74.7		STATE OF SEA		WIND DIRECTION							
							509		STATE OF WEATHER		690							
							420											

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ MACH OPERATION. #1 & 2 Boilers 1 & 2 F.D. Blowers 1 & 2 F.O.S. PUMPS. 1 & 2 M.F.C.D. PUMPS. MAIN AIR EJECTOR. M.F.C.I.C. PUMP. 2 M.F.C.O. PUMP. L.O. PURIFIER. FIRE & S.A. PUMP 1 & 2 AUX GENERATORS. AUX AIR EJECTOR. CIRC & COND PUMPS. 1 & 2 MAIN PORT STEERING GEAR. Tested overspeed trip & Low L.O. ALARM ON M.F. TURBINE & THROT. Checked Steering E.R. GEAR. Pumped Cargo holds Bilges RUN & Tested A.C. unit. FIRE drill @ 1515 SEC @ 1525 But drill @ 1529 SEC @ 1541 Stry @ 1515 LT @ 1543 Shifted F.O. Suct to Port Tank

Sch @ 1530

1600-2000 WATCH

Steaming as before on 18 NOZZ. 1555 to 1615 blew tubes on #1 & 2 boilers. added 4 gal. oil to #1 main feed Pump. Eng. Dept. Safety meeting. 40 men Present. F.C. QUINN Ch. ENGR. Conducted. Duration of meeting. 1545 to 1615. Changed and Cleaned bottom burner in #1 & 2 boiler. Checked operating mach. inspected S.E. Room

WATCH ENGR'S SIGNATURE

Conditions normal.

WATCH ENGR'S SIGNATURE

2000-2400 WATCH

Steaming as before on 18 NOZZ. Excessive Sparking of Burners #1 Gen. changed commutator and burned Amalgam lead in unit. Sparking decreased to almost non-existent. changed and cleaned Gen. h.o. STRAINERS. Added 2 bales L.O. to #1 F.D. Pump. Pumped out 2 bales H.O. #1, 2, 3, 4 S and #4 P. JR. Checked Steering Gear and added oil to Replenishing Tank. Made Rounds and Checked all Running Mach. Pumped up Settlers from #3 PYS DB.

WATCH ENGR'S SIGNATURE

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. DO to CROSSING the DATE LINE ADVANCED ALL CLOCKS 24 HRS FOR 12-1-66. Changed & Cleaned Center F.O. BURNERS & std disch. STRAINER. Daily test of Stry L.O. pump for 1-hr. Shifted & Cleaned MAIN L.O. STRAINERS. Held Eng's Casualty drill B-3 Loss of feed Pump Suct Watch INST & Bridge notified 0130-0200. Checked Steering E.R. GEAR. Pumped Cargo holds Bilges. Made Routine inspections of Mach & Eng's Spaces.

WATCH ENGR'S SIGNATURE

0400-0800 WATCH

Steaming as before on 18 nozzles. Changed and Cleaned bottom burner in #1 & 2 boilers. shifted and cleaned main h.o. strainers. 0500 to 0530 held Casualty drill B-3 Loss of feed Pressure. Eng. room Personnel instructed. Bridge notified. Checked all operating mach. Give #2 boiler bottom blow for 1 hr. due to high Alkalinity. at 0700 shifted F.O. suction to overhead settler.

WATCH ENGR'S SIGNATURE

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZLES. Burn tubes @ 0810. changed and cleaned Top Burners. changed and cleaned F.O. Suct. STRAINER. changed and cleaned Gen. h.o. STRAINERS. Pumped up Settlers from #4 PYS DB. Burners Sparking Excessively #1 Gen. called Chief Electric. Pumped out Bilge Holds #3 & 4 S and #4 P. Held Casualty Drill B-3 Loss of Feed Pump Press 4 men Present. Made Rounds and Checked all Running Mach. JR. Checked Steering Gear.

WATCH ENGR'S SIGNATURE

CHIEF ENGINEER

BOILER WATER READINGS

STB'D P5 PORT W5 - P5

HOURS 201 HOURS 201 - 201

AKL 7.59 AKL 11.10

T-AKL 13.43 T-AKL 16.30

SAL. 2.90 SAL. 3.73

PHOS. 38 PHOS. 53

R.ph 10.0 R.ph 10.0

CHIEF ENGR'S SIGNATURE

USNS		VOYAGE NO.		FROM		TO		TYPE OF VESSEL		DATE						
Gen John Pope Tap-110		6-A		OAKLAND CALIF		OKINAWA		P2-52-R2		12-1-2-66						
		WATCH						WATCH								
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200			1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200	
RUNNING TIME		240	240	240	240	240	240	MACHINERY PARTICULARS (CONT'D)	AFT. H. P. ROTOR BEARING	135	135	135	135	135	135	
DETENTION TIME									FORWARD L. P. ROTOR BEARING	133	130	129	131	130	131	
REVOLUTION COUNTER (END OF WATCH)		1555 7150	1557 9840	1560 2780	1562 5520	1564 7870	1567 0540		AFT. L. P. ROTOR BEARING	128	125	126	125	125	127	
TOTAL REVOLUTIONS (FOR WATCH)		22670	22690	22940	22740	22350	22670		HOTTEST GEAR BEARING FORWARD	160	160	160	158	158	159	
AVERAGE RPM		94.5	94.5	95.6	94.7	93.1	94.5		HOTTEST GEAR BEARING AFT	145	145	146	145	145	145	
F.O. METER (END OF WATCH)		1011 9560	1012 2050	1012 4590	1012 7100	1012 9570	1013 2190		AUX. COND. CONDENSATE	1 2	97	58 115	113	113	58 115	116
F.O. CONSUMED		2580	2490	2540	2510	2470	2620		1ST STAGE FEED WATER HEATER	158	158	160	158	158	160	
									D. C. FEED WATER HEATER	238	238	240	240	240	238	
									3RD STAGE FEED WATER HEATER	1050 160						
									F.O. TO BURNERS	185 185	185 190	185 185	185 185	190 180	190 185	
									F.O. BACK PRESSURE	10	10	10	10	12	11	
									PRESSURE AIR TO FURNACE	5.6 4.2	5.7 3.3	5.3 3.2	5.0 3.8	6.3 3.3	4.0 2.5	
									SALINITY	.41	.41	.53	.41	.41	.41	
									MAIN STEAM	690	695		690	700	700	
									SUPER HEAT	440	430	435	435	430	435	
									F.O. TO BURNERS	200 200	200 180	205 185	200 185	200 180	185	
									F.O. TEMP. IN SETTLING TANKS	102 104	102 104	103 107	104 104	105 104	98 110	
								PORT BOILER UPTAKE	335	335	335	335	335	335		
								STBD. BOILER UPTAKE	325	325	320	330	325	325		
								ENGINE ROOM TEMPERATURE	82	80	81	81	82	82		
								FIRE ROOM TEMPERATURE	82	80	81	81	82	82		
								NOZZLES IN USE	18	18	18	18	18	18		
								NO. OF BURNERS IN USE	6	6	6	6	6	6		
								BURNER TIP SIZE	53 70	53 70	53 70	53 70	53 70	53 70		
								CO2 % PORT BOILER					19 1/4%			
								CO2 % STBD. BOILER					20 1/4%			
								OIL LEVEL MAIN SUMP	1'2"	1'2"	1'3"	1'2"	1'4"	1'2"		

GENERATORS											FUEL - WATER AND LUBE OIL			
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL	DOMESTIC WATER
1200 TO 1600	1	1200	430	670	9	120	110		62	1150	1150	230	METER AT NOON	10132190
	2	1200	430	690	7	131	119		58	1230	1200	230	METER PREVIOUS NOON	10116980
1600 TO 2000	1		SEC										CONSUMED BY METER	15210
	2	1200	430	695	7	134	118		58	1500	1500	230	ON HAND AT START OF DAY	13076
2000 TO 2400	1		SECURED										RECEIVED DURING DAY	-0-
	2	1200	430	690	7	134	120		58	1350	1350	230	EXPENDED DURING DAY	703
2400 TO 0400	1		SEC										REMAINING ON BOARD	12373
	2	1200	430	690	7	134	120		58	1350	1350	230	ON HAND AT START OF DAY	874
0400 TO 0800	1		SEC										EVAPORATED OR RECEIVED	138
	2	1200	430	700	7	134	120		58	1500	1450	230	ON HAND	851
0800 TO 1200	1		SECURED										CONSUMED	161
	2	1200	430	700	7	134	120		58	1600	1550	230	ON HAND AT START OF DAY	1512
													EVAPORATED OR RECEIVED	1512
													ON HAND	1510
													CONSUMED	2
LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)											L.O. CENTRIFUGE - HOURS OPERATED			
											1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400
											0400 TO 0800	0800 TO 1200		
											4	4	4	4
SUMMARY											PERCENT OF SLIP			
											RUNNING TIME	1440	PERCENT OF SLIP	14.34
											DETENTION TIME	-0-	BBL FUEL/MI	1.39
											TOTAL REVOLUTIONS	134645	WIND DIRECTION	350
											AVERAGE R.P.M.	93.5	STATE OF SEA	Rough
											TOTAL MILES BY ENGINE	562	STATE OF WEATHER	690
											TOTAL MILES BY OBSERVATION	430		

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ MACH OPERATION. #1+2 BOILERS 102 F.W. BLOWERS 1+2 F.O.S. PUMPS. 1+2 M.N. F.O.S. PUMPS. M.N. AIR EJECTOR. M.N. AIR PMP. 2 M.N. COND PUMP L.O. PUMP. L.O.S. PUMP. FIRE & SAN PUMP. 1+2 AUX GENERATORS. AUX AIR EJECTORS. AUX AIR & COND PUMPS. OVER to MAIN. PORT STEERING GEAR. Tested OVERSPEED TRIP & LOW L.O. ALARM ON M.N. TURBINE & THRUST. Checked STEERING E.R. GEAR. Pumped CARGO holds Bilges. Chief Heat & Chief ENGR. Checked out 1+2 Aux GENERATORS. Secured #1 Aux GEN @ 1650. Made ROUTINE INSPECTIONS of MACH & ENGR SPACES.

WATCH ENGR'S SIGNATURE

1600-2000 WATCH

Steaming as before on 18 Nozzles. Bloused tubes from 1555 to 1615 on #1+2 Boilers. Changed and Cleaned bottom burner in #1+2 boilers. Shifted and Cleaned F.O. Strainer. Port Discharge Pumped out bilges & Cargo holds. Checked all Machinery. Carried out Standing and Night order.

WATCH ENGR'S SIGNATURE

2000-2400 WATCH

Steaming as before on 18 Nozzles. Pumped Settlers up from 2 P.S. DB. Changed and Cleaned GEN. L.O. STRAINER. CRACKED STEAM TO 4 P.S. DB. JR. Checked STEERING GEAR AND TIRE WATER SOUNDINGS. Made Rounds and Checked all RUNNING MACH.

WATCH ENGR'S SIGNATURE

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. Changed & CLEANED CENTER F.O. burners & stbd disch STRAINER. Shifted & CLEANED MAIN L.O. disch STRAINER. DAILY test of stbd L.O. pump FOR LHA. Pumped CARGO holds Bilges. Checked STEERING E.R. GEAR. Shifted F.O. to PORT and set @ 0330. Made ROUTINE INSPECTIONS of MACH & ENGR SPACES.

WATCH ENGR'S SIGNATURE

0400-0800 WATCH

Steaming as before on 18 Nozzles. Changed bottom burner in #1+2 boilers. Shifted and Cleaned main L.O. strainer. Gave #1 boiler bottom blow for (20 min) Pumped out bilges. Checked all operating mach.

WATCH ENGR'S SIGNATURE

0800-1200 WATCH

STEAMING AS BEFORE ON 18 NOZZLES. Bloused tubes 0835; Changed and cleaned TOP BURNERS; Changed and cleaned F.O. SUEZ STRAINER; Changed and cleaned #2 GEN L.O. STRAINER; Pumped up Settlers from #2 P.S. DB. Trip lamp 4-4 Reported WATER LEAK IN OVERHEAD. PHONICOR NOTIFIED; Added 2 Gals. L.O. to EACH M.N. F.O. Pump. Made Rounds and Checked all RUNNING MACH. Chief Reactor Reported all COMPRESS CHECKED in BOTH SUMMER and WINTER Positions. Pumped out Holes #2, 3, 4, 5 and 4 P.

WATCH ENGR'S SIGNATURE

CHIEF ENGINEER

BOILER WATER READINGS

105 STB'D FS

225 HOURS 225

AKL 16.35

T-AKL 12.19

SAL. 5.80

PHOS. 60

R.ph 10.5

PORT WS - FS

HOURS 225 - 225

AKL 5.84

T-AKL 11.68

SAL. 1.24

PHOS. 20

R.ph 10.0

REFRIGERATION ENGINEER COMPLETED CHECKING & SETTING

MAKE-UP AIR DAMPERS THROUGHOUT SKIP ON ALL

AIR CONDITIONING UNITS

CHIEF ENGR'S SIGNATURE

USNS		VOYAGE NO.		FROM		TO		TYPE OF VESSEL		DATE					
		WATCH						WATCH							
		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200			1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
RUNNING TIME								MACHINERY PARTICULARS (CONT'D)	AFT. H. P. ROTOR BEARING						
DETENTION TIME									FORWARD L. P. ROTOR BEARING						
REVOLUTION COUNTER (END OF WATCH)									AFT. L. P. ROTOR BEARING						
TOTAL REVOLUTIONS (FOR WATCH)									HOTTEST GEAR BEARING FORWARD						
AVERAGE RPM									HOTTEST GEAR BEARING AFT						
F.O. METER (END OF WATCH)									AUX. COND. CONDENSATE						
F.O. CONSUMED								1ST STAGE FEED WATER HEATER							
								O. C. FEED WATER HEATER							
								3RD STAGE FEED WATER HEATER							
MACHINERY PARTICULARS	PRESSURES	THROTTLE						BOILER PARTICULARS	TEMPERATURES	F.O. TO BURNERS					
		H.P. AHEAD								F. O. BACK PRESSURE					
		L.P. AHEAD								AIR TO FURNACE					
		VACUUM								UPTAKE					
		L.O. TO TURBINES								MAIN STEAM					
		AUX. STEAM								SUPER HEAT					
		BACK PRESSURE								F.O. TO BURNERS					
	TEMPERATURES	GLAND STEAM						MISCELLANEOUS	PRESSURES	F.O. TEMP. IN SETTLING TANKS					
		H.P. BLEEDER								PORT BOILER UPTAKE					
		L.P. BLEEDER								STBD. BOILER UPTAKE					
		STEAM AT THROTTLE								ENGINE ROOM TEMPERATURE					
		L.P. EXHAUST								FIRE ROOM TEMPERATURE					
		CONDENSATE								NOZZLES IN USE					
		CIRC. WATER IN								NO. OF BURNERS IN USE					
							BURNER TIP SIZE								
							CO ₂ % PORT BOILER								
							CO ₂ % STBD. BOILER								
							OIL LEVEL MAIN SUMP								

GENERATORS												FUEL - WATER AND LUBE OIL						
WATCH	GENERATOR NUMBER	R. P. M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	VOLTS	FUEL OIL	BOILER WATER	LUBE OIL	DOMESTIC WATER		
1200 TO 1600													METER AT NOON		ON HAND AT START OF DAY	108		
													METER PREVIOUS NOON	10132190	EVAPORATED OR RECEIVED			
													CONSUMED BY METER		ON HAND			
													ON HAND AT START OF DAY	12,373	CONSUMED			
													RECEIVED DURING DAY		ON HAND AT START OF DAY	3300		
													EXPENDED DURING DAY		RECEIVED			
													REMAINING ON BOARD		ON HAND			
													ON HAND AT START OF DAY	851	CONSUMED			
													EVAPORATED OR RECEIVED			1510		
													ON HAND					
													CONSUMED					
2000 TO 2400													LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)					
2400 TO 0400													L.O. CENTRIFUGE - HOURS OPERATED					
													1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
0400 TO 0800													SUMMARY					
													RUNNING TIME		PERCENT OF SLIP			
													DETENTION TIME		BBL FUEL/MI			
													TOTAL REVOLUTIONS		WIND DIRECTION			
													AVERAGE R.P.M.		STATE OF SEA			
													TOTAL MILES BY ENGINE		STATE OF WEATHER			
0800 TO 1200													TOTAL MILES BY OBSERVATION					

Nov. 57 + 58

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
29. L.O. PRES #1	9	9			9	9	9	9	9	9	9	9	9				9	9	9	9	9	9	9	
28. L.O. PRES #2	7	7			7	7	7	7	7	7	7	7	7				7	7	7	7	7	7	7	
31. L.O. TO COOLER #1	120	120			119	120	120	120	120	120	120	121	121				120	120	120	120	120	120	120	
30. L.O. TO COOLER #2	134	134			130	130	130	130	130	133	133	134	133				130	130	130	132	132	132	132	
33. L.O. FROM COOLER #1	110	110			110	110	110	110	110	110	110	111	111				110	110	110	110	110	110	110	
32. L.O. FROM COOLER #2	118	118			118	118	118	118	118	119	120	119	119				118	118	120	118	118	118	118	
35. L.O. GOV PRES #1	62	62			62	62	62	62	62	62	62	62	62				62	62	62	62	62	62	62	
34. L.O. GOV PRES #2	58	58			58	58	58	58	58	58	58	58	58				58	58	58	58	58	58	58	
37. AMPS POS #1	1100	850			750	950	1150	1000	1000	1700	1200	1000	1150				1250	1000	1250	950	950	950	950	
36. AMPS POS #2	1000	1100			1000	1250	1000	1400	1100	1150	1150	1300	1200				1250	1250	1250	1050	1050	1050	1050	
39. AMPS NEG #1	1050	850			950	950	1000	1000	1000	1150	1150	1000	1150				1150	1200	1250	950	950	950	950	
38. AMPS NEG #2	900	1000			1200	1250	1000	1050	1050	1050	1050	1150	1050				1150	1250	1250	1000	1000	1000	1000	
41. HP HIGH SPEED PIN. AFT	145	145			145	145	145	147	147	147	147	145	146				145	145	145	147	147	147	147	
42. HP INTER SPEED PIN FWD	145	145			144	145	145	143	143	143	143	145	144				145	145	145	145	145	144	144	
43. HP INTER SPEED PIN AFT	145	145			145	145	145	145	145	145	145	145	145				143	145	145	145	145	146	146	
44. L.P. THRUST BEARING	132	132			135	130	130	131	131	132	132	128	132				132	135	135	132	132	132	132	
45. H.P. THRUST BEARING	146	145			145	145	146	147	147	147	147	146	146				145	145	145	147	147	147	147	
46. LP HIGH SPEED PIN. FWD	134	134			130	130	130	132	132	132	132	132	132				130	130	130	133	133	133	133	
47. LP HIGH SPEED PIN. AFT	130	130			130	130	130	130	130	130	130	130	130				130	130	130	130	130	130	130	
48. LP INTER SPEED PIN FWD	150				150	150	150	150	150	150	150	150	150				150	150	150	150	150	150	150	
49. LP INTER SPEED PIN. AFT	130				130	130	130	130	130	130	130	130	130				130	130	130	130	130	130	130	
50. MAIN GEAR ROTOR FWD					115	115	115	114	114	114	114						115	115	115	117	117	114	114	
51. MAIN GEAR ROTOR AFT					110	110	110	108	108	109	109						105	110	110	111	110	108	108	
52. LP BLEAD	9	10			10	10	10	10	10	10	10	9	9				10	10	10	10	10	10	10	

Nov 27 + 28

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
1.	L.P. EXHAUST TEMP	103	103			102	102	102	103	103	104	104	102	102	102			105	105	105	103	103	103	103	
2.	MN COND STE TEMP	99	98			98	98	98	98	98	100	100	96	96	0			96	98	98	99	99	100	100	
3.	MN INJ TEMP	76	76			74	74	74	74	74	76	76	74	74				72	73	73	73	73	75	75	
4.	MN OVBD TEMP	87	87			88	88	88	86	86	86	86	86	86				86	86	86	86	86	86	86	
5.	L.O. TO COOLERS	126	127			128	128	128	128	128	126	126	126	128				127	128	128	128	128	128	128	
6.	L.O. FROM COOLERS	107	107			107	108	108	108	108	106	106	106	108				108	108	108	108	108	108	106	106
7.	THRUST ENG TEMP	117	117			120	120	120	118	118	118	118	116	117				120	120	120	120	120	117	117	
8.	FWD H.P. ROTOR ENG	128	128			125	125	125	128	128	128	128	126	128				125	125	125	128	128	128	128	
9.	AFT H.P. ROTOR ENG	136	136			135	135	135	135	135	135	135	135	136				130	135	135	135	135	135	135	
10.	FWD L.P. ROTOR ENG	133	132			130	130	130	132	132	135	135	131	131				130	130	130	133	133	132	132	
11.	AFT L.P. ROTOR ENG	126	128			125	125	125	128	128	128	128	125	126				125	125	125	128	128	128	128	
12.	HOT GEAR BRG FWD	160	160			160	160	160	160	160	160	160	160	160				160	160	160	160	160	160	160	
13.	HOT GEAR BRG AFT	145	145			145	145	145	147	147	147	147	145	146				145	145	145	147	147	147	147	
14.	LUX COND STE TEMP					110	110	102	102	102	106	106						106	104	104	103	103	102	102	
15.	1ST STAGE AIR TEMP					156	156	158	158	158	156	156		154				154	154	156	158	158	158	158	
16.	D.C. HEATER TEMP	240	238			240	240	240	240	240	240	240	240	238				240	235	240	240	240	240	240	
17.	SUPRHT TEMP PORT	640	640			650	650	650	645	645	640	640	650	650				650	645	650	635	635	640	640	
18.	SUPRHT TEMP STBD	680	690			690	690	690	690	690	670	670	665	680				680	680	680	680	680	690	690	
19.	F.O. SETT TEMP P	108	108			100	104	104	104	104	110	110	116	116				120	110	116	112	112	112	112	
20.	F.O. SETT TEMP S	108	104			105	105	105	108	108	120	120	112	112				120	112	112	105	105	105	108	
21.	UPTAKE PORT	340	335			335	335	335	330	330	320	320	325	335				320	330	330	325	325	325	325	
22.	UPTAKE STBD	320	320			330	325	320	320	320	310	310	320	330				320	330	330	318	318	320	320	
23.	F.O. PUMP SUCT TEMP	110	110			110	110	110	112	112	120	120	130	130				120	125	125	124	124	124	124	
24.	MN FD PMP L.O. PORT	32	32			32	32	32	32	32	32	32	32	32				32	32	32	32	32	32	32	
25.	MN FD PMP L.O. STBD	20	25			20	20	20	20	20	20	20	20	20				20	20	20	20	20	20	20	
26.	L.O. TO GEARS	18	19			110	110	110	110	110	110	110	18	18				110	110	110	110	110	110	110	
27.	AIR CONTR L.O. PRESS																								

[illegible]

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
1.	L.P. EXHAUST TEMP	102		102	102	102	102	102	103	104	105	105	101		103		105	105	105	105	105	102	102	102	102
2.	MN COND STE TEMP	97		97	94	96	98	97	100	100	102	104	94		97		94	95	96	96	98	98	98	98	98
3.	MN INJ TEMP	72		72	73	72	73	73	73	73	73	73	72		74		74	74	74	74	74	72	72	72	72
4.	MN OVBD TEMP	86		86	86	86	86	86	86	84	85	85	84		86		86	86	86	86	84	84	85	85	85
5.	L.O. TO COOLERS	126		125	126	126	125	125	126	126	126	126	124		125		125	125	125	125	126	126	126	126	126
6.	L.O. FROM COOLERS	108		107	106	106	106	106	106	106	106	106	106		107		106	106	106	106	106	106	106	106	106
7.	THRUST ENG TEMP	116		116	116	116	116	116	116	116	116	116	115		116		116	116	116	116	116	116	116	116	116
8.	FWD H.P. ROTOR ENG	125		125	125	125	125	125	128	128	128	128	125		125		125	125	125	125	125	125	127	127	127
9.	AFT H.P. ROTOR ENG	135		135	135	135	135	135	135	135	135	135	135		135		135	135	135	135	135	135	135	135	135
10.	FWD L.P. ROTOR ENG	131		131	130	130	130	130	131	131	131	131	130		130		130	130	130	130	130	130	129	129	129
11.	AFT L.P. ROTOR ENG	125		125	125	125	125	125	127	127	127	127	125		125		125	125	125	125	125	125	126	126	126
12.	HOT GEAR ENG FWD	158		158	158	158	158	158	160	159	159	159	155		160		160	160	160	160	160	160	160	160	160
13.	HOT GEAR ENG AFT	145		145	145	145	145	145	145	145	145	145	145		145		145	145	145	145	145	145	146	146	146
14.	AUX COND STE TEMP			115	115	115	115	115	115	115	115	115	115				115	115	115	115	115	115	113	113	113
15.	1ST STAGE AIR TEMP			158	158	160	160	158	156	156	160	160	1				156	156	158	158	156	156	158	160	160
16.	D.C. HEATER TEMP	236		240	240	240	240	240	235	236	238	238	240		238		240	238	238	238	240	240	240	240	240
17.	SUPRHT TEMP PORT	650		660	660	655	655	655	655	655	657	657	650		640		655	650	650	650	650	650	650	650	650
18.	SUPRHT TEMP STBD	680		700	700	700	700	700	710	700	700	700	700		670		690	690	690	700	695	695	685	685	685
19.	F.O. SETT TEMP P	104		104	104	105	105	105	105	100	98	98	102		102		102	102	102	102	100	100	103	103	103
20.	F.O. SETT TEMP S	104		104	104	104	104	104	104	102	102	102	106		104		104	104	104	104	108	108	107	107	107
21.	UPTAKE PORT	335		335	335	335	335	335	335	332	335	337	335		335		335	330	330	335	335	335	335	335	335
22.	UPTAKE STBD	320		330	325	325	325	325	325	314	315	315	325		325	3	330	320	320	325	320	320	320	320	320
23.	F.O. PUMP SUCT TEMP	110		110	108	108	108	108	110	110	108	108	110		108		110	108	108	110	110	110	112	112	112
24.	MN FD PMP L.O PORT	32		32	32	32	32	32	32	32	32	32	32		32		32	32	32	32	32	32	32	32	32
25.	MN FD PMP L.O STBD	20		20	20	25	25	20	20	20	20	20	20		20		20	20	20	20	20	20	20	20	20
26.	L.O. TO GEARS	18		18	18	18	18	18	18	18	18	18	18		18		18	18	18	18	18	18	18	18	18
27.	AIR CONTR L.O. PRESS																								

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 9-29

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																		DATE 9-29					
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREON IN COMPRESSOR	COND WATER		CHILLED WATER		BEARING		TEMPERATURE	SPEED RPM	REMARKS		
							SUCTION	DISCHARGE					IN	OUT	IN	OUT	LINE	THRUST					
1200	440	390	13	11	ON	14.5	18	12.5	15	6	25	46	120	112	84	91	50	45	140	82	-3900	1200-1600	Krupp
1300	440	390	-	11	ON	14.5	18	13.5	15	5	25	46	120	112	84	92	50	45	140	82	3900	1600-2000	
1400	440	390	-	11	ON	15	18	12.5	15	6	25	46	120	112	84	92	50	45	140	82	3900		
1500	410	36	-	11	ON	14	18	13	15	5	25	46	120	110	84	90	50	45	140	82	3850		2000-2400
1600	440	390	13	11	ON	15	18	13	15	5	25	46	121	111	84	90	50	45	140	84	3900		
1700	440	390	13	11	ON	15	18	13	15	5	25	46	121	111	84	90	50	45	140	84	3900		
1800	440	390	13	11	ON	15	18	14	15	5	25	46	121	111	84	90	50	45	140	84	3900	2400-0000	Bear
1900	440	380	13	11	ON	15	18	13	15	5	25	46	122	112	84	90	50	45	140	84	3900		
2000	440	380	-	11	ON	14.5	18	13	15	6	25	46	121	111	85	91	49	44	140	84	3900		
2100	420	370	12.5	11	ON	14	18	13	15	5	25	46	121	110	85	91	49	45	140	84	3850	0000-0400	Krupp
2200	440	360	13	11	ON	14	18	12	15	5	25	46	119	109	84	91	48	44	140	84	3850		
2300	440	360	-	11	ON	14	18	12	15	5	25	46	117	109	84	90	48	44	140	84	3850		
2400	430	350	-	11	ON	13.5	18	11.5	15	5	25	46	117	109	84	88	48	43	140	82	3800	0400-0800	Main
0100	440	360	-	11	ON	14	18	12	15	5	25	46	117	109	84	88	48	43	140	82	3850		
0200	440	330	12.5	11	ON	14	18	11.5	15	5	25	46	116	108	84	88	48	43	140	82	3800		
0300	440	350	12.5	11	ON	13.5	18	11.5	15	5	25	46	116	106	82	88	48	43	140	82	3800	0800-1200	Bear
0400	440	360	-	11	ON	14	18	12	15	5	25	46	117	109	83	88	48	44	140	84	3850		
0500	440	360	-	11	ON	14	18	12	15	5	25	46	117	109	83	88	48	44	140	84	3850		
0600	440	320	-	11	ON	14	18	12	15	5	25	46	117	109	83	88	48	44	140	84	3800	1200-1600	Krupp
0700	440	340	13	11	ON	14	18	12	15	5	25	46	118	108	83	88	48	44	140	84	3850		
0800	440	350	-	11	ON	13.5	18	11.5	15	5	25	46	117	108	84	88	48	44	140	84	3850		
0900	420	360	-	11	ON	13.5	18	12	15	5	25	46	117	109	84	88	48	44	140	84	3850	1600-2000	Main
1000	440	370	-	11	ON	14	18	12	15	5	25	46	117	109	84	88	48	44	140	84	3850		
1100	420	350	13	11	ON	13.5	18	12	15	5	25	46	118	108	84	88	47	44	140	84	3850		

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 10-5

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																				DATE 10-5					
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		L.O. TEMP.	FREC IN COMPRESSOR	COND WATER		CHILLED WATER		BEARING		SPEED RPM	REMARKS							
							SUCTION	DISCHARGE			IN	OUT	IN	OUT	LINE	THRUST									
1200	450	230	12	11	ON	13	18	8			14	5	25	46	118	100	84	88	48	44	140	86	-3550	1200-1600	Krupp
1300	460	240	12	11	ON	13	18	8			14	5	25	46	118	100	84	88	48	44	140	86	3550	1600-2000	
1400	460	230	12	11	ON	13	18	8			14	5	25	46	118	100	84	88	48	45	141	86	3550		
1500	460	220	12	11	ON	12.5	18	7.5			14	5	25	46	117	98	84	88	48	45	141	86	3550		Blanc
1600	460	220	12	11	ON	13	17	8			14	5	25	47	119	99	84	88	47	45	140	86	3450	2000-2400	
1700	460	220	12	11	ON	13	17	8			14	5	25	47	119	99	84	88	47	45	140	86	3450		
1800	460	220	12	11	ON	13	17	8			14	5	25	47	118	99	84	88	47	45	140	85	3450		Blanc
1900	460	220	12	11	ON	13	17	8			14	5	25	47	118	99	84	88	47	45	140	85	3450		
2000	440	220	12	11	ON	12.5	17	7.5			14	5	25	47	118	98	83	87	47	45	140	85	3425	0000-0400	
2100	440	220	12	11	ON	12.5	17	7			14	5	25	47	118	98	83	87	47	45	140	85	3425		Krupp
2200	460	210	12	11	ON	12.5	17	7			14	5	25	47	118	99	83	87	47	45	140	87	3400		
2300	450	210	11	11	ON	12.5	17	7			14	5	25	47	117	97	83	87	47	45	140	84	3400		
2400	450	220	12	11	ON	13	17	7			14	5	25	46	115	96	82	88	47	44	140	84	3400		Blanc
0100	450	220	11	11	ON	13	17	7			14	5	25	46	115	96	82	88	47	44	140	84	3400		
0200	460	210	12.5	11	ON	13	17	7			14	5	25	46	115	98	82	88	47	44	140	84	3400		
0300	460	210	11.5	11	ON	13	17	7			14	5	25	46	115	96	84	86	47	45	140	84	3400		Blanc
0400	460	210	11	11	ON	13	17	7			14	5	25	46	117	97	84	88	47	45	140	84	3400		
0500	460	210	11	11	ON	13	17	7			14	5	25	46	117	97	84	88	47	45	140	84	3400		
0600	460	200	11	11	ON	13	17	6			14	5	25	47	116	95	84	88	46	45	140	84	3400		Blanc
0700	460	200	11	11	ON	13	17	6			14	5	25	47	116	95	84	88	46	45	140	84	3400		
0800	460	210	11.5	11	ON	13	17	5.5			14	5	25	47	116	96	83	86	47	45	140	84	3400		
0900	460	200	11	11	ON	13	17	6.5			14	5	25	47	117	96	83	86	47	45	140	84	3375		Blanc
1000	460	220	11.5	11	ON	13	17	7.5			14	5	25	47	118	98	85	88	47	45	140	84	3325		
1100	460	220	11.5	11	ON	13	17	7.5			14	5	25	47	119	98	85	88	47	45	140	85	3375		

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 10-6

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																				DATE 10-6	
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREC IN COMPRESSOR	COND WATER		CHILLED WATER		BEARING		SPEED RPM	REMARKS	
							SUCTION	DISCHARGE					IN	OUT	IN	OUT	LINE	THRUST			
1200	460	230	12	11	ON	12	17	8	14	5	25	46	117	100	84	88	48	44	140	84	1200-1600
1300	460	230	12	11	ON	13	17	7	14	5	25	46	116	98	84	88	48	44	140	84	1600-2000
1400	460	230	12	11	ON	13	17	7	14	5	25	46	116	98	84	88	48	44	140	84	
1500	430	220	12	11	ON	13	17	7	14	5	25	46	116	98	84	86	48	44	140	84	
1600	460	220	12	11	ON	13	17	7	14	5	25	46	118	98	83	88	47	45	138	84	2000-2400
1700	460	200	11	11	ON	13	17	7	14	5	25	46	118	97	83	88	47	45	138	84	
1800	460	200	11	11	ON	13	17	7	14	5	25	46	118	96	83	88	47	45	138	84	
1900	460	200	11	11	ON	13	17	7	14	5	25	46	118	96	83	88	47	45	138	84	
2000	460	210	11	11	ON	13	17	7	14	5	25	47	117	96	83	86	47	45	138	84	
2100	460	200	10	11	ON	12.5	17	6	14	5	25	47	117	96	83	86	46	44	138	84	
2200	460	210	11	11	ON	12.5	17	6.5	14	5	25	47	117	96	83	86	46	44	138	84	
2300	460	200	10.5	11	ON	12.5	17	6	14	5	25	48	117	95	83	86	46	44	138	84	
2400	460	200	11	11	ON	12.5	17	6	14	5	25	46	115	99	82	86	46	43	140	84	
0100	460	210	10	11	ON	13	17	7	14	5	25	46	115	96	82	86	47	44	140	84	
0200	460	200	11	11	ON	13	17	7	14	5	25	47	115	96	82	86	47	44	140	84	
0300	460	200	12	11	ON	12.5	17	6.5	14	5	25	47	115	94	82	86	46	43	140	84	
0400	460	200	11	11	ON	13	17	6	14	5	25	47	117	95	82	86	46	44	140	84	
0500	460	200	11	11	ON	13	17	6	14	5	25	47	117	95	82	86	46	44	140	84	
0600	460	200	11	11	ON	13	17	6	14	5	25	47	117	95	82	86	46	44	140	84	
0700	460	180	9	11	ON	13	17	6	14	5	25	47	117	95	82	86	46	44	140	84	
0800	460	200	10	11	ON	13	17	5.5	14	5	25	47	117	96	84	87	46	44	140	84	
0900	450	200	10.5	11	ON	13	17	6	14	5	25	47	118	96	84	87	47	45	140	84	
1000	450	200	10	11	ON	12.5	17	6.5	14	5	25	47	117	96	84	87	47	45	140	84	
1100	450	210	10.5	11	ON	13	17	6.5	14	5	25	47	117	96	84	87	47	45	140	84	

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 10-7

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																				DATE 10-7			
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREC IN COMPRESSOR	COND WATER	CHILLED WATER	BEARING		TEMPERATURE	SPEED RPM	REMARKS				
							SUCTION	DISCHARGE							LINE	THRUST							
																				IN	OUT	IN	OUT
1200	450	200	12	11	ON	12.5	17	6.5	14	5	25	47	115	96	82	86	47	44	139	84	-3375	1200-1600	Kump
1300	450	220	11	11	ON	13	17	7	14	5	25	47	115	96	82	86	47	44	139	84	3400	1600-2000	
1400	450	210	10	11	ON	13	17	7	14	5	25	47	115	96	82	86	47	44	139	84	3400		
1500	460	220	11	11	ON	13	17	7	14	5	25	47	115	96	82	85	47	44	139	84	3400		Marin
1600	450	200	11	11	ON	13	17	7	14	5	25	47	115	96	82	87	47	44	140	84	3400	2000-2400	Bean
1700	450	210	11	11	ON	13	17	7	14	5	25	47	115	96	83	87	47	44	140	84	3400		
1800	450	200	11	11	ON	12	17	6	14	5	25	47	116	95	82	86	46	44	138	84	3300		
1900	450	200	12	11	ON	12	17	6	14	5	25	47	117	95	82	86	46	44	138	84	3300		Kump
2000	460	200	11	11	ON	12.5	17	6	14	5	25	47	116	95	83	86	46	44	138	84	3325	0000-0400	
2100	460	200	11	11	ON	13	17	6	14	5	25	47	116	95	83	86	46	44	138	84	3325		
2200	460	190	10.5	11	ON	12.5	17	5.5	14	5	25	47	116	94	83	86	46	44	140	84	3300		Marin
2300	460	190	10	11	ON	13	17	6	14	5	25	47	116	94	83	85	46	44	140	84	3300		
2400	460	200	11	11	ON	12.5	17	6	14	5	25	47	115	94	83	84	46	43	140	84	3300		
0100	450	180	10	11	ON	11.5	17	5.5	14	5	25	47	115	94	82	84	46	43	140	84	3300	0400-0800	Bean
0200	450	180	10	11	ON	11	17	6	14	5	25	47	115	94	82	84	46	43	140	84	3300		
0300	460	190	10	11	ON	12.5	17	5.5	14	5	25	47	114	94	81	83	46	44	140	84	3300		
0400	460	190	11	11	ON	13	17	6	14	5	25	47	115	94	82	86	46	44	140	84	3300		Marin
0500	460	190	11	11	ON	13	17	6	14	5	25	47	115	94	82	86	46	44	140	84	3300	0800-1200	
0600	460	200	11	11	ON	13	17	6	14	5	25	48	116	95	82	86	46	44	140	84	3300		
0700	460	200	11	11	ON	13	17	6	14	5	25	48	116	95	82	86	46	44	140	84	3325		Bean
0800	450	190	11.5	11	ON	12.5	17	6	14	5	25	48	116	95	83	86	46	44	140	84	3325		
0900	450	190	11	11	ON	13	17	6	14	5	25	48	116	95	83	86	47	45	140	84	3375		
1000	450	210	11.5	11	ON	13	17	7	14	5	25	47	116	97	83	86	47	45	140	84	3400		
1100	450	220	12	11	ON	13	17	7	14	5	25	47	117	97	83	86	47	45	138	84	3400		

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 10-9

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																			DATE 10-9				
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREF IN COMPRESSOR	COND WATER	CHILLED WATER	BEARING		TEMPERATURE	SPEED RPM	REMARKS				
							SUCTION	DISCHARGE							LINE	THRUST							
																				IN	OUT	IN	OUT
1200	450	220	13	11	ON	13	17	7	14	5	25	47	115	96	82	84	48	44	139	84	-3400	1200-1600	Krupp
1300	450	220	11.5	11	ON	13	17	7	14	5	25	47	115	98	82	84	48	44	139	84	3400	1600-2000	
1400	450	240	12	11	ON	13	17	8	14	5	25	47	117	98	82	84	48	44	139	84	3425		
1500	430	210	10	11	ON	13	17	7.5	14	5	25	46	116	98	82	86	48	44	139	86	3425		Murphy
1600	450	230	11	11	ON	13	17	8	14	5	26	46	118	98	82	86	47	45	137	85	3400	2000-2400	
1700	460	230	11	11	ON	13	17	8	14	5	25	46	118	99	82	86	47	45	137	85	3400		
1800	430	230	11	11	ON	13	17	8	14	5	25	46	118	99	82	86	47	45	137	85	3400		Blam
1900	460	230	11	11	ON	13	17	8	14	5	25	46	118	99	82	86	47	45	137	85	3400		
2000	460	220	11	11	ON	13	17	7.5	14	5	26	47	118	99	83	87	47	45	138	85	3425	0000-0400	
2100	460	220	11	11	ON	13	17	7.5	14	5	26	47	118	99	83	87	47	45	138	84	3400		
2200	460	220	11	11	ON	13	17	7	14	5	26	47	117	98	83	87	47	45	138	84	3400		
2300	460	210	10	11	ON	13	17	7	14	5	26	47	117	98	82	86	47	45	138	84	3425		Krupp
2400	460	220	11	11	ON	13	17	7	14	5	25	47	115	98	82	84	48	44	138	84	3400		
0100	460	220	11	11	ON	13	17	7	14	5	25	46	115	96	82	84	47	44	138	84	3400	0400-0800	
0200	450	220	12	11	ON	13	17	7	14	5	25	46	115	96	82	84	47	44	138	84	3400		
0300	460	210	11	11	ON	13	17	6.5	14	5	25	47	115	96	82	84	47	44	138	84	3350		Murphy
0400	460	210	12	11	ON	13	17	7	14	5	25	47	116	97	82	86	47	44	138	84	3350		
0500	460	210	12	11	ON	13	17	7	14	5	25	47	116	97	82	86	47	44	138	84	3350	0800-1200	
0600	460	210	12	11	ON	13	17	7	14	5	25	47	117	96	82	86	47	45	138	84	3350		
0700	460	210	12	11	ON	13	17	7	14	5	25	47	117	96	82	86	47	45	138	84	3350		
0800	460	200	11.5	11	ON	13	17	6	14	5	25	47	116	95	82	85	47	45	138	83	3325		Blam
0900	460	210	12	11	ON	12.5	17	6.5	14	5	25	47	117	95	82	85	47	45	138	83	3375		
1000	460	210	12	11	ON	13	17	7	14	5	25	47	117	96	82	85	47	45	136	83	3400		
1100	460	220	12	11	ON	13	17	7	14	5	25	47	117	97	82	85	47	45	136	84	3400		

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	62	0	110	95	0	115	96							11	110	98
14:00	62	—	—	—	0	115	95							—	—	—
16:00	64	—	—	—	—	—	—							15	110	108
18:00	64	—	—	—	0	115	97							5	110	102
20:00	64	0	110	94	—	—	—							5	115	99
22:00	62	0	120	96	0	115	95							20	115	100
24:00	62	0	110	93	0	115	94							12	110	96
26:00	62	0	115	94	0	115	94							12	110	97
28:00	62	0	115	94	0	115	95							12	110	98
30:00	62	0	115	94	0	115	96							16	115	98
32:00	62	0	105	90	0	115	95							13	115	99
34:00	62	0	115	94	0	115	96							20	115	98

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11-9-66

COLD STORAGE BOX TEMPERATURES												REMARKS
	ICE CLEAN	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
TIME	1	2	3	4	5	6	7	8	9	10	11	
1200	0	37	0	-2	7	2	35	-1	35	33	42	1200-1600
1400	-1	37	2	-2	7	-1	35	0	35	33	41	Beans
1600	0	37	4	-1	7	-3	35	-2	36	33	42	1600-2000
1800	0	38	5	0	7	-3	35	-2	36	33	42	Marin
2000	0	38	4	0	7	-3	35	-3	36	33	42	2000-2400
2200	0	37	3	0	7	-3	35	-3	36	33	42	
2400	1	36	4	-2	8	-1	34	0	35	33	42	Marin
0200	0	36	2	-2	8	-1	34	0	35	33	42	
0400	0	37	2	-1	8	-2	35	0	35	33	42	
0600	1	37	2	-2	8	0	35	0	35	33	42	Knap
0800	0	37	2	0	10	2	35	2	35	33	42	0800-1200
1000	0	37	3	2	10	1	35	0	35	33	42	Knap
												Beans


 CHIEF ENGINEER

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11/14/66

COLD STORAGE BOX TEMPERATURES												REMARKS
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
TIME	1	2	3	4	5	6	7	8	9	10	11	
1200	0	38	2	-3	-	-	35	2	36	33	42	1200-1600
1400	0	38	2	-3	-	-	36	0	36	33	44	Beams
1600	0	38	2	-2	-	-	36	-1	36	33	47	1600-2000
1800	1	38	2	-2	-	-	36	-1	36	33	43	Marvin
2000	1	37	0	-2	-	-	37	0	35	33	41	2000-2400
2200	2	38	1	6	-	-	37	2	35	33	41	Marvin
2400	2	38	4	8	44	34	38	0	36	33	40	Marvin
0200	2	37	3	8	31	23	37	0	36	33	40	0200-0400
0400	1	37	4	6	25	12	37	-1	36	33	40	0400-0600
0600	2	38	4	6	22	9	38	0	36	33	41	Gintel
0800	1	37	4	0	20	7	40	-2	35	33	40	0800-1200
1000	0	37	2	-1	-	-	40	-1	35	33	40	0830 Loading STORES Boxes #546
												Beams

SECURED LOADING STORES @ 2400



 CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	60	0	105	93	0	115	96							15	115	100
14:00	61	0	115	95	0	110	95							10	105	98
16:00	61	0	105	94	-	-	-							25	115	98
18:00	61	0	110	93	0	110	96							16	115	98
20:00	61	0	110	93	-	-	-							5	110	98
22:00	61	0	100	80	-	-	-							10	110	97
24:00	60	0	110	95	-	-	-							15	115	97
02:00	60	0	115	93	0	115	95							20	115	98
04:00	60	3	115	92	0	110	95							5	110	97
06:00	60	0	110	90	-	-	-							5	110	98
08:00	60	0	110	90	0	115	95							20	115	98
10:00	60	0	110	93	-	-	-							5	110	98

MAIN REEFER LOG:

USNS GEN JOHN POPE (T-AP110)

DATE 11-15-66

COLD STORAGE BOX TEMPERATURES												REMARKS
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
TIME	1	2	3	4	5	6	7	8	9	10	11	
1200	1	38	2	-1	-	-	40	-2	35	33	41	
1400	2	36	2	-2	-	-	40	0	35	33	41	Beans
1600	1	36	5	-2	-	-	40	2	35	33	41	
1800	1	37	4	-2	-	-	40	1	35	33	42	Marrin
2000	0	37	5	-1	28	16	41	1	36	33	43	
2200	1	38	5	-1	21	10	41	0	36	33	41	
2400	0	36	4	0	19	8	41	-2	36	33	-	
2600	0	37	4	-1	16	6	41	-1	36	33	-	Marrin
2800	0	37	4	-2	14	5	41	-2	36	33	-	
3000	0	37	4	-2	12	3	36	-1	36	33	42	Sintel
3200	0	38	3	-2	10	3	35	-1	36	33	42	
3400	0	36	3	-2	11	1	31	-2	35	-	42	Sintel
LOADING Box #11 @ 2330 Box open Secured loading @ 0400												
 CHIEF ENGINEER												
1800-1200 1000 Loading stores Box #10 												

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	61	-	-	-	-	-	-							17	115	98
14:00	60	0	105	90	0	115	92							10	110	98
16:00	60	0	115	94	0	115	95							10	110	98
18:00	60	-	-	-	0	110	93							-	-	-
20:00	60	0	110	92	0	115	95							10	110	98
22:00	60	0	110	94	-	-	-							15	115	98
24:00	60	0	110	92	0	115	95							15	115	98
26:00	60	0	110	91	0	115	93							15	110	99
28:00	60	0	110	91	-	-	-							20	115	100
30:00	60	0	110	90	-	-	-							20	115	98
32:00	60	0	110	92	0	115	94							15	115	98
34:00	60	0	105	90	-	-	-							23	110	96

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	60	-	-	-	0	115	96							5	110	97
14:00	60	0	105	90	0	115	95							13	110	98
16:00	60	0	110	92	0	115	96							15	115	100
18:00	60	0	110	91	0	115	95							15	115	98
20:00	60	0	100	91	0	120	97							20	115	98
22:00	60	0	110	91	0	115	94							0	100	99
24:00	60	0	105	90	0	115	94							2	110	97
26:00	60	0	105	90	0	115	96							20	115	97
28:00	60	0	105	90	-	-	-							20	115	98
30:00	60	0	105	91	0	115	96							22	115	98
32:00	60	0	105	87	0	115	96							17	115	97
34:00	60	0	105	90	0	115	94							5	110	98

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11-14-66

COLD STORAGE BOX TEMPERATURES												REMARKS
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
TIME	1	2	3	4	5	6	7	8	9	10	11	
1200	0	36	3	0	10	0	30	2	35	-	41	1200-1600 Beann
1400	0	36	2	0	10	-1	30	9	35	-	41	
1600	1	36	2	-	-	0	31	-1	35	41	41	1600-2000 Marvin
1800	10	37	2	9	26	0	32	0	36	40	41	
2000	-	38	2	0	22	1	34	-2	36	39	41	2000-2400 Marvin
2200	10	37	3	0	-	6	34	0	-	39	-	
2400	10	37	3	0	20	3	35	-1	36	39	-	0000-0400 Gintef
0200	8	37	3	-1	17	3	35	-1	-	-	-	
0400	6	38	2	-2	14	2	36	-1	-	-	-	0400-0800 Gintef
0600	7	38	2	-2	12	2	36	2	39	39	41	
0800	6	37	3	-1	21	0	35	4	-	33	42	0800-1200 0800 Loading Stores Box # 9 Beann
1000	5	37	1	0	20	-1	35	0	-	33	41	

Loading Box # 10 + 11 @ 2330
Secured Loading @ 0400


CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	60	0	110	92	0	115	94							15	110	98
14:00	61	0	105	90	—	—	—							3	110	98
16:00	60	0	105	91	0	115	96							25	115	97
18:00	60	0	105	90	—	—	—							25	115	96
20:00	60	0	110	93	0	110	94							20	115	97
22:00	60	0	110	90	0	115	96							25	115	97
24:00	60	0	110	92	0	115	98							25	115	100
02:00	60	0	105	90	—	—	—							20	115	99
04:00	60	0	110	90	0	110	98							20	115	99
06:00	60	0	105	89	—	—	—							20	115	96
08:00	60	0	105	90	0	115	96							7	110	100
10:00	60	0	110	94	0	115	94							16	115	97

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11-17-66

COLD STORAGE BOX TEMPERATURES												REMARKS
	ICE CLEAN	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
TIME	1	2	3	4	5	6	7	8	9	10	11	
1200	5	37	3	2	11	0	35	0	-	33	41	Beans
1400	5	37	1	-1	10	-1	35	0	-	33	41	
1600	5	38	2	-2	9	-1	35	0	-	35	-	Marin
1800	4	38	2	-2	10	-1	36	0	44	39	42	
2000	4	38	1	-1	9	-2	36	-1	43	40	41	Marin
2200	4	38	1	0	9	-2	36	-2	42	40	41	
2400	3	37	2	0	-8	-2	37	2	42	38	40	Gintef
0200	3	36	2	-2	8	-2	36	2	41	36	40	
0400	3	36	2	-1	8	-2	36	0	40	36	40	Beans
0600	3	37	2	0	7	-3	36	0	40	36	45	
0800	2	37	1	-1	7	-3	35	1	-	33	45	Beans
1000	2	37	1	-1	12	-1	35	1	-	33	45	
 CHIEF ENGINEER												1200-1600 1600-2000 1830 Defrosting #10 box. 2000-2400 2030 Sec. defrosting, #10 back on line. 0200-0400 0400-0800 0800 Loading stores #9 Box Beans

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	60	0	110	95	—	—	—							26	115	96
14:00	60	0	110	95	0	115	96							25	115	95
16:00	60	0	110	93	0	115	94							25	115	96
18:00	60	0	100	91	0	115	97							25	115	96
20:00	60	0	105	95	0	115	92							25	115	96
22:00	60	0	110	94	0	115	94							25	115	98
24:00	60	0	110	94	—	—	—							26	115	95
26:00	59	0	110	94	0	110	94							25	115	96
28:00	59	0	110	92	—	—	—							24	115	95
30:00	59	0	105	90	0	115	93							22	115	95
32:00	59	0	105	90	0	110	95							23	115	96
34:00	59	0	105	90	0	110	94							20	115	96

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11-18-66

COLD STORAGE BOX TEMPERATURES												REMARKS	
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT		
TIME	1	2	3	4	5	6	7	8	9	10	11		
1200	2	38	1	-2	10	35 35	35	-2	-	33	45	1200-1600 1230 # 9 Walkin back on line	
1400	1	37	1	-2	8	-2	36	-2	44	33	42	Beans	
1600	1	38	1	-2	7	-3	36	-1	43	38	42	1600-2000	
1800	1	37	0	-1	7	-4	35	-2	43	38	42	Maurin	
2000	1	38	0	0	6	-1	35	-2	42	37	41	2000-2400	
2200	1	38	1	-1	6	-2	35	-2	42	36	41		
2400	1	37	0	-1	6	2	35	-2	40	36	41	Maurin	
1800	1	37	1	-2	6	0	35	0	40	36	41	0000-0400	
0400	1	37	1	-2	6	-1	35	2	40	36	41		
0600	1	37	0	-2	6	-2	35	0	40	36	41	Beans	
0800	0	37	0	0	6	-2	35	-3	39	37	41	0400-0800	
1000	0	37	0	0	7	2	35	-1	39	36	41	Beans	
												0800-1200	
												Ginty	


 CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12.00	59	0	110	92	—	—	—							20	115	96
14.00	59	0	110	93	0	110	94							20	115	96
16.00	60	0	105	91	0	115	92							18	115	96
18.00	60	—	—	—	0	115	94							24	115	97
20.00	60	0	105	85	0	115	93							21	115	96
22.00	—	—	—	—	—	—	—							—	—	—
24.00	59	0	110	91	0	115	96							15	115	94
26.00	59	0	110	93	0	115	94							15	115	95
28.00	59	0	110	94	0	115	94							12	115	96
30.00	60	0	105	90	—	—	—							10	115	97
32.00	59	0	105	90	0	115	95							5	115	98
34.00	59	—	—	—	0	115	95							5	110	97

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 11/20/66

COLD STORAGE BOX TEMPERATURES												REMARKS
TIME	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
	1	2	3	4	5	6	7	8	9	10	11	
1200	1	37	0	0	7	-2	35	-1	36	33	41	1200-1600
1400	0	37	3	-1	11	-2	35	0	36	33	41	1600-2000
1600	0	38	1	-1	9	-2	35	1	36	33	41	
1800	0	38	1	-1	8	-2	35	0	36	33	41	
2000	0	38	1	-1	8	-3	35	0	36	33	41	
2200	0	38	2	0	8	0	35	0	36	33	41	
2400	0	37	1	-1	8	2	35	-1	36	33	41	
0200	0	37	1	-1	7	3	35	-1	36	33	41	
0400	0	37	1	-2	7	0	35	0	36	33	41	
0600	0	37	1	-2	7	-1	35	0	36	33	41	
0800	0	37	0	-1	7	-3	35	2	36	33	41	
1000	0	37	1	0	19	1	35	0	36	33	41	
												1200-1600
												1600-2000
												2000-2400
												2400-0400
												0400-0800
												0800-1200

Sinter

Mami

Mami

Beans

Beans

Sinter


 CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	59	0	115	90	0	110	94							—	—	—
14:00	59	0	105	89	—	—	—							5	110	96
16:00	60	0	110	91	—	—	—							—	—	—
18:00	60	0	110	92	0	115	95							0	110	96
20:00	60	0	100	90	0	115	94							0	105	96
22:00	60	—	—	—	0	120	95							0	115	96
24:00	59	0	110	92	—	—	—							11	115	94
26:00	59	0	115	95	0	115	96							13	115	96
28:00	59	0	110	94	0	—	—							5	115	94
30:00	59	0	105	93	0	115	94							5	115	98
32:00	59	0	105	90	0	115	94							0	110	96
34:00	60	0	105	92	—	—	—							0	115	98

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ~~ON~~ BACK

MINUTES AT 2

DATE _____

1. *Journal of the American Medical Association*, 1997; 277: 1033-1036.

	11/0V. 27-66																								11/0V. 26-66																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
	HOUR ENDING																								HOUR ENDING																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400		0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
STEAM TO REG. VALVE, PRESSURE #G	6	6	7	7	8	7	8	8	8	8	8	6	6	7	7	7	7	7	7	7	7	8	7			6	6	7	7	8	8	8	8	6	6	7	7	7	7	7	7	7	7	8	7																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	1	1	4	2	2	2	2	2	2	2	1	1	1	1	2	2	2	2	2	2			2	2	2	1	1	4	2	2	2	2	2	2	2	2	2	2	2	2	2	2																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	2	2	2	2	2	3	2	1	1	1	1	0	0	1	1	1	1	2	2	2	2	2	2			2	2	2	2	3	2	1	1	1	1	1	1	1	1	2	2	2	2	2	2																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	230	235	240	230	235	235	230	230	240	240	255	250	250	245	235	235	240	240	240	240	240	240			240	230	235	240	230	235	235	230	230	240	240	240	240	240	240	240	240	240	240	240	240																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	210	200	210	200	200	205	200	195	195	195	195	190	190	200	200	200	200	200	200	200	200	200	200			210	200	210	200	200	205	200	195	195	195	190	190	200	200	200	200	200	200	200	200	200	200																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
1ST EFFECT SHELL PRESSURE, *HG	6"	6"	6"	8"	8"	8"	8"	8	8	8	8	11"	11"	11"	11"	9"	9"	10"	10"	10	10	10	10			6"	6"	6"	8"	8"	8"	8"	8	8	8	8	11"	11"	11"	11"	9"	9"	10"	10"	10	10	10	10																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
2D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
2D EFFECT SHELL PRESSURE, *HG	17"	17"	17"	18"	18	18	18"	18	18	15	15	19"	19"	19"	19"	18"	18"	18"	18"	19	19	19	19			17"	17"	17"	18"	18	18	18"	18	18	15	15	19"	19"	19"	19"	18"	18"	18"	18"	19	19	19	19																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	158	158	156	152	151	151	151	151	148	148	148	148	152	152	150	150	150	150	150	150			160	160	160	158	158	156	152	151	151	151	151	148	148	148	148	152	152	150	150	150	150	150	150																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
2D EFFECT SHELL PRESSURE, *HG	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
CONDENSATE TO COOLER, TEMPERATURE, °F	140	135	135	140	140	138	138	132	132	132	132	134	134	134	135	138	138	136	138	138	138	138	138			140	135	135	140	140	138	138	132	132	132	132	134	134	134	135	138	138	136	138	138	138	138	138																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
CONDENSATE FROM COOLER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	136	138	130	130	130	130	130	130	130	130	110	110	130	130	125	128	130	130	130	130			130	130	130	136	138	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
STEAM TO AIR EJECTOR, PRESSURE, #G	90	90	90	90	90	90	90	92	92	92	92	90	90	90	90	90	90	90	90	90	90	90	90			90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
AIR EJECTOR DRAINS, TEMPERATURE, °F	70	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	03562600	1200	
0200	03563700	1100	
0300	03565000	1300	
0400	03566600	1600	1 Hr-20 min.
0500	03567700	1100	
0600	03569400	1700	1 Hr-20 min.
0700	03570400	1000	
0800	03571500	1100	
0900	03572700	1200	
1000	03573800	1100	
1100	03574900	1100	
1200	03548100		
1300	03549000	900	
1400	03550100	1100	
1500	03551100	1000	
1600	03552200	1100	
1700	03554400	2200	?
1800	03555500	1700	1100
1900	03556400		1100
2000	03557800	1200	1200
2100	03558900	1100	1400
2200	03559900		
2300	03560400	1500 (4 Hr-20 min)	
2400	03561400	1000	
		23,000	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	16		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	4100		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

Nov-27-66
 1 & 2 evap. dist to 3 port & stbd.
 SIGNED *[Signature]*

0400-0800
 #2 Evap dist to #3 port & stbd.
 @ 0500 Filled #2 MacEvap Tank.
 SIGNED *R. Shppard*

0800-1200
 #1 & 2 Evap. Dist.
 to #3 Port & Stbd...
 WATER DIST. LAST (25 Hrs):
 25,600 GALS
 SIGNED *[Signature]*

Nov-26-66
 1 & 2 evap. dist to #3 port & stbd.
 SIGNED *[Signature]*

1200-1600
 #2 Evap. Dist. to #3 port & stbd.
 @ 1700 #2 Evap dist to #2 stbd. feed.
 SIGNED *R. Shppard*

2000-2400
 #1 & 2 - Evap. Dist. to
 #3 Port & Stbd...
 #2 Brine Pump Kick off
 @ 2235 -
 SIGNED *[Signature]*

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS AHEAD OR BACK

201414.

MINUTES AT

DATE _____

Nov. 26 1966

1964

	1/Nov. 27-66												1/Nov. 28-66											
	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	9	9	9	9	8	8	8	8	9	9	8	8	8	8	9	9	9	9	9	8	
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	3	3	3	2	2	2	2	2	2	2	2	1	1	1	2	2	2	2	2	2	
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	2	2	2	2	2	2	2	2	2	2	2	1	1	1	1	2	2	3	2	2	2	2	2	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	236	240	230	235	230	236	230	230	228	228	230	230	230	230	232	230	228	230	230	230	
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195	195	195	195	195	195	195	195	200	195	195	200	200	195	195	195	195	
1ST EFFECT SHELL PRESSURE, *HG	9"	9"	9"	8"	8"	8"	8"	8"	8"	8"	8"	9"	9"	9"	11"	9"	8"	9"	8"	8"	8"	8"	8"	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	168	168	168	170	170	170	170	165	165	165	165	165	165	165	168	168	168	170	170	168	168	168	168	
2D EFFECT SHELL PRESSURE, *HG	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	156	156	156	160	160	154	156	156	156	156	156	158	158	160	160	160	160	160	160	160	160	158	158	
3D EFFECT SHELL PRESSURE, *HG	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	23"	
CONDENSATE TO COOLER, TEMPERATURE, °F	132	132	132	134	134	130	130	131	131	131	131	134	134	134	134	136	136	136	136	136	136	136	136	
CONDENSATE FROM COOLER, TEMPERATURE, °F	90	90	90	92	92	90	90	90	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	132	132	130	130	130	130	130	130	130	130	130	130	136	136	128	128	130	130	130	130	
STEAM TO AIR EJECTOR, PRESSURE, #G	40	40	40	40	40	42	42	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	72	72	72	73	73	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	72	72	72	73	73	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	144	144	144	150	150	148	150	144	144	144	144	150	150	150	142	143	143	146	146	146	150	154	154	
CIRC. WATER OVERBOARD, TEMPERATURE, °F	92	90	90	94	94	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	2	2	2	2	2	2	2	2	2	
CIRC. PUMP DISCHARGE PRESSURE, #G	25	25	25	17	17	17	17	17	17	17	17	16	16	25	17	15	16	15	17	17	17	17	17	
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	20	20	25	25	25	25	25	25	
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	30	30	25	25	25	25	25	25	25	25	25	25	30	40	35	36	26	26	26	26	
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	60	68	55	40	40	59	57	58	58	58	58	59	59	58	50	58	55	58	58	55	55	58	58	
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	15	15	20	15	10	10	10	10	10	10	10	10	
FEED DENSITY, 32NDS												1.7	1.7	1.7	1.7									
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5					1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	
CHEMICAL SALINITY TEST	221	220	221	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	
AIR EJECTOR DRAINS, SALINITY - E. P. M.	01	01	01	01	01	01	01	01	01	01	01	02	02	02	02	02	02	02	02	02	02	02	02	
1ST EFFECT DRAINS, SALINITY - E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
CONDENSATE FROM COOLER, SALINITY - E. P. M.	05	05	04									06	06	05	05									

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
1100 0000		5	
0100 0100	083538000	1300	
0200 0200	08359300	1300	
0300 0300	08360600	1300	
0400 0400	08362400	1200	1 Hr 20 min
0500 0500	08363400		1200
0600 0600	08365300		1700
0700 0700	08366500		1200
0800 0800	08367500		1000
0900 0900	08368700	1200	
1000 1000	08369400	1200	
1100 1100	08371100	1200	
1200 1200	08339800		
1300 1300	08341100	1300	
1400 1400	08342300	1200	
1500 1500	08343600	1300	
1600 1600	08344900	1300	
1700 1700	08347500	2600	2
1800 1800	08348800	1300	1300
1900 1900	08350100		1300
2000 2000	08351300	1200	1200
2100 2100	08352600	1300	1200
2200 2200	08353900	1300	1200
2300 2300	08355500	1600	1200
2400 2400	083567	1200	1200

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	48		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	57,200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 5676 (REV. 11-50) BACK

REMARKS

0000-0400

1200-1600

0400-0800

1600-2000

0800-1200

2000-2400

#-1
1 & 3 evap. dist. to 3 port & stbd.Nov. 27-66
1 & 2 evap. dist. to 3 port & stbd.

1 Hr 20 min

SIGNED

SIGNED

C0400 shifted #1 Evap. dist. to #1 stbd.
C0500 Filled #1 H2O evap. tank.#1 Evap. dist. to #3 port & stbd.
@ 1700 #1 Evap. dist. to #1 stbd. Feed
72 King chemical an #1 stbd. Every 15 min.
1730 still 2.#1 port 2. Test 2 Drops
#1 stbd 9. Test 3 Drops
#2 port Mt
#2 stbd 9. Test 2 Drops#1 port - 8. - 2 Drops
#1 stbd - 3. - 2 Drops
#2 port Mt
#2 stbd - 9. - 2 Drops

SIGNED

SIGNED

#-1 & 2 EVAP. DIST. TO
#-3 PORT & STBD...
F.W. DIST. (LAST 25 HRS)
31,300 GALS#-1 & 2 EVAP. DIST
TO #-3 PORT & STBD...

SIGNED

SIGNED

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels
of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS **ON BACK**

MINUTES AT

DATE _____

19

	Nov. 26 - 66																								Nov. 25 - 66																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	08339800		
0100	08327100	1300	
0200	08328300	1200	
0300	08329700	1400	
0400	08332900	1200	
0500	08332400	1500	1500
0600	08333600		1200
0700	08334900		1300
0800	08336100	1200	
0900	08337400	1300	
1000	08338600	1200	
X 1100	08309500	1200	
1200	08310600	1100	
1300	08311800	1200	
1400	08313000	1200	
1500	08314300	1300	
1600	08315800	1500	
1700	08317000	1200	
1800	08318300	1300	
1900	08319500	1200	
2000	08320800	1300	
2100	08322100	1300	
2200	08323400	1300	
2300	08324700	1300	
2400	08325800	1100	
		76300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	24	24	24
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	26900		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS	
Nov-26-66 1 1/2 evap. dist. to #3 port & stbd. SIGNED <i>[Signature]</i>	Nov-25-66 1 1/2 evap. dist. to #3 port & stbd. SIGNED <i>[Signature]</i>
0400 #1 Evap dist to #1 stbd 0500 Filled #1 H2O Evap Tank. 0700 shifted #1 Evap to #2 stbd. Dumped #1 stbd to Bilge. #1 port 12' Test 2 drops #1 stbd 2' Test salty #2 port Mt. Test #2 stbd 7' Test 2 drops SIGNED <i>R. Shuppard</i>	0400 #1 Evap dist to #3 port & stbd SIGNED <i>R. Shuppard</i>
#1 & 2 Evap. Dist to #3 Port & Stbd. WATER DIST. FOR LAST (24 Hrs) 54,300 9945 30,300 SIGNED <i>[Signature]</i> Stocked in CDS	#1 & 2 Evap Dist. to #3 Port & Stbd. SIGNED <i>[Signature]</i> For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

2

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	03536900	1100	
0200	03537800	1100	
0300	03539000	1200	
0400	03540100	1100	
0500	03541500	1400	1400
0600	03542600		1100
0700	03543700		1100
0800	03544800	1100	
0900	03545900	1100	
1000	03547000	1100	
1100	03548100	1100	
1200			
1300			
1400			
1500			
1600			
1700			
1800			
1900			
2000	03530900		
2100	03532200	1300	
2200	03533300	1100	
2300	03534500	1200	
2400	03535600	1100	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	#		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV 11-50) BACK

REMARKS

0000-0400
1 & 2 Evap. dist. to # 3
port & still.

SIGNED *[Signature]*

0400-0800
@ 0400 # 2 Evap dist to # 2 still
@ 0500 Filled # 2 No. 6 Evap Tank.

SIGNED *R. Shippard*

0800-1200
1 & 2 EVAP. DIST.
TO # 3 PORT & STILL.

WATER DIST. LAST 12 HOURS
17,200 GALS

SIGNED *E. J. Magallanes*

Stocked in CDS

1200-1600

SIGNED

1600-2000
@ 1845 Lit off # 2 Evap.
@ 1900 Drine pump stopp'd
secured # 2 plant
@ 1930 Lit off # 2 unit - dist. to
Bilges

SIGNED *R. Shippard*

2000-2400
1 & 2 EVAP DIST TO
3 PORT & STILL...

SIGNED *E. J. Magallanes*

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY YU. S. S. Gen John Pope 7 AP 110PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE Nov - 25, 1966

	NOV. 26 - 66												NOV. 25 - 66											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	6	6	6	6									7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	1	1	3	2	2	2	2	1	1	1	1									0	0	0	1	1
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	4	2	2	3	3	3	2	2	2									5	5	3	3	3
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	245	240	225	230	230	230	235	235	230	230									240	240	240	240	
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	200	200	205	205	205	205	205	200	200	200	200									190	190	190	190	200
1ST EFFECT SHELL PRESSURE, "HG	8"	8"	8"	8"	8"	8"	9"	8	8	8	8									11	11	11	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-									-	-	-	-	-
2D EFFECT SHELL PRESSURE, "HG	17"	17"	17"	17"	17"	17"	18"	18	18	18	18									19	19	19	19	19
3D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	160	160	160	158	160	154	154	154	154									150	150	154	154	150
3D EFFECT SHELL PRESSURE, "HG	-	-	-	-	-	-	-	-	-	-	-									-	-	-	-	-
CONDENSATE TO COOLER, TEMPERATURE, °F	135	135	136	138	138	140	140	138	138	135	135									136	136	136	136	135
CONDENSATE FROM COOLER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-									-	-	-	-	-
BRINE OVERBOARD, TEMPERATURE, °F	110	110	110	120	124	138	138	110	120	120	120									110	110	112	112	110
STEAM TO AIR EJECTOR, PRESSURE, #G	90	90	90	88	88	88	88	88	88	88	88									90	90	90	90	90
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	70	70	70	70	70	70	70	74	74	74	74									70	70	70	70	70
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	70	70	70	70	70	70	70	74	74	74	74									70	70	70	70	70
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-									-	-	-	-	-
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-									-	-	-	-	-
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	110	110	110	110	110	116	110	110	110	110	110									105	105	105	105	110
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	131	131	132	132	132	130	132	126	126	126	126									122	122	122	122	122
FEED TO 1ST EFFECT, TEMPERATURE, °F	152	152	158	156	156	156	156	156	156	156	156									142	142	142	142	142
CIRC. WATER OVERBOARD, TEMPERATURE, °F	90	90	90	90	90	90	90	94	94	90	94									90	90	90	90	90
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3									3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	22	22	22	20	20	20	20	20	20	20	20									21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25									25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	27	27	27	24	24	25	22	30	30	31	30									26	26	28	28	25
FEED PUMP SUCTION PRESSURE, #G	13	15	15	15	15	15	15	15	15	15	15									15	15	15	15	15
FEED PUMP DISCHARGE PRESSURE, #G	15	15	15	16	17	18	16	20	20	20	20									16	16	16	16	16
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	2	2	2	2	2	2	2	2	2									0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	52	52	54	52	52	50	50	54	54	54	54									53	53	53	53	52
F. W. PUMP DISCHARGE PRESSURE	10	10	8	10	10	10	10	10	10	10	10									10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.6	1.6	1.6	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5									1.5	1.5	1.5	1.5	1.6
CHEMICAL TEST	20	20	20	20	20	20	20	20	20	20	20									20	20	30	30	20
AIR EJECTOR DRAINS, SALINITY - E. P. M.	.02	.02	.02	.02	.02	.02	.02	.02	.02	.02	.02									.02	.02	.02	.02	.02
1ST EFFECT DRAINS, SALINITY - E. P. M.	0	0	.02	0	0	0	.02	0	0	0	0									0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY - E. P. M.	.04	.04	.02					.02	.02	.02	.02									.04	.04	.04	.04	.04