

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ MACH INSPECTION 1+2 BOLLERS, 1+2 F.O. BOLLERS 1+2 F.O.S.
P.M.P.S. 1+2 M.V.F.E. P.M.P.S. M.V.AUX AIR EJECTORS. M.V.AUX GIRE P.M.P.S. M.V.AUX COND. P.M.P.S. L.O. PURIFIER.
L.O.S P.M.P. MAIN AIR COMPRESSOR 1+2 AUX GENERATORS. A.C. UNIT F.R.C. & SAN P.M.P. STD STEERING GEAR.
TESTED OVERSPEED TRIP LOW L.O. ALARM ON M.V. TANKING & THROTT PUMPED BILGES. Checked Steering
F.R. Gear. Added 2 GALS L.O. #1 M.V. FEED P.M.P. MADE ROUTINE ROUNDS ON MACH & ENG SPACES.
Weekly test of EMERGENCY EQUIPMENT & SAFETY DEVICES.

WATCH ENGR'S SIGNATURE-

1600-2000 WATCH

Steaming as before. 1550 to 1616 blew tubes on #1 & 2 boilers.
Changed bottom burner in #1 & 2 boilers, shifted F.O. sect. to outboard sett.
at 1630. shifted & cleaned F.O. disch. strainer to #1 & 2 boilers. Checked all
operating mach. & S.E. room. 1752 Cruising Cond. set. W.T. Doors Closed B/S.
Added one gal. oil to #1 feed Pump. Pumped bilges.

WATCH ENGR'S SIGNATURE-

2000-2400 WATCH

Underway, Steaming on 18 Nozz, cleaned & changed top burners #1 & 2 Boilers
2030 to 2100 pumped Settlers from #4 & DB Tanks, cleaned & shifted L.O. strainers
on #1 & 2 generators. Clean & shift F.O. Disch. Strainers, made Rounds &
Insp of mach & Eng spaces. Made Weekly tests of Emerg Equip & Safety devices
& Machinery.

WATCH ENGR'S SIGNATURE-

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE CHANGED & CLEANED CENTER F.O. BURNERS.
P's DISCH STRAINERS. DAILY test of STBY L.O. PUMP FOR 1-HR PUMPED BILGES. INSPECTED &
CLEANED MAIN L.O. DISCH STRAINER. Check Steering F.R. Gear. Shifted F.O. Sect to Port
inbd sett & L.O. PUMPED UP outbd sett FROM #4 & DB TKS. Added 2 GALS L.O. to #1 MAIN
FEED PUMP. MADE ROUTINE ROUNDS ON MACH & ENG SPACES.

WATCH ENGR'S SIGNATURE-

0400-0800 WATCH

Steaming as before. Changed bottom burners in #1 & 2
boilers. shifted & cleaned F.O. Disch. and suction strainers to #1 & 2
boilers. added one gal. oil to #1 feed Pump. 0650 W.T. doors opened B/S
Pumped bilges & Cargo holds. Checked all operating mach. & S.E. room.
0730 shifted to outboard settler.

WATCH ENGR'S SIGNATURE-

0800-1200 WATCH

Underway, Steaming on 18 Nozz, cleaned & changed top burners #1 & 2 Boilers
0800 to 0840 blew tubes #1 & 2 Boilers, cleaned & changed L.O. strainers in #1 & 2 gen.
added oil to L.O. purifier, pumped Cargo holds p. & S.
Made Rounds & Insp of Mach & Eng spaces.

WATCH ENGR'S SIGNATURE-

CHIEF ENGINEER

BOILER READINGS

STB'D PORT

HOURS 11/62 HOURS 1319

AKL 7.58 AL 8.76

T-AT 1285 T-AKL 1285

SAL. 33' SAL. 4.14

PHOS. 50 PHOS. 4.5

R.ph 10 R.ph 10

CHIEF ENGR'S SIGNATURE-

USNS GEN John POPE TEP-116 VOYAGE NO. 7-B FROM CINCINNATI TO VUNG TAU VIETNAM TYPE OF VESSEL P2-52-RE DATE 1-28-67

WATCH							WATCH						
	1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200		1200 TO 1600	1600 TO 2000	2000 TO 2400	2400 TO 0400	0400 TO 0800	0800 TO 1200
RUNNING TIME	240	240	240	240	240	240	MACHINERY PARTICULARS (CONT'D)	AFT. H. P. ROTOR BEARING	139	138	139	138	138
DETENTION TIME						222		FORWARD L. P. ROTOR BEARING	132	135	132	132	135
REVOLUTION COUNTER (END OF WATCH)	2141	2143	2146	2148	2150	2153	TEMPERATURES (CONT'D)	AFT. L. P. ROTOR BEARING	130	130	131	130	130
TOTAL REVOLUTIONS (FOR WATCH)	23670	23800	23990	23780	23700	23780		HOTTEST GEAR BEARING FORWARD	154	155	154	155	153
AVERAGE RPM	98.5	99.1	100.0	99.0	98.7	96.2	TEMPERATURES (CONT'D)	HOTTEST GEAR BEARING AFT	146	145	146	145	146
F.O. METER (END OF WATCH)	1082	1082	1083	1083	1083	1084		AUX. COND. CONDENSATE	113/114		112/116	112/114	108/110
F.O. CONSUMED	2980	2870	2850	2880	2850	2670	TEMPERATURES (CONT'D)	1ST STAGE FEED WATER HEATER	162	162	162	162	162
MACHINERY PARTICULARS	PRESSURES	THROTTLE	440	435	440	435		D. C. FEED WATER HEATER	240	240	238	238	240
		H.P. AHEAD	440	430	440	435		3RD STAGE FEED HP WATER HEATER	050				
		L.P. AHEAD	27	28	28	27.5		F.O. TO BURNERS	200/195	190/195	200/200	195/195	200/210
		VACUUM	28.5"	28.2"	28.5	28.5		F.O. BACK PRESSURE	10	13	13/14	13	14
		L.O. TO TURBINES	12	12	12	12		AIR TO FURNACE	5.6/5.8	5.6/6.0	6.0/6.0	5.8/6.0	5.6/7.0
		AUX. STEAM	145	150	150	150		SALINITY UPTAKE	.41	.41	.41	.41	.83
		BACK PRESSURE	9	9	9	9		MAIN STEAM	440	435	440	435	435
		GLAND STEAM	1.0	1.0	1.5	1.5		SUPER HEAT	690	695	685	685	690
		H.P. BLEEDER	70	76	75	74		F.O. TO BURNERS	150/150	160/160	160/160	160/160	160/160
		I.P. BLEEDER	6	6	6	6		F.O. TEMP. IN SETTLING TANKS	75/80	80/80	83/85	85/85	80/85
TEMPERATURES	PRESSURES	L.P. BLEEDER	9"	9"	10	9	MISCELLANEOUS	PORT BOILER UPTAKE	325	325	320	330	340
		STEAM AT THROTTLE	690	695	685	685		STBD. BOILER UPTAKE	335	330	335	345	365
		L.P. EXHAUST	109	110	112	109		ENGINE ROOM TEMPERATURE	93	92	91	90	90
		CONDENSATE	105	105	106	105		FIRE ROOM TEMPERATURE	93	92	91	90	90
		CIRC. WATER IN	80	81	80	79		NOZZLES IN USE	18	18	18	18	18
		CIRC. WATER OUT	92	92	92	92		NO. OF BURNERS IN USE	6	6	6	6	6
		L.O. TO COOLERS	125	127	127	125		BURNER TIP SIZE	53/70	53/70	53/70	53/70	53/70
		L.O. FROM COOLERS	110	110	108	108		CO ₂ % PORT BOILER					13 1/4
		TEMPERATURE THRUST BEARING	118	118	118	117		CO ₂ % STBD. BOILER					13 1/4
		FORWARD H.P. ROTOR BEARING	124	124	125	124		OIL LEVEL MAIN SUMP	1'4"	1'4"	1'4"	1'4"	1'4"

GENERATORS												FUEL - WATER AND LUBE OIL					
WATCH	GENERATOR NUMBER	R.P.M.	STEAM PRESSURE	STEAM TEMP.	L.O. PRESSURE	L.O. TO COOLER	L.O. FROM COOLER	TEMP. OF HOTTEST BEARING	L.O. GOVERNOR PRESSURE	AMPS POSITIVE	AMPS NEGATIVE	FUEL OIL	WATER	LUBE OIL	DOMESTIC WATER	LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.)	L.O. CENTRIFUGE - HOURS OPERATED
1200 TO 1600	1	1200	440	690	9	122	110		62	700	700	METER AT NOON	10840720	ON HAND AT START OF DAY	254	4	4
	2	1200	440	690	7	136	122		60	850	850	METER PREVIOUS NOON	10823620	EVAPORATED OR RECEIVED	66	4	4
												CONSUMED BY METER	17100	ON HAND	267		
												ON HAND AT START OF DAY	17006	CONSUMED	53		
												RECEIVED DURING DAY	-0-	ON HAND AT START OF DAY	2580		
												EXPENDED DURING DAY	771	RECEIVED	-0-		
												REMAINING ON BOARD	16235	ON HAND	2575		
1600 TO 2000	1	1200	435	695	9	120	110		62	1000	1000	ON HAND AT START OF DAY	825	CONSUMED	5		
	2	1200	435	695	7	136	124		60	650	550	EVAPORATED OR RECEIVED	143	DIESEL OIL	1375		
												ON HAND	738	ON HAND	1372		
												CONSUMED	280	CONSUMED	3		
2000 TO 2400	1	1200	440	685	9	120	110		61	750	750	SUMMARY					
	2	1200	440	685	7	136	124		60	700	750	RUNNING TIME	1422	PERCENT OF SLIP	11.77		
												DETENTION TIME	-0-	BBL FUEL/MI	1.49		
2400 TO 0400	1	1200	435	685	9	120	110		62	750	750	TOTAL REVOLUTIONS	139050	WIND DIRECTION			
	2	1200	435	685	7	136	122		61	750	750	AVERAGE R.P.M.	97.7	STATE OF SEA			
												TOTAL MILES BY ENGINE	518	STATE OF WEATHER			
0400 TO 0800	1	1200	440	650	9	120	110		61	750	750	TOTAL MILES BY OBSERVATION	457				
	2	1200	440	650	7	135	122		60	850	850						

REMARKS

1200-1600 WATCH

UNDERWAY ON 18 NOZZ MACH IN OPERATION 1+2 BOILERS. 1+2 F.O. BURNERS 1+2 F.O.S. PUMPS. 1+2 MIN. F.O. PUMPS. MIN+MAX AIR EJECTORS. MIN+MAX CIRC. PUMPS. MIN+MAX COND. PUMPS. L.O. PURIFIER. L.O.S. PUMP. 1+2 AUX GENERATORS. A.G. UNIT. FIRE & SAN PUMP. MAIN A.R. COMPRESSOR. 2nd STEERING GEAR. TESTED OVERSPEED TRIP LOW L.O. ALARM ON MIN TURBINE & THRUST. PUMPED BILGES. PUMPED UP PORT SETTLERS FROM #4 & #4. CHECKED STEERING E.R. GEAR. ADDED 3 GALS L.O. TO #1 MIN FEED PUMP. MADE ROUTINE ROUNDS ON MACH & ENG'S SPACES.

WATCH ENGR'S SIGNATURE-

George Bunnay

1600-2000 WATCH

STEAMING AS BEFORE. 1555 TO 1618 BLEW TUBES ON #1 & 2 BOILERS. CHANGED BOTTOM BURNER IN #1 & 2 BOILERS, SHIFTED & CLEANED F.O. DISCH. STRAINER TO #1 & 2 BOILERS. CHECKED ALL MACH. AND S.E. ROOM. PUMPED BILGES. 1830 W.T. DOORS CLOSED 3/4. CRUISING COND. SET. ADDED (1) ONE GALLON OIL BACK TO #1 & 2 FEED PUMPS.

WATCH ENGR'S SIGNATURE-

H. Jones

2000-2400 WATCH

UNDERWAY, STEERING ON 18 NOZZ. CLEANED & CHANGED 70 DISCH STRAINERS. CLEANED TOP BURNERS #1 & 2 BOILERS, SHIFTED TO SHIPBOARD 70 SETTLER @ 2200. CHANGED & SHIFT L.O. STRAINERS #1 & 2 GENERATORS, ADDED 1 GAL L.O. TO #2 TUB. MADE ROUNDS & INSPECTION OF MACH & ENG SPACES.

WATCH ENGR'S SIGNATURE-

R. Summers

2400-0400 WATCH

UNDERWAY ON 18 NOZZ MACH AS BEFORE. CHANGED & CLEANED CENTER F.O. BURNERS. 1/2 DISCH STRAINERS. DAILY TEST OF STBY L.O. PUMP FOR 1-HR. INSPECTED & CLEANED MAIN L.O. DISCH STRAINER. PUMPED BILGES. CHECKED STEERING E.R. GEAR. PUMPED UP PORT SETTLERS FROM #4 & #4. 1/2 K13 TKS. ADDED 2 GALS L.O. TO #1 MIN FEED PUMP. MADE ROUTINE ROUNDS ON MACH AND ENG'S SPACES.

WATCH ENGR'S SIGNATURE-

George Bunnay

0400-0800 WATCH

STEAMING AS BEFORE. CHANGED BOTTOM BURNER ON #1 & 2 BOILERS. SHIFTED & CLEANED F.O. SUCTION AND DISCH. STRAINERS TO #1 & 2 BOILERS. SHIFTED & CLEANED MAIN L.O. STRAINER. CHECKED ALL OPERATING MACH. & S.E. ROOM. PUMPED BILGES & CARGO TANKS. 0710 OPENED W.T. DOORS. MODIFIED CRUISING COND. SET. 3/4.

WATCH ENGR'S SIGNATURE-

R. Summers

0800-1200 WATCH

UNDERWAY, STEAMING ON 18 NOZZ, CLEANED TOP BURNERS #1 & 2 BOILERS, CLEAN & SHIFT L.O. STRAINERS #1 & 2 ENG, CLEAN & SHIFT 70 DISCH STRAINERS, @ 1000 SET COND, 3 CLOSED W.T. DOORS. @ 1045 TOOK DRAG ON 70 TANK #6 D.B. @ 1100 REDUCE SPEED TO 90 RPM BOB, STEERING ENG ROOM MANEUVERED BY MC SUMMERS @ 1130, MADE ROUNDS & INSPECTION OF MACH. & ENG SPACES.

WATCH ENGR'S SIGNATURE-

R. Summers

CHIEF ENGINEER

BOILER WATER READINGS

STB'D PORT

HOURS 1486 HOURS 1349

AKL 7.01 AKL 8.76

T-AKL 1226 T-AKL 1460

SAL. 3.51 SAL. 4.14

PHOS. 50 PHOS. 50

R.ph 10 R.ph 10

CHIEF ENGR'S SIGNATURE-

R. Summers

REMARKS

1200-1600 WATCH

Underway MANEUVERING Shifted MAIN SEA SMT to High @ 1200 FINE @ 1306. CTR 21535310. FOM #1- 3736090 - #2- 7105450. Secured M.S.B.S AND Engaged TACKLING @ 1315. Secured 1st stage on AIR EJECTOR. BULL AS PER BOOK. MACH INOPERATION #1+2 Boiler 1+2 F.W. PUMPS 1+2 F.O.S. PUMPS 1+2 M.H.F. PUMPS M.H.AUX AIR EJECTORS. M.H.AUX AIR PUMPS. M.H.AUX COND PUMPS. 1+2 AUX GENERATORS. M.H. AIR COMPRESSOR. F.W. & SAN PUMPS. H.C. UNIT. L.O. PURIFIER. L.O.S PUMP. Checked STARRING E.R. Bilges at safe level Rotor CLEARING FULL ASTER HP 1070 LP 090

1600-2000 WATCH

OILER STALLWORTH FWT MORGAN. Refer Allen. Elmer PORTER WATCH ENGR'S SIGNATURE: *Henry Bruny*
Anchored in Vung Tau Harbor. Steaming #1+2 Turbo H.C. L.C. system in operation with J.G. engaged. Shifted M.C.F. to main Condenser. Checked all operating mach & S.E. room. Shifted & cleaned F.O. Disch. strainer to #1+2 boilers

2000-2400 WATCH

OILER - QUEEN F/W LINDSLEY WATCH ENGR'S SIGNATURE: *Jim Jones*
At Anchor, Vung Tau, Steaming #1+2 Boilers, maintain Vacuum on main unit, L.C. system in operation jacking gear engaged, added 2 gal L.O. to #2 Feed pump, added 3 gal L.O. to #1 Feed pump, made Rounds & Insp of Mach & Eng spaces.

2400-0400 WATCH

Oiler Lovell, F/W Higgins, Tefer, Beane. WATCH ENGR'S SIGNATURE: *R Summers*
AT ANCHOR VUNG TAU MACH INOPERATION AS BEFORE WITH VACUUM UP ON MAIN UNIT SECURED L.O. PURIFIER @ 0000 CLEANED BACK IN SERVICE ON 5 @ 0030 CHANGED & CLEANED F.O. BURNERS ON #1+2 BOILERS. % DISCH. STRAINERS DAILY test of Stby L.O. PUMP FOR 1-HR. Bilges AT SAFE LEVEL. Checked STARRING E.R. Made ROUTINE ROUNDS ON MACH & ENG SPACES

0400-0800 WATCH

OILER MCGINNIS FWT MORGAN. Refer Allen. WATCH ENGR'S SIGNATURE: *Henry Bruny*
Steaming as before. Aux static with vacuum upon main unit. Shifted and cleaned F.O. section & Disch strainer to #1+2 boilers. gave #2 boiler bottom blow for (1) hour through contaminated Enaps. Checked all operating mach. & S.E. room. Added jacking to top of lower gage glass on #2 boiler. 0730 shifted section to outboard settler.

0800-1200 WATCH

OILER - QUINN F/W LINDSLEY. WATCH ENGR'S SIGNATURE: *Jim Jones*
At Anchor, Vung Tau, Vacuum on main unit, jacking gear engaged. Cleaned & changed Burners #1+2 Boilers, clean & shift F.O. Disch strainers. @ 0910 Secured #2 main Feed pump. Repacking same, Stby feed pump in oper. @ 1130 Secured Sanitary system, working on piping, @ 1140 Sanitary system put in service. made Rounds & Insp of Mach & Eng spaces.

CHIEF ENGINEER

Oiler - Lovell F/W Higgins WATCH ENGR'S SIGNATURE: *R Summers*

BOILER WATER READINGS

STE'D PORT

HOURS 1370 HOURS 1367

AKL 7.01 AKL 8.26

T-VL 1285 T-AKL 1285

SAL. 1.90 SAL. 4.14

PHOS. 50 PHOS. 45

R.ph 10 R.ph 10

CHIEF ENGR'S SIGNATURE: *Chen*

REMARKS

1200-1600 WATCH

AT ANCHOR PORT OF VUNG TAN S. VIET NAM. MACH INOPERATION. 1+2 Boilers 1+2 I.D. Bledors. 1+2 Stby Fuel Pumps. 1+2 F.O.S. Pumps. M.N. + Aux A.R. Ejectors. M.N. + Aux CIRC Pumps. M.N. + Aux COND. Pumps. 1+2 Aux GENERATORS L.O. Purifier. L.O.S. Pump. P.C. Unit. FIRE + SDH PUMP. MAIN AIR COMPRESSOR. PUMPED MAP PORT SOILERS FROM #4 D.B. TKS. Tested CO2 ALARM VACUUM UP ON MAIN UNIT. REPAIRS COMPLETED ON #2 M.N. FUEL PUMP @ 1420 PART SAME ON THE LINE + SECURED Stby. Changed & Cleaned 1/2 F.O. Disch Strainers. Bilges AT SAFE LEVEL. Checked Steering E.R. Added 2 BALS L.O. to #2 M.N. FUEL PUMP. Made Rounds on MACH + ENG. SPACES.

Oiler Stallworth FWT Morgan REPAIR ATTEND.

WATCH ENGR'S SIGNATURE-

George Bannay

1600-2000 WATCH

Steaming as before. Changed burners on #1 + 2 boilers. Shifted and Cleaned F.O. Discharge strainer to #1 + 2 boilers. Checked all operating machinery and S.E. room.

CILER-QUEEN F/W-LINDSLEY-

WATCH ENGR'S SIGNATURE-

Jim Jones

2000-2400 WATCH

At Anchor, Vung Tan, Vacuum on main unit, Jocking gear engaged, L.O. Sys in operation, Cleaned & changed Burners, L.O. Strainers on #1 + 2 Generators. Made Rounds & Insp of MACH + Eng spaces. Added 1 gal L.O. to #2 main fuel pump.

Oiler-Lowell FWT Highers

WATCH ENGR'S SIGNATURE-

R Summers

2400-0400 WATCH

AT ANCHOR VUNG TAN MACH INOPERATION AS BEFORE. Daily test of Stby L.O. PUMP FOR 1-hr. Inspected & Cleaned main L.O. Disch STRAINERS. Held ENGS CASUALTY drill B-6. Major fuel oil LEAK. Watch Inst + Bridge notified same - also changed & cleaned 1/2 F.O. Disch STRAINERS. Bilges AT SAFE LEVEL. Took A drag ON #1 & D.B. F.O. TKS. Made Routine Rounds ON MACH + ENGS SPACES.

Oiler Stallworth FWT Morgan.

WATCH ENGR'S SIGNATURE-

George Bannay

0400-0800 WATCH

At Anchor, steaming as before. Held fire room Casualty drill B-6. Major fuel oil leak. inst. watch notified Bridge. Shifted & Cleaned F.O. Suck and discharge strainers to #1 + 2 boilers. Compounded #2 boiler with 60% M59. Checked all operating mach. + S.E. room. Shifted and Cleaned main L.O. strainer.

CILER-QUEEN F/W LINDSLEY

WATCH ENGR'S SIGNATURE-

Jim Jones

0800-1200 WATCH

At Anchor, Vung Tan, Vacuum on main unit, L.O. system in operation, Jocking gear engaged, Cleaned & changed burners, clean & shift F.O. Disch strainers, 0900 to 0930 Held Eng Casualty Drill B-6 4-men present bridge notified, Made Rounds & Insp of MACH + Eng spaces.

Oiler-Lowell FWT Highers

WATCH ENGR'S SIGNATURE-

R Summers

CHIEF ENGINEER

BOILER WATER READINGS

STB'D

PORT

HOURS 1534 HOURS 1390

AKL 7.01 AKL 7.01

T-REL 1168 T-AKL 1168

SAL. 2.98 SAL. 3.31

PHOS. 50 PHOS. 30

R.ph 10 R.ph 18

CHIEF ENGR'S SIGNATURE-

R Summers

USNS		VOYAGE NO.		FROM		TO		TYPE OF VESSEL		DATE	
Gen John Pope TAP-110		7-6		Vung Tau Vietnam				P2-52-R8		1-31-67 2-1-67	
WATCH											
1200 TO 1600 1600 TO 2000 2000 TO 2400 2400 TO 0400 0400 TO 0800 0800 TO 1200											
RUNNING TIME 6 240 240											
DETENTION TIME											
REVOLUTION COUNTER (END OF WATCH) 2153 2156 2158 6140 0980 4530											
TOTAL REVOLUTIONS (FOR WATCH) 21520 2350											
AVERAGE RPM 89.6 98.1											
F.O. METER (END OF WATCH) 1084 1085 1088 9520 2290 5040											
F.O. CONSUMED 1000 2770 2750											
MACHINERY PARTICULARS (CONT'D)											
AFT. H. P. ROTOR BEARING 140 138											
FORWARD L. P. ROTOR BEARING 133 132											
AFT. L. P. ROTOR BEARING 130 130											
HOTTEST GEAR BEARING FORWARD 153 154											
HOTTEST GEAR BEARING AFT 145 146											
AUX. COND. CONDENSATE 120 114											
1ST STAGE FEED WATER HEATER 164 163											
D. C. FEED WATER HEATER 240 238 238											
3RD STAGE FEED WATER HEATER 154 154											
F.O. TO BURNERS 195 200 260 195 200 186											
F. O. BACK PRESSURE 10 10 10 10 10 10											
AIR TO FURNACE 1.5 5.6 5.5 1.5 5.6 5.5											
SALINITY UPTAKE .41 .41 .41											
MAIN STEAM 440 430 440											
SUPER HEAT 600 700 700											
F.O. TO BURNERS 150 155 155 150 155 155											
F.O. TEMP. IN SETTLING TANKS 85 85 85 85 85 85											
PORT BOILER UPTAKE 360 315 320											
STBD. BOILER UPTAKE 300 320 325											
ENGINE ROOM TEMPERATURE 91 90 88											
FIRE ROOM TEMPERATURE 91 90 88											
NOZZLES IN USE 18 18 18											
NO. OF BURNERS IN USE 6 6 6											
BURNER TIP SIZE 53 53 53 70 70 70											
CO2 % PORT BOILER											
CO2 % STBD. BOILER											
OIL LEVEL MAIN SUMP 1'4" 1'4" 1'4"											
MACHINERY PARTICULARS											
THROTTLE 440 430 440											
H.P. AHEAD 430 440											
L.P. AHEAD 25" 27 27											
VACUUM 28.0 28.2 28											
L.O. TO TURBINES 12 12 12											
AUX. STEAM 150 150 150											
BACK PRESSURE 9 9 9											
GLAND STEAM 2.0 4.0 1.0											
H.P. BLEEDER - 70 70											
I.P. BLEEDER - 6 6											
L.P. BLEEDER - 8" 8"											
STEAM AT THROTTLE 700 700											
L.P. EXHAUST 115 106 107											
CONDENSATE 102 104											
CIRC. WATER IN 78 76											
CIRC. WATER OUT 88 88											
L.O. TO COOLERS 110 127 126											
L.O. FROM COOLERS 109 109 108											
TEMPERATURE THRUST BEARING 118 117											
FORWARD H.P. ROTOR BEARING 124 124											
GENERATORS											
WATCH GENERATOR NUMBER R.P.M. STEAM PRESSURE STEAM TEMP. L.O. PRESSURE L.O. TO COOLER L.O. FROM COOLER TEMP. OF HOTTEST BEARING L.O. GOVERNOR PRESSURE AMPS POSITIVE AMPS NEGATIVE VOLTS											
1200 TO 1600 1 1200 440 9 120 110 62 1300 1300 240											
2 1200 440 7 135 122 60 240											
1600 TO 2000 1 1200 430 700 9 120 110 61 1500 1450 240											
2 1200 440 7 135 122 60 240											
2000 TO 2400 1 1200 440 9 118 108 62 1400 1400 240											
2400 TO 0400 4 4 4											
0400 TO 0800 4 4 4											
0800 TO 1200 4 4 4											
FUEL - WATER AND LUBE OIL											
METER AT NOON 10855040											
METER PREVIOUS NOON 10848620											
CONSUMED BY METER 6620											
ON HAND AT START OF DAY 15907											
RECEIVED DURING DAY -0-											
ON HAND AT START OF DAY 2400											
RECEIVED DURING DAY 321											
REMAINING ON BOARD 15586											
ON HAND AT START OF DAY 650											
EVAPORATED OR RECEIVED											
ON HAND											
CONSUMED											
LOW PRESS. EVAPORATORS (No. of hrs. operated) (Fresh water made gals.) 4 4											
L.O. CENTRIFUGE - HOURS OPERATED											
1200 TO 1600 1600 TO 2000 2000 TO 2400 2400 TO 0400 0400 TO 0800 0800 TO 1200											
4 4 4											
SUMMARY											
RUNNING TIME											
DETENTION TIME											
TOTAL REVOLUTIONS											
AVERAGE R.P.M.											
TOTAL MILES BY ENGINE											
TOTAL MILES BY OBSERVATION											
PERCENT OF SLIP											
BBL FUEL/MI											
WIND DIRECTION											
STATE OF SEA											
STATE OF WEATHER											

REMARKS

1200-1600 WATCH

AT ANCHOR Vung Tau. MACH IN OPERATION 1+2 BOILERS 1+2 FLS BLOWERS 1+2 FAS PUMPS 1+2 MAIN
 FEED PUMPS. MIN+MAX AIR EJECTORS MIN+MAX CIRC PUMPS MIN+MAX COND PUMPS. LA. PURIFIER L.O.S. PMP. FIRC. SAN PMP.
 MAIN AIR COMPRESSOR. 1+2 AUX GENERATORS. P.C. UNIT. PUMPED UP PORT 3rd FROM #4 P.A. B.T.K. TIME CHECK @ 1358
 WHEEL CLEARANCE & PERMISSION TO TEST MAIN ENGINE @ 1358. Engaged Tacking Gear @ 1400. OPEN M.S. & R.B. &
 WARMING UP MAIN UNIT @ 1405. Tested Telegraph @ 1405. St by @ 1446. CTR 21536140. FOM-P-7109780-S-3739360
 BULLS AS PER BOOK Dept @ 1554. CTR 21539460. FOM-P-7110080-S-3739620. 18NOV22 90

1600-2000 WATCH
 1615

Under way on 18 Nov. 1600 to 1625 blew tubes on #1 & 2 boilers
 1615 let off #1 & 2 of Engrs 1628 Engines up to speed 18 Nov. 1650 open low
 and closed high sea section. 1730 secured #2 Turbo Gen. 1745 secured #2
 Aux. Generator. 1815 Ch. Engr. inspected Engine room & mach. Port oil pump in
 straining Eng. is imply phd. pump is low of oil 1st assist. Engr. has been notified.
 Checked all operating mach. & S.E. room.

WATCH ENGR'S SIGNATURE-

2000-2400 WATCH

Underway, Steaming on 18 Nov, Cleaned & Changed Top Budmers #1+2 Blue
 Clean & Shift 70 Dieck Strainers #1+2, Cleaned & Shift 20 strainers #1+2 Gen.
 Pumped filges & Cargo holds, Made Rounds and Snaps of Mach & Eng spaces

WATCH ENGR'S SIGNATURE-

2400-0400 WATCH

WATCH ENGR'S SIGNATURE-

0400-0800 WATCH

WATCH ENGR'S SIGNATURE-

0800-1200 WATCH

WATCH ENGR'S SIGNATURE-

CHIEF ENGINEER

12-1600 Cont. N.B.C. DRILL @ 1300 Secured @ 1345

BOILER WATER READINGS

STB'D	PORT
HOURS	HOURS
AKL	AKL
T-/KL	T-AKL
SAL.	SAL.
PHOS.	PHOS.
R.ph	R.ph

CHIEF ENGR'S SIGNATURE-

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 1/27/67

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																			DATE 1/27/67		
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	STEAM & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREC IN COMPRESSOR	COND WATER		CHILLED WATER		BEARING		TEMPERATURE		REMARKS
							SUCTION	DISCHARGE					IN	OUT	IN	OUT	LINE	THRUST		SPEED RPM	
1200	440	250	12	11	ON	13	18	6.5	14	6	26	46	112	96	77	84	49	46	127	78	1200-1600
1300	440	260	12	11	ON	13	18	6.5	14	6	26	46	112	96	77	84	49	46	127	78	1600-2000
1400	440	250	12	11	ON	13	18	6.5	14	6	26	46	112	96	77	84	48	45	128	78	
1500	440	250	12	11	ON	13	18	5.5	14	6	26	46	112	94	76	83	48	45	127	78	
1600	440	250	11	11	ON	13	18	6	15	7	26	46	110	94	76	82	48	45	126	77	2000-2400
1700	440	250	12	11	ON	13	18	6	15	7	26	46	112	94	76	82	48	45	127	78	
1800	440	250	12	11	ON	13	18	6	15	7	26	46	112	94	76	82	48	45	127	78	
1900	440	250	11	11	ON	13	18	6.5	15	7	26	46	112	96	76	82	48	45	127	78	
2000	440	260	11	11	ON	13	18	7	15	6	26	46	112	96	78	83	49	46	128	78	0000-0400
2100	440	270	13	11	ON	13	18	7	15	6	26	46	113	97	78	83	50	46	128	78	
2200	440	260	12	11	ON	13	18	6.5	15	6	26	46	113	96	77	83	49	45	128	78	
2300	440	250	10.5	11	ON	13	18	7	15	6	26	46	113	96	78	83	49	45	128	79	
2400	440	250	12	11	ON	13	18	7	15	6	26	46	113	97	78	83	48	45	129	79	
0100	440	250	11	11	ON	13	18	7	15	6	26	46	114	97	79	84	49	45	129	79	0400-0800
0200	440	250	11	11	ON	13	18	7	15	6	26	46	112	96	78	84	48	45	129	80	
0300	440	250	13	11	ON	13	18	6.5	15	6	26	46	112	96	78	84	48	45	129	80	
0400	440	250	13	11	ON	13	18	6.5	15	6	26	46	112	96	78	84	48	45	130	80	
0500	440	250	11	11	ON	13	18	7	15	6	26	46	113	96	78	84	48	45	130	80	0800-1200
0600	440	250	11	11	ON	13	18	7	15	6	26	46	114	96	78	84	48	45	130	80	
0700	440	250	12	11	ON	13	18	7	15	6	26	46	114	96	78	84	48	45	130	80	
0800	430	250	10.5	11	ON	13	18	7	15	6	26	46	114	97	78	84	50	46	130	80	
0900	440	260	11	11	ON	13	18	7	15	6	26	46	114	97	79	84	49	46	130	80	
1000	440	270	12	11	ON	13	18	7.5	15	6	26	46	115	98	80	85	50	46	130	80	
1100	440	270	11	11	ON	13	18	8	15	6	26	46	115	99	80	85	50	46	130	80	

All

Bent

B. Law

All

Bent

B. Law

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG

DATE 1/26/67

CENTRIFUGAL AIR CONDITIONING COMPRESSOR LOG																				DATE 1/26/6		
TIME	STEAM TO THROTTLE	STEAM TO NOZZLE	STEAM TO EXHAUST	SEER & LUBE OIL	PURGE UNIT	COMPRESSOR LUBE OIL	PRESSURE		COND WATER	CHILLED WATER	L.O. TEMP.	FREC IN COMPRESSOR	COND WATER		CHILLED WATER		BEARING		TEMPERATURE	SPEED RPM	REMARKS	
							SUCTION	DISCHARGE					IN	OUT	IN	OUT	LINE	THRUST				
1200																					1200-1600 1330 Kit off unit Allen	
1300																					1600-2000	
1400	440	240	11	11	ON	13	17	5	14	6	25	45	105	90	73	26	47	44	74	114	3500	
1500	440	240	11		ON	13	18	4.5	14	6	25	45	105	90	73	76	47	44	120	72	3350	Bintley
1600	420	230	11	11	ON	13	18	4.5	14	6	26	45	106	90	74	80	47	44	122	73	3375	2000-2400
1700	400	240	12	11	ON	13	18	4.1	14	6	26	45	106	90	74	80	47	44	122	73	3350	
1800	420	240	11	11	ON	13	18	4.5	14	6	26	46	108	90	73	78	47	44	122	74	3300	
1900	430	240	11	11	ON	13	18	4.5	14	6	26	46	108	90	73	78	47	44	122	74	3300	Beam
2000	420	230	11	11	ON	13	18	4.5	15	6	26	46	109	90	73	78	47	44	122	74	3325	0000-0400
2100	410	230	11.5	11	ON	13	18	4.5	15	6	26	46	109	90	73	78	47	44	122	74	3300	Retard clutch 1 hour
2200	420	230	11	11	ON	13	18	4.5	14	6	26	46	110	90	74	79	47	44	124	75	3300	
2300	430	230	11	11	ON	13	18	5	14	6	26	46	110	93	76	81	47	44	124	76	3325	Allen
2400	430	230	11	11	ON	13	18	5	14	6	26	46	110	92	76	82	47	44	126	78	3325	
0100	440	220	11	11	ON	13	18	5	14	6	26	46	110	93	74	82	47	44	126	77	3325	0400-0800
0200	440	230	11	11	ON	13	18	5	14	6	26	46	110	93	76	82	47	44	126	77	3350	
0300	440	230	11	11	ON	13	18	5	14	6	26	46	112	93	78	83	47	44	127	78	3375	
0400	440	230	11	11	ON	13	18	5	14	6	26	46	112	92	76	82	47	44	128	78	3350	
0500	440	230	12	11	ON	13	18	5.5	14	6	26	46	112	94	76	82	47	44	128	78	3375	Bintley
0600	440	240	11	11	ON	13	18	6	14	6	26	46	112	94	76	82	48	45	128	78	3375	0800-1200
0700	440	230	11	11	ON	13	18	6	14	6	26	46	112	94	76	82	48	45	129	78	3375	
0800	440	250	12	11	ON	13	18	7	14	6	26	46	115	96	78	84	48	45	130	79	3425	
0900	400	260	11	11	ON	13	18	7	14	6	26	46	115	97	80	85	48	46	129	78	3425	Beam
1000	440	260	12	11	ON	13	18	7	14	6	26	46	115	96	78	81	49	45	129	78	3425	
1100	440	250	12	11	ON	13	18	6	14	6	26	46	114	95	78	81	48	45	129	78	3425	
1200	440	250	11	11	ON	13	18	6	14	6	26	46	113	94	77	82	49	45	128	78	3400	

$$\begin{array}{r} 12 \\ 8 \\ \hline 96 \\ 12 \\ \hline 108 \end{array}$$

5034

$$\begin{array}{r} 419.50 \\ 12 \overline{) 5034} \\ \underline{48} \\ 23 \\ 12 \\ \underline{12} \\ 104 \\ 108 \\ \underline{60} \\ 60 \end{array}$$

$$\begin{array}{r} 419.50 \\ 133.76 \\ \hline 553.26 \\ 11200 \\ \hline 665.26 \\ 18 \\ \hline 581.808 \\ 727.26 \\ \hline 7309068 \end{array}$$

4

$$\begin{array}{r} 209 \\ 8 \\ \hline 1672 \\ 8 \\ \hline 133.76 \end{array}$$

7

5

$$\begin{array}{r} 72726 \\ 13090 \\ \hline 162 \end{array}$$

$$\begin{array}{r} 72726 \\ 1309 \\ \hline 596.36 \end{array}$$

$$\begin{array}{r} 1243 \\ 145 \\ 8 \\ \hline 1400 \\ 1400 \\ \hline 2800 \\ 28 \end{array}$$

$$\begin{array}{r} 325 \\ 20 \\ \hline 6500 \\ 6500 \end{array}$$

$$\begin{array}{r} 3800 \\ 4 \\ \hline 11200 \end{array}$$


TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
1240	72	0	120	98	0	115	92							2	120	100
1400	72	0	120	98	0	120	93							22	115	100
1600	76	0	120	100	0	120	94							10	120	100
1800	77	0	120	100	—	—	—							—	—	—
2000	74	0	120	98	0	120	94							9	120	99
2200	72	0	115	97	0	120	93							19	120	98
2400	72	0	120	98	0	115	92							15	120	99
2600	72	0	120	98	0	120	94							12	120	99
2800	72	0	115	98	0	120	94							7	120	99
3000	73	0	115	98	0	120	94							—	—	—
3200	72	0	120	99	0	120	92							5	120	99
3400	71	0	120	98	0	120	95							—	—	—
3600	71	0	120	99	0	120	94							17	120	99

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE

1/22/69

COLD STORAGE BOX TEMPERATURES												REMARKS
TIME	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT	
1200 0200	0	34	4	0	30	-1	34	-2	37	34	40	0000-0400 1200-1600 All.
1400 0400	0	34	4	0	28	-1	35	0	37	34	40	0400-0800 1600-2000 Gintef
1600 0600	1	36	3	0	28	-1	35	2	37	36	41	...
1800 0800	0	36	3	0	24	-1	35	-1	37	36	41	
2000 1000	0	34	3	0	21	-2	34	0	37	35	40	1000-1200 2000-2400 Blair
2200 1200	-1	35	3	-1	20	-2	34	-2	37	35	40	Retard Clocks 1 hour
2400 1400	0	34	3	-1	19	-2	34	0	37	36	40	
0100 1500	0	34	3	-1	17	-2	34	0	37	36	40	All.
0300 1700	0	34	3	-1	17	-2	34	-1	37	37	41	
0500 1900	0	35	3	0	28	-2	35	0	36	35	40	Gintef
0700 2100	0	36	3	0	31	5	34	7	36	34	40	
0900 2300	6	36	3	0	30	0	34	-1	36	34	39	1600-2000 0400-0800 Blair
1100 2500												2000-2400 0800-1200 Gintef


 CHIEF ENGINEER

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE 1/21/67

TIME	COLD STORAGE BOX TEMPERATURES										FRUIT
	ICE	DAIRY	MEAT	FROZ	THAW	MEAT	THAW	MEAT	VEG.	BUTT.	
	CREAM			FOOD						EGGS	
	1	2	3	4	5	6	7	8	9	10	11
0200	-1	34	7	0	35	5	34	1	37	33	40
0400	0	37	5	0	30	2	34	0	37	33	40
0600	2	37	4	0	25	0	35	0	37	34	40
0800	1	36	4	0	22	-1	37	0	37	35	40
1000	-1	36	3	-1	21	-1	35	-2	38	34	40
1200	0	35	3	-1	19	-1	34	1	38	34	40
1400	0	36	2	-2	16	-1	34	1	37	34	40
1600	-1	34	3	-1	17	-1	34	1	37	34	40
1800	0	34	3	-1	14	-1	34	-2	37	35	41
2000	-1	36	4	0	28	0	35	7	36	34	40
2200	0	36	3	3	23	-1	36	-1	36	33	40
2400	-1	38	3	3	29	-1	35	-1	36	35	40

REMARKS	
1200-1600	Allan
1600-2000	Gintef
2000-2400	Beano
2400-0400	Allan
0400-0800	Gintef
0800-1200	Beano

CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
1240	72	0	120	98	0	120	93							7	115	100
1400	72	0	120	96	0	120	94							-	-	-
1600	72	0	115	95	0	120	93							8	120	98
1800	74	0	120	100	0	120	93							-	-	-
2000	74	0	120	98	-	-	-							18	120	99
2200	73	0	120	99	0	120	95							17	120	99
2400	73	0	120	100	0	120	94							12	120	99
2600	74	0	120	98	0	120	94							10	120	100
2800	74	0	120	98	-	-	-							10	120	100
3000	74	0	115	98	0	120	94							10	120	100
3200	73	0	120	98	-	-	-							3	115	99
3400	72	0	120	97	0	115	92							4	115	98

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	74	0	120	100	0	120	94									
14:00	74	0	120	100	0	115	94							4	120	100
16:00	72	0	120	100	0	120	94							10	120	100
18:00	72	0	120	98	0	120	93							5	115	98
20:00	74	0	120	100	0	120	95							12	120	99
22:00	74	0	120	99	0	120	93							9	120	99
24:00	73	0	120	98	0	120	93							10	120	99
02:00	74	0	120	99	0	115	92							7	120	99
04:00	74	0	120	99	0	120	94									
06:00	70	0	120	98	0	120	93							10	120	98
08:00	70	0	120	94	0	120	93							7	120	96
10:00	71	0	120	99	-	-	-							6	120	99

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE

1/20/67

TIME	COLD STORAGE BOX TEMPERATURES										
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT
	1	2	3	4	5	6	7	8	9	10	11
1200	0	36	4	0	21	-2	34	4	37	36	39
1400	0	36	4	0	25	-3	34	-1	37	36	39
1600	1	35	4	0	21	-2	34	0	37	-	40
1800	1	37	3	0	21	-3	36	0	37	41	40
2000	0	35	3	-1	19	-3	34	-2	37	34	40
2200	0	34	3	-1	18	-3	34	0	37	34	40
2400	0	36	4	0	17	-3	35	1	37	34	41
0100	0	37	4	0	16	-3	34	0	37	34	40
0200	0	36	4	0	16	-3	34	0	37	34	40
0400	0	38	4	0	24	-2	40	-2	40	36	42
0600	0	37	4	0	23	-1	37	0	38	34	40
0800	-1	37	4	0	18	-2	35	-1	36	33	40

REMARKS

1200-1600

DEFROSTING #10 Box @ 1500

Allen

1600-2000

Box #10 BACK ON THE LINE @ 1800

Sinter

2000-2400

Blair

2400-0100

Retard Clocks 1 hour

Allen

0100-0400

Sinter

0400-0800

Blair


 CHIEF ENGINEER

MAIN REEFER LOG: USNS GEN JOHN POPE (T-AP110)

DATE

11/19/67

TIME	COLD STORAGE BOX TEMPERATURES										
	ICE CREAM	DAIRY	MEAT	FROZ FOOD	THAW	MEAT	THAW	MEAT	VEG.	BUTT. EGGS	FRUIT
	1	2	3	4	5	6	7	8	9	10	11
1200	0	35	4	-1	28	-1	34	2	36	39	40
1400	0	34	4	-1	28	-3	34	-1	36	34	40
1600	3	34	4	0	24	-3	35	0	37	35	40
1800	0	36	4	-1	22	-1	34	0	37	35	40
2000	0	36	4	-1	22	0	34	2	37	35	40
2200	-1	37	4	-1	20	2	34	-1	38	34	40
2400	0	35	4	0	20	0	34	-1	37	35	40
1200	0	36	4	0	19	-1	34	2	37	35	40
1400	-1	36	4	0	18	-2	34	-1	37	35	40
1600	-1	36	4	0	19	-2	37	2	36	35	40
1800	-1	37	4	-1	24	-2	34	22	36	35	39
2000	0	37	4	-1	22	-1	35	0	37	36	40

REMARKS

1200-1600

Completed greasing a-c units

Allen

1600-2000

Bintef

2000-2400

Blans

2400-1200

Allen

1200-1800

Bintef

1800-1200

Blans


 CHIEF ENGINEER

TIME	CIRC WATER	COMPRESSOR 1			COMPRESSOR 2			COMPRESSOR 3			COMPRESSOR 4			COMPRESSOR 5		
	INLET TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP	SUCT PRESS	DISCH PRESS	WATER OUT TEMP
12:00	72	0	115	98	0	120	92							15	115	100
14:00	72	0	120	98	0	120	93							12	120	100
16:00	72	0	120	98	-	-	-							15	120	100
18:00	72	0	120	98	0	115	93							15	120	100
20:00	73	0	-	-	0	115	92							-	-	-
22:00	73	0	120	100	0	115	92							13	120	99
24:00	73	0	120	100	0	120	94							5	115	100
02:00	74	0	120	100	0	120	92							12	120	100
04:00	73	0	120	98	0	120	94							-	-	-
06:00	72	0	120	98	-	-	-							10	120	100
08:00	71	0	120	98	0	120	93							9	120	98
10:00	71	0	115	97	-	-	-							9	120	98

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	
1.	L.P. EXHAUST TEMP	109	109	109	108	106	105	105	104	106	107	108	109	108	109	109	108	110	108	110	110	110	111	111	112	109
2.	MN COND STE TEMP	105	105	104	102	102	98	100	99	100	103	103	104	105	105	105	104	105	105	105	105	105	105	106	106	104
3.	MN INJ TEMP	79	79	79	78	77	75	75	75	76	78	78	80	80	80	80	80	80	81	81	80	80	80	80	80	80
4.	MN OVBD TEMP	98	98	98	90	90	86	86	86	88	90	90	92	92	92	92	92	92	92	92	92	92	93	93	93	92
5.	L.O. TO COOLERS	124	126	126	127	127	126	126	126	127	127	127	128	128	128	128	128	127	127	127	127	127	127	127	127	126
6.	L.O. FROM COOLERS	108	108	109	109	109	109	109	108	108	108	108	109	110	110	110	110	110	110	110	108	108	108	108	109	
7.	THRUST BRG TEMP	117	117	118	118	118	118	118	116	117	117	117	118	119	118	118	118	118	118	118	118	118	118	118	118	118
8.	FWD H.P. ROTOR BRG	124	124	124	124	124	123	123	122	124	125	125	124	124	124	124	124	124	124	124	125	124	125	125	124	
9.	AFT H.P. ROTOR BRG	139	138	138	138	138	138	138	136	137	138	138	139	140	139	140	138	138	138	138	138	138	139	139	138	
10.	FWD L.P. ROTOR BRG	132	132	132	134	135	135	135	130	132	133	132	132	132	132	132	135	135	135	135	132	133	132	132	132	
11.	AFT L.P. ROTOR BRG	130	130	130	130	130	130	130	128	129	130	130	130	130	130	130	130	130	130	130	130	132	131	131	131	130
12.	HOT GEAR BRG FWD	154	154	154	153	153	153	153	152	153	154	154	155	155	154	155	155	155	155	155	155	155	155	154	154	154
13.	HOT GEAR BRG AFT	145	145	146	145	145	145	145	144	145	146	146	147	146	146	146	145	145	145	145	145	146	146	146	146	145
14.	MIX COND STE TEMP	113	113	113	113	113	113	113	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
15.	1ST STAGE AIR TEMP	162	162	164	160	160	160	162	158	160	162	162	162	160	162	162	162	162	162	162	160	162	162	162	162	160
16.	D.C. HEATER TEMP	240	240	238	240	240	240	240	240	240	240	240	240	238	240	240	240	240	240	240	238	240	238	238	238	238
17.	SUPRHT TEMP PORT	655	655	655	650	660	660	660	650	670	660	670	655	660	660	660	670	660	660	660	650	655	660	665	655	
18.	SUPRHT TEMP STBD	655	650	650	660	660	660	660	660	680	670	670	660	660	660	660	670	670	670	670	660	660	660	660	660	660
19.	F.O. SETT TEMP P 4	80	85	80	80	80	80	80	80	80	80	85	75	75	75	75	75	80	80	80	80	80	82	82	83	80
20.	F.O. SETT TEMP S 3	85	85	75	75	75	80	85	85	85	85	85	80	80	80	80	80	80	80	80	80	80	82	84	85	80
21.	UPTAKE PORT 2	330	330	338	335	340	340	340	335	325	325	325	325	325	325	325	330	330	325	325	325	325	330	330	332	335
22.	UPTAKE STBD 1	345	345	345	355	360	345	370	360	320	380	330	330	335	335	335	340	350	325	330	330	335	335	335	335	340
23.	F.O. PUMP SUCT TEMP	90	98	80	80	86	90	90	92	93	93	93	85	84	84	86	86	86	86	86	86	86	88	88	88	88
24.	MN FD PMP L.O PORT	35	36	35	35	35	35	37	35	35	35	34	36	34	34	34	35	36	36	36	34	34	34	34	35	34
25.	MN FD PMP L.O STBD	22	24	25	22	28	23	27	25	25	25	24	23	24	23	23	23	25	27	25	23	23	23	24	24	26
26.	L.O. TO GEARS	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
27.	AIR CONTR L.O. PRESS	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
29. L.O. PRES #1	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
28. L.O. PRES #2	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
31. L.O. TO COOLER #1	120	120	120	120	120	120	120	118	120	120	120	120	123	120	120	120	120	120	120	120	120	120	120	120
30. L.O. TO COOLER #2	136	136	136	136	136	136	136	134	135	135	125	136	136	136	136	136	136	136	136	136	136	136	136	136
33. L.O. FROM COOLER #1	110	110	110	110	110	110	110	108	110	110	110	110	111	111	111	110	110	110	110	110	110	110	110	110
32. L.O. FROM COOLER #2	122	122	122	122	122	122	122	121	122	122	122	122	122	122	122	124	124	124	124	124	124	124	124	124
35. L.O. GOV PRES #1	62	62	62	61	61	61	61	61	61	61	61	62	62	62	62	62	62	62	61	61	61	61	61	62
34. L.O. GOV PRES #2	61	61	61	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	61
37. AMPS POS #1	750	750	750	750	1050	700	800	750	650	650	750	750	850	750	700	750	850	800	550	1000	750	750	700	750
36. AMPS POS #2	750	750	750	750	500	800	750	650	650	750	750	850	800	900	900	800	750	1100	1500	750	750	700	750	800
39. AMPS NEG #1	750	750	750	750	1050	700	800	750	650	650	750	750	850	750	700	750	850	800	550	1000	750	750	700	750
38. AMPS NEG #2	750	750	750	750	500	800	750	650	650	750	750	850	800	900	900	750	750	1100	550	750	750	700	750	800
41. HP HIGH SPEED PIN. AFT	146	146	146	145	145	145	145	143	144	146	146	147	146	146	146	145	145	145	145	147	146	147	146	146
42. HP INTER SPEED PIN FWD	136	136	136	135	140	140	140	136	138	136	136	139	139	140	139	140	140	140	140	138	139	138	138	138
43. HP INTER SPEED PIN AFT	136	137	138	136	140	140	140	137	138	136	136	138	139	138	140	140	140	140	140	138	139	138	137	136
44. L.P. THRUST BEARING	132	132	132	134	134	134	134	130	132	132	132	134	134	134	134	134	134	134	134	134	134	133	132	132
45. H.P. THRUST BEARING	146	146	146	145	145	145	145	145	145	145	145	147	147	146	146	148	148	148	148	147	147	147	147	145
46. LP HIGH SPEED PIN. FWD	134	134	135	135	135	135	135	133	134	135	135	135	135	135	135	135	135	135	135	135	136	136	136	134
47. LP HIGH SPEED PIN. AFT	126	126	127	128	128	128	128	127	128	128	128	127	127	127	127	128	128	128	128	128	128	127	127	127
48. LP INTER SPEED PIN FWD	150	150	150	150	150	150	150	148	149	150	149	150	150	150	150	150	150	150	150	150	150	150	150	150
49. LP INTER SPEED PIN. AFT	130	130	130	130	130	130	130	128	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
50. MAIN GEAR ROTOR FWD	114	114	114	115	115	115	115	115	115	115	115	114	115	114	114	114	115	115	115	115	115	115	115	114
51. MAIN GEAR ROTOR AFT	110	110	110	110	110	110	110	110	110	110	110	109	110	110	110	110	110	110	110	110	110	110	110	110
52. LP BLEED	9	9	9	8	7	8	8	9	10	10	10	9	9	9	9	8	7	7	7	10	12	10	9	9

✓

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
1.	L.P. EXHAUST TEMP	112	112	110	114	114	114	114	112	112	112	112	110	110	112	112	114	114	114	114	114	114	114	114	112
2.	MN COND STE TEMP	108	108	108	108	108	105	105	105	106	106	105	106	106	106	106	108	108	110	110	109	109	109	109	108
3.	MN INJ TEMP	82	82	82	82	82	79	79	78	79	79	79	78	80	80	80	83	83	83	83	82	82	82	82	82
4.	MN OVBD TEMP	92	92	92	92	92	88	88	88	88	88	88	88	90	90	90	92	92	92	92	92	92	92	92	92
5.	L.O. TO COOLERS	126	126	126	126	126	126	126	126	126	126	126	128	128	128	128	128	128	128	128	128	128	126	126	126
6.	L.O. FROM COOLERS	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
7.	THRUST BRG TEMP	115	115	115	115	115	115	115	115	115	115	115	115	115	115	115	116	116	116	116	116	116	116	116	116
8.	FWD H.P. ROTOR BRG	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122
9.	AFT H.P. ROTOR BRG	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132
10.	FWD L.P. ROTOR BRG	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132
11.	AFT L.P. ROTOR BRG	125	125	125	125	125	125	125	125	126	126	125	125	125	125	125	126	126	126	126	125	125	125	125	125
12.	HOT GEAR BRG FWD	148	148	148	148	148	148	148	148	148	148	148	148	150	150	150	148	148	148	148	148	148	148	148	148
13.	HOT GEAR BRG AFT	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142
14.	AUX COND STE TEMP	116	116	116	116	116	116	116	112	112	112	114	110	110	110	110	122	122	118	118	118	118	116	116	116
15.	1ST STAGE AIR TEMP	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	175	175	170	170	170	170	170
16.	D.C. HEATER TEMP	238	238	238	238	238	236	236	236	236	238	238	238	238	238	238	238	238	238	238	236	236	238	238	238
17.	SUPRHT TEMP PORT	725	725	720	735	735	740	730	730	730	725	720	725	725	725	725	735	735	725	725	730	730	725	720	725
18.	SUPRHT TEMP STBD	725	725	720	735	735	740	730	730	730	725	720	725	725	725	725	735	735	725	725	730	730	725	720	725
19.	F.O. SETT TEMP P</																								

[illegible]

At

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
1.	L.P. EXHAUST TEMP	108	108	108	110	110	110	110	108	108	110	110	108	108	108	110	110	110	110	108	108	108	108	108	108
2.	MN COND STE TEMP	106	106	106	106	106	106	106	106	106	107	108	106	106	106	106	105	105	105	105	106	106	106	106	106
3.	MN INJ TEMP	78	78	78	81	81	80	80	80	80	80	82	77	77	77	77	78	78	78	78	78	78	78	78	78
4.	MN OVBD TEMP	88	88	88	90	90	90	90	88	88	90	90	86	86	86	86	86	86	86	86	86	88	88	88	88
5.	L.O. TO COOLERS	128	128	128	126	126	126	126	126	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128
6.	L.O. FROM COOLERS	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
7.	THRUST BRG TEMP	115	115	115	115	115	115	115	115	115	115	116	115	115	115	115	115	115	115	115	115	115	115	115	115
8.	FWD H.P. ROTOR BRG	122	122	122	122	122	122	122	122	122	122	122	120	120	120	120	125	125	122	122	122	122	122	122	122
9.	AFT H.P. ROTOR BRG	134	134	134	130	130	130	130	132	132	132	132	130	130	130	130	130	130	130	130	132	132	132	134	134
10.	FWD L.P. ROTOR BRG	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	134	132
11.	AFT L.P. ROTOR BRG	125	125	125	127	127	127	127	126	126	126	126	125	125	125	125	125	125	125	125	125	125	125	126	125
12.	HOT GEAR BRG FWD	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148
13.	HOT GEAR BRG AFT	142	142	142	142	142	142	142	142	142	142	142	140	140	140	140	142	142	142	142	142	142	142	142	142
14.	AUX COND STE TEMP	114	114	114	114	114	114	114	114	116	116	116	110	110	110	110	112	112	112	112	112	114	112	114	114
15.	1ST STAGE AIR TEMP	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170
16.	D.C. HEATER TEMP	238	238	238	240	240	238	238	236	236	236	236	238	238	238	238	238	238	236	236	236	238	238	236	238
17.	SUPRHT TEMP PORT	720	720	720	720	720	725	725	725	730	725	725	730	730	720	720	715	715	725	725	725	730	725	725	720
18.	SUPRHT TEMP STBD	720	720	720	720	720	725	725	725	730	725	725	730	730	720	720	715	715	725	725	725	730	725	725	720
19.	F.O. SETT TEMP P	305	302	302	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	305	310	305	305
20.	F.O. SETT TEMP S	295	290	290	292	292	295	295	290	298	300	300	302	300	300	300	295	295	290	290	290	290	290	290	290
21.	UPTAKE PORT	305	305	300	310	310	310	310	310	300	305	300	300	300	300	300	300	300	300	300	300	305	310	305	305
22.	UPTAKE STBD	295	295	290	295	295	295	295	295	290	295	295	295	295	300	300	295	295	285	285	290	290	290	290	290
23.	F.O. PUMP SUCT TEMP	86	86	86	90	90	92	92	92	96	88	88	106	104	100	100	96	96	94	94	94	96	96	90	86
24.	MN FD PMP L.O PORT	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32	32
25.	MN FD PMP L.O STBD	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28
26.	L.O. TO GEARS	114	114	114	112	112	112	112	112	112	112	114	112	112	112	112	112	112	112	112	112	112	114	114	114
27.	AIR CONTR L.O. PRESS	28	28	28	27	27	27	27	28	28	28	28	28	28	28	28	28	28	28	28	27	27	27	27	27

[illegible]

	TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	
1.	L.P. EXHAUST TEMP	104	106	106	108	108	110	110	108	108	108	106	103	120	108	106	100	100	100	104	104	104	104	104	104	104
2.	MN COND STE TEMP	102	102	102	107	107	106	106	106	106	104	104	82	86	86	90	90	90	90	102	102	102	102	102	104	104
3.	MN INJ TEMP	76	76	76	77	77	80	80	80	80	78	78	74	74	74	74	74	74	74	75	75	74	74	76	76	76
4.	MN OVBD TEMP	86	86	86	90	90	92	92	92	90	86	86	84	84	84	84	78	78	78	84	84	84	84	86	86	86
5.	L.O. TO COOLERS	128	128	128	128	128	128	128	128	128	128	114	115	126	126	118	118	118	126	128	128	128	128	128	128	128
6.	L.O. FROM COOLERS	110	110	110	110	110	110	110	110	110	110	110	110	112	112	108	108	108	110	110	110	110	110	110	110	110
7.	THRUST BRG TEMP	115	115	115	115	115	115	115	115	115	115	115	110	110	112	112	108	108	108	112	115	115	115	115	115	115
8.	FWD H.P. ROTOR BRG	120	120	120	122	122	122	122	122	122	120	120	110	115	120	120	115	115	115	120	120	120	120	120	120	120
9.	AFT H.P. ROTOR BRG	130	130	130	130	130	130	130	130	130	130	130	118	122	128	128	122	122	122	132	132	132	132	132	132	130
10.	FWD L.P. ROTOR BRG	120	130	130	135	135	132	130	132	132	132	132	110	115	115	115	120	120	120	135	135	135	135	135	135	132
11.	AFT L.P. ROTOR BRG	125	125	125	130	130	127	125	126	126	126	126	110	115	120	120	120	120	120	125	125	125	125	125	125	125
12.	HOT GEAR BRG FWD	148	148	148	148	148	148	147	148	148	148	148	120	130	138	138	130	130	130	148	148	148	148	148	148	148
13.	HOT GEAR BRG AFT	140	140	140	142	142	140	140	140	140	140	140	120	128	132	132	126	126	126	140	140	140	140	140	140	140
14.	AUX COND STE TEMP	104	104	104	112	112	110	112	116	114	114	114	88	88	88	88	90	90	90	92	94	94	94	94	110	106
15.	1ST STAGE AIR TEMP	170	170	170	170	170	170	170	170	170	170	170	98	140	145	145	95	95	95	170	170	170	170	170	170	170
16.	D.C. HEATER TEMP	238	238	235	238	238	238	235	236	236	236	236	238	238	238	238	236	236	236	236	236	236	236	236	236	238
17.	SUPRHT TEMP PORT	720	720	720	725	725	710	710	715	735	720	725	600	700	645	645	635	635	635	730	725	725	730	725	720	720
18.	SUPRHT TEMP STBD	720	720	720	725	725	710	710	715	735	720	725	600	700	645	645	635	635	635	730	725	725	730	725	720	720
19.	F.O. SETT TEMP P	100	100	100	100	100	102	102	102	104	106	110	100	100	100	100	98	98	98	98	98	98	98	100	100	95
20.	F.O. SETT TEMP S	95	95	95	90	90	90	90	90	90	96	100	95	95	95	95	95	95	95	95	95	95	90	90	95	95
21.	UPTAKE PORT	300	300	300	310	310	310	310	315	300	300	300	295	285	290	290	275	275	275	300	300	300	300	300	300	300
22.	UPTAKE STBD	295	295	295	295	295	295	295	300	290	290	295	260	275	275	280	265	265	265	285	290	290	295	295	295	295
23.	F.O. PUMP SUCT TEMP	95	95	95	94	94	86	86	86	86	94	102	33	33	33	33	78	78	78	100	100	94	90	94	90	
24.	MN FD PMP L.O PORT	32	32	32	32	32	32	32	32	32	32	32	28	28	28	28	32	32	32	33	33	33	32	32	32	32
25.	MN FD PMP L.O STBD	28	28	28	28	28	28	28	28	28	28	28	100	100	100	100	27	27	27	30	30	28	28	28	28	28
26.	L.O. TO GEARS	112	112	112	112	112	112	112	112	114	114	114	110	110	114	114	110	110	110	114	114	112	112	112	112	112
27.	AIR CONTR L.O. PRESS	28	28	28	28	28	27	27	27	27	27	27	28	28	28	28	28	28	28	28	28	28	28	28	28	28

29. L.O. PRES #13

28. L.O. PRES #24

31. L.O. TO COOLER #13

32. L.O. TO COOLER #24

33. L.O. FROM COOLER #13

32. L.O. FROM COOLER #24

35. L.O. GOV PRES #13

34. L.O. GOV PRES #24

37. AMPS POS #13

36. AMPS POS #24

39. AMPS NEG #13

38. AMPS NEG #24

41. HP HIGH SPEED PIN. AFT

42. HP INTER SPEED PIN FWD

43. HP INTER SPEED PIN AFT

44. LP THRUST BEARING

45. LP THRUST BEARING

46. LP HIGH SPEED PIN FWD

47. LP HIGH SPEED PIN AFT

48. LP INTER SPEED PIN FWD

49. LP INTER SPEED PIN AFT

50. MAIN GEAR ROTOR FWD

51. MAIN GEAR ROTOR AFT

52. LP BLEAD

9	9	9	8	8	8	8	9	9	9	9	9	9	9	9	8	8	8	9	9	9	9	9	9
10	10	10	10	10	9	9	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
130	130	130	134	134	134	134	134	134	134	134	134	134	134	134	130	130	130	130	130	130	130	130	130
136	136	136	144	144	144	145	145	142	142	142	142	142	142	135	135	135	135	138	138	138	136	136	136
110	110	110	114	114	114	114	114	114	114	112	112	108	108	108	108	110	110	110	110	110	110	110	110
118	118	118	122	122	124	124	126	126	126	124	124	116	116	116	116	118	118	118	118	118	118	118	118
64	64	64	63	63	63	63	64	64	64	64	64	64	64	64	64	64	64	64	64	64	64	64	64
44	44	44	43	43	43	43	42	42	42	42	42	45	45	45	45	45	45	44	44	44	44	44	44
1400	1400	1350	1425	1425	1500	1500	1500	1500	1500	1500	1500	850	850	850	850	750	750	750	750	750	750	750	750
1250	1250	1250	1300	1300	1300	1425	1450	1500	1500	1500	1500	750	750	750	750	750	750	750	750	750	750	750	750
1400	1400	1300	1425	1425	1500	1500	1600	1500	1500	1500	1500	850	850	900	850	750	750	850	850	850	1350	1300	1300
1250	1250	1250	1300	1300	1300	1450	1500	1500	1500	1500	1500	750	750	750	750	750	750	750	750	750	750	750	750
140	140	140	142	142	140	140	140	140	140	140	140	135	135	135	135	126	126	140	140	140	140	140	140
148	148	148	146	146	146	146	148	148	146	146	146	120	136	140	140	130	130	148	148	148	148	148	148
135	135	135	137	137	137	137	135	135	135	135	135	115	128	130	130	125	125	132	135	135	135	135	135
132	132	135	135	135	135	135	132	132	132	132	132	110	120	135	135	115	115	135	132	132	132	132	132
140	140	140	144	144	144	144	144	144	144	144	144	120	130	130	130	124	124	142	142	142	142	142	142
128	128	130	128	128	128	128	128	128	128	128	128	115	120	125	125	114	114	128	128	128	128	128	128
126	126	126	122	122	127	127	123	125	125	125	125	110	120	126	126	120	120	127	125	125	125	125	125
148	148	148	148	148	147	147	148	148	148	148	148	115	135	138	138	120	120	148	148	148	148	148	148
140	140	140	140	140	140	140	140	140	140	140	140	138	106	130	132	125	125	140	140	140	140	140	140
110	110	110	110	110	112	110	112	112	112	112	112	105	106	108	108	106	106	110	110	110	110	110	110
108	108	108	107	107	110	110	110	110	110	110	110	105	106	106	106	106	106	107	108	108	108	108	108
12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"
			144	144	144	144										126	126	142					

TIME	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
1. L.P. EXHAUST TEMP	103	105	105	105	105	105	108	106	106	106	106	106	134	107	95	95	95	95	100	102	103	104	105	105
2. MN COND STE TEMP	96	102	101	100	102	102	102	102	102	102	102	102	78	81	81	88	88	82	94	97	97	98	99	98
3. MN INJ TEMP	76	76	76	76	77	77	77	77	77	77	77	77	73	73	73	73	73	73	73	73	73	73	73	76
4. MN OVBD TEMP	86	86	86	84	90	90	90	89	89	89	89	89	78	76	76	78	78	78	84	88	98	98	98	88
5. L.O. TO COOLERS	125	127	127	127	127	127	127	126	126	126	126	114	116	116	116	114	114	118	120	126	126	126	126	126
6. L.O. FROM COOLERS	108	110	110	108	108	108	108	108	108	108	108	108	108	108	107	109	109	109	106	108	108	108	108	109
7. THRUST BRG TEMP	115	115	115	118	118	118	118	117	117	117	117	114	114	115	111	112	115	115	115	117	118	117	117	118
8. FWD H.P. ROTOR BRG	122	124	124	123	123	123	123	125	125	124	124	115	117	116	115	118	120	118	123	125	125	122	123	123
9. AFT H.P. ROTOR BRG	135	139	136	138	138	138	138	136	136	138	137	120	124	124	124	125	123	125	135	136	137	136	136	137
10. FWD L.P. ROTOR BRG	129	134	132	133	133	133	135	132	132	132	132	120	122	122	120	125	123	125	130	132	133	132	132	130
11. AFT L.P. ROTOR BRG	128	130	130	130	130	130	130	128	128	129	129	118	120	120	120	122	120	122	125	130	131	130	131	130
12. HOT GEAR BRG FWD	146	155	154	153	153	150	153	150	150	152	152	130	124	125	122	125	123	125	145	145	148	148	148	149
13. HOT GEAR BRG AFT	142	147	145	145	145	145	145	145	145	146	146	120	120	124	125	125	125	125	135	140	145	145	145	145
14. AUX COND STE TEMP	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108
15. 1ST STAGE AIR TEMP	159	169	158	162	162	162	162	158	160	161	160	90	90	94	92	92	94	94	100	156	158	159	160	160
16. D.C. HEATER TEMP	240	240	240	240	240	240	240	240	240	240	240	240	240	240	238	240	238	240	238	239	240	239	240	240
17. SUPRHT TEMP PORT	680	685	685	680	680	680	685	680																

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
29. L.O. PRES #1	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
28. L.O. PRES #2	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
31. L.O. TO COOLER #1	120	118	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	118	118	118	119	119	119	120
30. L.O. TO COOLER #2	131	131	131	132	134	134	134	134	134	134	134	134	134	134	134	134	132	132	132	132	133	133	133	134
33. L.O. FROM COOLER #1	109	109	109	108	110	110	110	110	109	109	109	109	108	108	108	109	108	110	108	108	109	109	109	110
32. L.O. FROM COOLER #2	120	118	120	120	122	122	122	122	122	120	120	122	116	116	116	118	120	120	118	118	118	119	119	120
35. L.O. GOV PRES #1	62	62	62	61	61	61	61	62	62	62	63	62	62	62	62	61	61	61	61	62	62	62	62	62
34. L.O. GOV PRES #2	60	62	62	60	60	62	62	61	61	62	62	60	60	60	60	60	60	60	60	60	60	61	61	61
37. AMPS POS #1	500	700	650	1000	550	550	550	600	700	700	700	900	1050	1050	1250	1150	1150	1400	1250	1250	1250	1250	1250	1250
36. AMPS POS #2	1250	1300	750	650	1000	950	940	700	600	800	700	750	1050	1050	1300	1350	1400	1200	1200	1400	1400	1500	1250	1300
39. AMPS NEG #1	500	700	650	1000	350	550	550	650	700	700	900	1050	1050	1250	1150	1150	1400	1250	1250	1250	1250	1250	1250	1250
38. AMPS NEG #2	1300	1300	750	500	1000	1000	900	700	600	800	700	700	1100	1100	1500	1450	1250	1400	1500	1400	1400	1250	1250	1300
41. HP HIGH SPEED PIN. AFT	140	147	145	145	145	145	145	145	145	145	145	145	120	125	125	125	125	125	125	135	140	142	143	145
42. HP INTER SPEED PIN FWD	130	140	139	138	135	132	132	133	133	137	137	118	120	120	120	125	123	125	130	135	135	135	135	135
43. HP INTER SPEED PIN AFT	130	140	140	138	135	135	138	138	138	138	138	100	120	126	126	125	123	125	130	140	140	142	142	140
45. L.P. THRUST BEARING	120	132	132	132	132	132	134	132	132	132	132	110	110	112	112	114	114	116	122	122	122	122	122	132
44. L.P. THRUST BEARING	140	144	140	145	145	145	145	145	145	145	145	116	125	124	122	125	120	125	140	142	145	145	145	145
46. LP HIGH SPEED PIN. FWD	128	135	135	135	135	135	135	137	137	135	136	114	120	120	120	122	120	122	130	132	132	132	132	135
47. LP HIGH SPEED PIN. AFT	125	128	127	128	128	128	128	127	127	128	128	118	120	120	120	122	120	122	123	125	126	128	127	128
48. LP INTER SPEED PIN FWD	145	148	150	150	150	150	150	148	148	149	149	125	125	125	125	125	125	125	135	135	135	135	135	135
49. LP INTER SPEED PIN. AFT	130	132	132	135	135	135	135	132	132	133	133	120	120	129	125	125	125	125	135	135	135	135	135	135
50. MAIN GEAR ROTOR FWD	114	115	115	115	115	115	115	115	115	115	115	110	110	111	111	112	112	112	115	115	115	115	115	115
51. MAIN GEAR ROTOR AFT	110	110	110	110	110	110	110	110	110	110	110	106	107	105	107	102	108	108	105	110	110	110	110	110
52. LP BLEND	9	9	9	8	8	8	8	10	10	10	10	24	24	24	26	25	24	25	25	10	10	10	10	10

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY _____

U. S. S.

GEN. JOHN POPE

PLANT NO.

AT ANCHOR _____

TIME: ZONE DESCRIPTION

SET CLOCKS

**AHEAD
-OR
\$ BACK**

20 min

MINUTES AT 2300-0100-0500

DATE 1-26

19 67

[illegible]

1-27-67

#-1

1-26-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	09551600		
0000			
0100	09569900	1300	
0200	09571200	1300	
0300	09572900	1700	1 HR 20 MIN
0400	09574200	1300	
0500	09575500		1300
0600	09577000		1500 = 1 HR 20 MIN
0700	09578200		1200
0800	09579400		1200
0900	09580600	1200	
1000	09581900	1300	
1100	09583300	1400	
1200	09585200	1200	
1300	09587200	1400	
1400	09589500	1300	
1500	09591800	1300	
1600	09594100	1300	
1700	09596400	1300	
1800	09598700	1200	
1900	09601000	1300	
2000	09603300	1100	
2100	09605600	1300	
2200	09607900	1300	
2300	09610200	1700	
2400	09612500	1000	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	341		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	451900		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400

1 & 2 EVAP DIST TO
3 CENTER POTABLE TANK
ADDE 8 OZ CHLORINE PER 1000 GALS

1 HR 20 MIN

SIGNED

Mc Roy Hill

0400-0800

20400 #1 Evap. Dist. to #1 stld. tank
Filled #1 Hoarvop Tank, 3/4 cor Hoarvop.
20300 shifted Dist. to #3

#1 part-23' - Test 2 drops
#1 stld 14' - Test 30 drops
#2 part-22' - Test 2 drops
#2 stld-12' - Test 30 drops

SIGNED

R. Sheppard

0800-1200

- 1 & 2 EVAP. DIST.
TO # - 3 CENTER ...
(Added 8 OZ Chlorine
per 1000 gals... Dist...
F.W. Dist. 25 Hrs, 31,400 GALS

SIGNED

E. J. Magallanes

Stocked in CDS

REMARKS

1200-1600

1 & 2 EVAP DIST TO
3 CENTER POTABLE TANK
ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

Mc Roy Hill

1600-2000

#1 Evap. Dist. to #3 &
Added 8 OZ Chlorine to each 1000 gals water dist.

SIGNED

R. Sheppard

2000-2400

- 1 & 2 EVAP. DIST.
TO # - 3 CENTER LINE
(Added 8 OZ Chlorine
to each 1000 gals water dist)

SIGNED

E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY _____

U. S. S. GEN. JOHN POPE

PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ~~OR~~ ~~BEHIND~~ 20 min

MINUTES AT 2300-0100-0500

DATE 7-16

1967

	1-27-67										HOUR ENDING														1-26-67									
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400										
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	6	6	6	6	6	6	6	6	7	7	7	7	7	7	7	7	7										
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	2	2	2	2	1	1	1	1	1	1	1	1	1	1	2	2	2										
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	1"	1"	1"	1"	1	1	1	1	1	1	1	1	1"	1"	1"	1"	1	1	1	1	1										
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	240	234	240	246	240	240	235	235	235	235	240	240	240	240	240	240	240	240	230	230	230	230	235										
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	200	200	198	200	200	200	200	200	200	200	200	202	200	198	198	200	200	200	200	200	200	200	200	200										
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10"	10"	10"	10"	10	10	10	10	9	9	9	9	10"	10"	10"	10"	10	10	10	10	10										
2D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
2D EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	15	15	15	15	16"	16"	16"	16"	15	15	15	15	15										
3D EFFECT COIL DRAIN, TEMPERATURE, °F	162	164	164	158	158	158	158	158	158	158	158	160	162	162	164	152	152	152	152	160	160	160	160	160										
3D EFFECT SHELL PRESSURE, "HG	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	144	144	142	142	142	142	142	142	140	140	140	140	134	134	134	134	136	136	138	138	138										
CONDENSATE FROM COOLER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	134	134	132	132	132	132	132	132	130	130	128	130	126	126	124	124	124	124	124	124	126										
STEAM TO AIR EJECTOR, PRESSURE, #G	102	102	102	94	96	94	94	94	94	94	94	100	101	100	100	92	92	92	92	100	100	102	102	100										
AIR EJECTOR DRAINS, TEMPERATURE, °F																																		
CIRC. WATER INJECTION, TEMPERATURE, °F	76	76	76	78	78	78	79	76	76	76	76	73	73	73	73	73	73	73	73	73	76	76	76	76										
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	76	76	76	78	78	78	79	76	76	76	76	73	73	73	73	73	73	73	73	73	76	76	76	76										
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	115	115	115	120	120	120	120	116	116	116	116	115	115	115	115	115	115	115	115	115	115	115	115	115										
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	138	138	138	142	142	140	142	138	138	138	138	138	138	138	138	138	140	140	140	138	138	138	138	138										
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	162	162	164	164	164	164	158	158	158	158	158	158	158	158	150	150	156	166	158	158	158	158	160										
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	104	104	104	104	102	102	102	102	104	104	104	104	104	104	104	104	104	104	104	104	102										
CIRC. PUMP SUCTION PRESSURE, #G	6	6	6	5	5	5	5	5	5	5	5	6	6	6	6	5	5	5	5	5	5	5	5	6										
CIRC. PUMP DISCHARGE PRESSURE, #G	25	25	25	23	23	23	23	23	23	23	23	25	25	25	25	23	23	23	23	24	24	24	24	24										
BRINE PUMP SUCTION PRESSURE, #G	20	22	22	24"	24"	24"	24"	24	24	24	24	20	20	20	20	25"	25"	25"	25"	25	25	25	25	25										
BRINE PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	34	34	34	34	20	20	20	20	25	25	25	25	25										
FEED PUMP SUCTION PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
FEED PUMP DISCHARGE PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0										
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	55	55	56	55	55	55	55	50	50	50	50	55	55	55	58	52	52	53	54	52	52	52	52	52										
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10										
FEED DENSITY, 32NDS																																		
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5										
AIR EJECTOR DRAINS, SALINITY—E. P. M.	3.0	3.0	3.0	3.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	3.0	3.0	3.0	3.0	3.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	3.0										
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3										
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0										

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	04692000		
0100	04706500	1000	
0200	04707500	1000	
0300	04708800	1300	1 HR 20 MIN
0400	04709800	1000	
0500	04710800		1000
0600	04712300		1500 = 1 HR - 20 min
0700	04713400		1100
0800	04714400		1000
0900	04715500	1100	
1000	04716700	1200	
1100	04718000	1300	
1200	04692900	900	
1300	04694000	1100	
1400	04695000	1000	
1500	04696000	1000	
1600	04697000	1000	
1700	04698000	1000	
1800	04699000	1000	
1900	04700100	1100	
2000	04701100	1000	
2100	04702100	1000	
2200	04703100	1000	
2300	04704500	1400	
2400	04705500	1000	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	341		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	392600		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
	(Engineer Officer, U. S. N.)		

1-27-67 #2

0000-0400
#1 & 2 EVAP DIST TO
#3 CENTER POTABLE TANK

ADDED 80Z CHLORINE PER 1000 GALS

1 HR - 20 min

SIGNED M R of Hill

0400-0800
00400 #2 Evap. Dist. to #2 stbd. Feed.
Filled #2 No. 2 Evap. Tank, 3/4 can No. 2 Evap.
00700 shifted Dist. to #3

SIGNED R. Shippard

0800-1200
#1 & 2 Evap. Dist. to #3
Center Line
Added 80Z Chlorine
Per 1000 gals Dist.
F.W. Dist. 25 Hes. 26,000 GALS

SIGNED E. J. Magallanes

1-26-67

1200-1600
#1 & 2 EVAP DIST TO
#3 CENTER POTABLE TANK

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED M R of Hill

1600-2000
#2 Evap. Dist. to #3

SIGNED R. Shippard

2000-2400
#1 & 2 EVAP. DIST.
TO #3 CENTER LINE
Added 80Z Chlorine
to each 1000 GALS WATER DIST.

SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. JOHN POPE

PLANT NO. 1

AT ANCHOR _____

TIME: ZONE DESCRIPTION

AHEAD OR SET CLOCKS BACK

MINUTES AT

DATE 1-24 1967

	1-25-67												1-25-67											
	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	9	9	9	9	8	8	8	8	8	8	8	9	9	9	9	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	1	0	0	0	0	0	0	0	0	0	0	-0	0	0	0	0	0	0		0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	5	5	3	3"	3"	3"	3"	4	4	4	4	5	5	6	5	5"	5"	5"		5	5	5	5	5
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	235	240	240	240	240	220	220	225	225	230	235	240	240	240	240	240		240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	188	188	185	195	195	195	195	185	185	185	185	174	174	176	174	185	185	185		185	185	185	185	185
1ST EFFECT SHELL PRESSURE, "HG	14	14	12	12"	12"	13"	13"	13	13	13	13	14	14	14	14	14"	14"	14"		14	14	14	14	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	168	168	165	170	170	170	170	165	165	165	165	164	165	168	166	166	166	166		166	166	166	166	168
2D EFFECT SHELL PRESSURE, "HG	14	14	15	14"	14"	15"	15"	15	15	15	15	14	14	14	14	15"	15"	15"		15	15	14	14	14
3D EFFECT COIL DRAIN, TEMPERATURE, °F	158	156	155	160	160	160	160	155	155	155	155	156	158	158	154	156	156	156		156	156	156	156	156
3D EFFECT SHELL PRESSURE, "HG	23	23	22	22"	22"	22"	22"	22	22	22	22	23	23	23	23	23"	23"	23"		23	23	23	23	23
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	138	138	138	138	138	135	135	138	138	136	136	136	136	136	136	136		136	136	136	136	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94		94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	130	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128		128	128	128	128	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92		92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	73	73	73	73	73	73	73	72	72	72	72	71	71	72	72	73	73	73		71	71	73	73	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	73	73	73	73	73	73	73	72	72	72	72	71	71	72	72	73	73	73		71	71	73	73	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	162	160	170	170	172	172	160	160	160	160	162	162	162	162	162	162	160		160	160	160	160	160
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	104	104	104	104	104	104	104	104	104	98	100	100	102	104	104		104	104	104	104	104
CIRC. PUMP SUCTION PRESSURE, #G	4	5	5	5	5	5	5	5	5	5	5	6	6	6	6	5	5	5		5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20		20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	24"	24"	24"	24"	22	22	22	22	22	22	22	22	25"	25"	25"		22	22	22	22	22
BRINE PUMP DISCHARGE PRESSURE, #G	36	33	35	35	30	30	30	34	34	34	34	36	36	36	36	35	34	24		36	36	36	36	35
FEED PUMP SUCTION PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
FEED PUMP DISCHARGE PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		-	-	-	-	-
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	4	4	4	3"	4"	4	4	4	4	4	4	4	4	4	4	4	4	4		4	4	4	4	4
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	55	55	55	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58		58	58	58	58	58
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10		10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5		1.5	1.5	1.5	1.5	1.5
Chemical Test	3.0	3.0	3.0	3.0	3.0	3.0	3.0	2.0	2.0	2.0	2.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0		3.0	3.0	2.0	2.0	3.0
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.3	0.3	0.3	0.3		0.3	0.3	0.3	0.3	0.3
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

1-26-67

#1

1-24-57

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	09519300		
0100	09520200		
0200	09538800	1300	
0300	09540200	1400	
0400	09541500	1300	
0500	09542800	1300	
0600	09544100	1300	
0700	09545400	1300	
0800	09546700	1300	1200
0900	09547900	1300	1300
1000	09549200	1300	1300
1100	09550500		1300
1200	09551600		1100
1300	09521600	1400	
1400	09523000	1400	
1500	09524400	1400	
1600	09525700	1300	
1700	09526900	1200	
1800	09528400	1500	
1900	09529700	1300	
2000	09531100	1400	
2100	09532300	1200	
2200	09533600	1300	
2300	09534900	1300	
2400	09536200	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	317		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	420500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

#1 & 2 EVAP DIST TO
#3 CENTER POTABLE TANK

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

Mc Roy Hill

0400-0800

#1 Evap. Dist. to #3 center line
Drained #1 No. 6000 Tank, cleaned
Tank, clean No. 6000 pump strainer,
filled #1 No. 6000 Tank 3/4 for No. 6000
Add 8 oz chlorine to each 1000 gal water dist.

#1 port - 23' - Test 2 drops
#1 starboard - 12' - Test 2 drops
#12 port 22' - Test 2 drops
#12 starboard - 15' - Test 2 drops

SIGNED

R. Sheppard

0800-1200

- 1 EVAP. DIST. TO
- 1 STBD FEED

F.W. Dist. 24 Hrs) 31,400 GALS PER 1000 GALS DIST.

SIGNED

E. J. Magallanes

Stocked in CDS

1200-1800

#1 & 2 ~~EVAP~~ EVAP DIST TO
#3 PORT & STBD POTABLE TANK

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

Mc Roy Hill

1200-2000

#1 Evap. Dist. to #3 center
Add 8 oz chlorine to each 1000 gal water dist.

SIGNED

R. Sheppard

2000-2400

1 & 2 EVAP. DIST.
TO # - 3 CENTER
(Added 8 OZ CHLORINE
PER 1000 GALS DIST.)

SIGNED

E. J. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY _____

U. S. S.

LOW PRESSURE DISTILLING PLANT
 GEN. JOHN POPE

PLANT NO.

2

**AHEAD
OR
\$ BACK**

TIME: ZONE DESCRIPTION

SET CLOCKS **OR** BACK

MINUTES AT

DATE _____

1-24 . 19 67

AT ANCHOR

	1-26-67																								HOUR ENDING								1-26-67							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400																
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7																
STEAM FROM REG. VALVE, PRESSURE #G	0	0	0	0	0	0	0	2	2	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0																
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	1	0	0	1"	1"	1"	1"	1	1	1	1	0	1	1	1	2"	2"	2"	0	0	1	1	1	1																
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	235	240	240	240	240	230	230	230	230	235	235	240	240	240	240	240	240	240	240	240	240	240																
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	198	198	198	205	205	205	205	205	205	205	205	200	198	198	190	200	200	198	200	200	200	200	198	198																
1ST EFFECT SHELL PRESSURE, *HG	10	10	10	10"	10"	10"	10"	9	9	9	9	10	10	10	10	10"	10"	10"	9	9	9	9	10	10																
2D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
2D EFFECT SHELL PRESSURE, *HG	14	14	14	15"	15"	15"	15"	15	15	15	15	11	11	11	12	14"	14"	14"	14	14	14	14	14	14																
3D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	156	156	156	156	160	160	162	162	160	160	160	160	156	156	156	-	-	-	-	-	-																
3D EFFECT SHELL PRESSURE, *HG	-	-	-	-	-	-	-	-	-	-	-	-	-	-	160	-	-	-	-	-	-	-	-	-																
CONDENSATE TO COOLER, TEMPERATURE, °F	140	142	140	138	138	138	138	138	142	142	142	134	136	136	136	136	136	136	142	142	142	142	142	142																
CONDENSATE FROM COOLER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
BRINE OVERBOARD, TEMPERATURE, °F	130	128	128	128	128	128	128	128	128	128	128	128	128	124	126	126	126	126	126	126	126	126	128	128																
STEAM TO AIR EJECTOR, PRESSURE, #G	90	90	90	94	94	94	94	98	98	98	98	88	90	90	90	90	90	90	90	96	90	90	90	90																
AIR EJECTOR DRAINS, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
CIRC. WATER INJECTION, TEMPERATURE, °F	93	93	93	93	93	93	93	92	92	92	92	91	91	92	92	93	93	93	91	91	93	93	93	93																
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	93	93	93	93	93	93	93	92	92	92	92	91	91	92	92	93	93	93	91	91	93	93	93	93																
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	115	115	115	124	124	122	122	120	112	120	120	118	-	-	-	115	115	115	115	115	115	115	115	115																
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	148	146	146	146	146	144	144	146	146	146	146	146	-	-	-	140	142	142	142	142	142	142	142	142																
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	166	166	166	166	166	166	166	166	166	170	170	168	160	162	160	164	164	164	164	164	164																
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	104	104	104	104	102	102	102	102	100	102	102	102	100	102	102	102	102	102	102	102	102																
CIRC. PUMP SUCTION PRESSURE, #G	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6																
CIRC. PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25																
BRINE PUMP SUCTION PRESSURE, #G	22	22	23	25"	25"	25"	25"	25	25	25	25	23	23	23	23	25"	25"	25"	25	25	25	25	25	26																
BRINE PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	30	30	30	30	30	30	30	30	30																
FEED PUMP SUCTION PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
FEED PUMP DISCHARGE PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-																
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	1	1	1	1	5	5	5	5	0	0	0	0	0	0	0	0	0																
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	54	54	55	54	54	52	52	55	55	55	55	54	54	54	54	54	54	54	54	54	54	54	54	54																
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10																
FEED DENSITY, 32NDS																																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5																
Chemical Test		30	30	30	30	30	30	20	20	20	20																													
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3																
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0																
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0																																							

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	04668600		
0100	04681900	1000	
0200	04683000	1100	
0300	04684000	1000	
0400	04684900	900	
0500	04685900	1000	
0600	04686900	1000	
0700	04687800	900	
0800	04688800	1000	
0900	04689800	1000	
1000	04690900	1100	
1100	04692000	1100	
1200	04693500	900	
1300	04695000	1000	
1400	04696400	900	
1500	04697400	1000	
1600	04698300	900	
1700	04699300	1000	
1800	04700200	900	
1900	04701300	1100	
2000	04702400	900	
2100	04703400	1000	
2200	04704900	700	
2300	04705900	1000	
2400	04706900	1000	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	317		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	369200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
	(Engineer Officer, U. S. N.)		

1-25-67 #2

0000-0400

1 & 2 EVAP DIST TO
3 CENTER POTABLE TANK

ADDED 802 CHLORINE PER 1000 GALS

SIGNED McRoy Hill

0400-0800

2 EVAP DIST TO # 3 CENTER LINE.
Drained # 2 HOGWASP TANK, cleaned
TANK. Cleaned HOGWASP pump & strainer.
Filled # 2 HOGWASP TANK. 3/4 clean HOGWASP

SIGNED R. Shypard

0800-1200

2 EVAP DIST TO
3 CENTER LINE
Added 802 CHLORINE
TO EACH 1000 GALS DIST.
F.W. DIST. 24 Hrs. 23,400 gals

SIGNED E. D. Magallanes

SIGNED E. D. Magallanes

Stocked in CDS

1-25-67

1200-1600

1 & 2 EVAP DIST TO
3 PORT & STBD POTABLE TANK

ADDED 802 CHLORINE PER 1000 GALS

SIGNED McRoy Hill

1600-2000

2 EVAP DIST TO # 3 & 1
Added 802 Chlorine to each 1000 gal. water dist.

SIGNED R. Shypard

2000-2400

1 & 2 EVAP DIST TO
3 CENTER LINE
Added 802 CHLORINE
PER 1000 GALS DIST.

SIGNED E. D. Magallanes

SIGNED E. D. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. JOHN POPE

PLANT NO. 1

AT ANCHOR _____

TIME: ZONE DESCRIPTION

SET CLOCKS AHEAD OR BACK

MINUTES AT

DATE 7-23

1967

	1 - 23 - 67																							
	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	9	9	9	9	8	8	8	8	8	8	9	8	9	9	10	9	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, "HG DR #G	4	4	4	4"	4"	4"	4"	4	4	4	4	4	4	4	4	4"	4"	4"	4"	4	4	4	4	4
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	235	240	235	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	185	185	185	195	195	195	195	190	185	185	185	185	185	185	185	195	195	195	195	185	185	185	185	185
1ST EFFECT SHELL PRESSURE, "HG	15	15	15	17"	17"	17"	17"	15	15	15	15	15	15	15	15	13"	13"	13"	13"	14	14	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	166	166	166	166	158	158	158	158	158	158	158	158	166	166	166	166	156	156	156	156	158
2D EFFECT SHELL PRESSURE, "HG	15	15	15	16"	16"	15"	15"	15	15	15	15	14	14	14	14	15"	16"	16"	16"	15	15	15	15	15
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	152	150	156	156	156	156	156	156	156	156	155	155	156	156	156	156	156	156	146	146	146	146	148
3D EFFECT SHELL PRESSURE, "HG	23	23	23	23"	23"	23"	23"	23	23	23	23	22	22	22	22	23"	23"	23"	23"	23	23	23	23	23
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	134	128	128	128	128	128	128	132	132	134	134	134	134	132	130	130	132	124	134	134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	92	92	92	88	88	88	88	90	90	90	90	91	91	91	91	90	90	92	92	92	92	92	92	92
BRINE OVERBOARD, TEMPERATURE, °F	128	128	130	122	122	120	122	122	122	122	124	132	130	132	132	124	124	125	125	125	125	125	125	128
STEAM TO AIR EJECTOR, PRESSURE, #G	90	90	90	90	90	90	90	90	90	90	90	92	90	90	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	72	72	72	72	72	72	72	71	71	71	71	71	71	71	71	72	72	72	72	72	72	72	72	72
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	72	72	72	72	72	72	72	71	71	71	71	71	71	71	71	72	72	72	72	72	72	72	72	72
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	165	162	170	170	172	170	168	168	168	168	160	168	164	164	170	170	170	170	169	169	169	169	165
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	104	104	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	19	19	19	19	23	23	23	23	21	21	21	21	19	19	19	19	21	19	19	19	19
BRINE PUMP SUCTION PRESSURE, #G	20	20	20	26"	26"	26"	26"	25	25	25	25	20	20	20	20	26"	26"	26"	26"	26	26	26	26	24
BRINE PUMP DISCHARGE PRESSURE, #G	42	42	42	30	30	30	30	33	33	33	33	42	42	42	40	30	30	30	30	37	37	37	37	35
FEED PUMP SUCTION PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED PUMP DISCHARGE PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	2"	2"	2"	2	1	1	1	1	4	4	4	4	2"	2"	2"	3"	2	2	2	2	2
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	58	58	58	58	58	58	58	56	56	56	56	58	58	58	56	58	58	58	58	58	58	58	58	55
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
	30	30	30	30	20	20	20	20	20	20	20	30	30	30	30	30	20	20	20	20	20	20	20	20
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	09487300		
0100	09505000	1300	
0200	09506300	1300	
0300	09507600	1300	
0400	09508900	1300	
0500	09510100	1200	
0600	09511300		1200
0700	09512500		1200
0800	09513600		1100
0900	09514900		1300
1000	09516100		1200
1100	09517300		1200
1200	09488600	1300	
1300	09490100	1600	
1400	09491400	1300	
1500	09492700	1300	
1600	09493900	1200	
1700	09495200	1300	
1800	09496400	1200	1200
1900	09497400		1000
2000	09498500	1100	2400
2100	09499800	1300	
2200	09501200	1400	
2300	09502400	1200	
2400	09503700	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	293		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	390300		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

1-24-67 #1

0000-0400

1 + 2 EVAP DIST TO

3 PORT + STBD POTABLE TANK

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED M E Roy Hill

0400-0800

1 Evap. Dist. to # 3 port + stbd.

Filled # 1 Hg 6-Lvup Tank - 3/4 can NaOCl.

@ 0600 Shifted Dist. to # 1 stbd. Feed.

1 port 23' - Test 2 drops

1 stbd - 22' - Test 2 drops

2 port 22' - Test 2 drops

2 stbd - 21' - Test 2 drops

SIGNED R. Sheppard

0800-1200

1 & 2 EVAP. DIST. TO

3 STBD FRED ----

@ 1030 Shifted Dist. to

3 Port & STBD ----

F. W. DIST. (24 Hrs) ~~30,600~~ 30,200 GALS

SIGNED E. J. Magallanes

1-23-67

1200-1600

1 & 2 EVAP DIST TO

3 PORT + STBD POTABLE TANK

ADDED 6 OZ CHLORINE PER 1000 GALS

SIGNED M E Roy Hill

1600-2000

1 Evap. Dist. to # 3 port + stbd.

@ 1700 Shifted Dist. to # 1 stbd. Feed

@ 1900 Shifted Dist. to # 3 port + stbd

SIGNED R. Sheppard

2000-2400

1 & 2 EVAP. DIST TO

3 Port & STBD ----

(Added 8 OZ chlorine

PER 1000 GALS DIST. TO

SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. JOHN POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS AHEAD OR BACK

MINUTES AT

DATE _____

1-23

- 19.

67

	1-24-67												1-23-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7	6	6	6	6	7	7	7	7	7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	1	1	1	2"	2"	2"	2"	4"	4"	4"	2"	5	5	5	5	2"	2"	2"	2"	1	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	235	235	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	200	198	200	200	200	205	200	200	200	200	200	198	200	200	200	200	200	200	200	200	200	200	200	200
1ST EFFECT SHELL PRESSURE, *HG	11	11	11	10"	10"	10"	10"	11	11	11	11	11	11	11	11	16"	10"	10"	10"	11	10	10	10	11
2D EFFECT COIL DRAIN, TEMPERATURE, °F	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2D EFFECT SHELL PRESSURE, *HG	19	19	19	19"	19"	18"	18"	19	19	19	19	19	19	19	19	19	19"	19"	19"	19"	19	19	19	19
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	150	154	154	154	154	148	148	148	148	148	148	148	148	152	154	154	154	146	146	146	146	148
3D EFFECT SHELL PRESSURE, *HG	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	138	138	136	136	136	136	136	136	132	132	132	132	138	136	136	136	138	136	136	136	136
CONDENSATE FROM COOLER, TEMPERATURE, °F	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	128	128	126	126	126	126	126	126	130	130	132	130	128	126	126	126	126	126	126	126	128
STEAM TO AIR EJECTOR, PRESSURE, #G	90	90	90	92	92	92	92	92	92	92	92	90	90	90	90	90	90	92	92	90	90	90	90	90
AIR EJECTOR DRAINS, TEMPERATURE, °F	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	72	72	72	72	72	72	72	71	71	71	71	71	71	71	71	72	72	72	72	72	72	72	72	72
CIRC. WATER INJECTION, TEMPERATURE, °F	72	72	72	72	72	72	72	71	71	71	71	71	71	71	71	72	72	72	72	72	72	72	72	72
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	72	72	72	72	72	72	72	71	71	71	71	71	71	71	71	72	72	72	72	72	72	72	72	72
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	115	115	115	116	116	115	115	115	115	115	115	115	115	115	115	116	116	116	116	115	115	115	115	115
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	154	158	158	144	144	142	144	144	144	144	144	154	154	154	156	140	140	140	140	154	154	154	154	156
FEED TO 1ST EFFECT, TEMPERATURE, °F	155	154	154	168	168	168	168	168	168	168	168	168	166	168	168	164	164	166	166	142	132	132	132	155
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	104	104	102	102	102	102	102	102	102	100	100	100	100	100	100	100	100	100	102
	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP SUCTION PRESSURE, #G	23	23	23	24	24	24	24	24	24	24	24	23	23	23	23	24	24	24	24	24	24	24	24	24
CIRC. PUMP DISCHARGE PRESSURE, #G	16	15	15	25"	25"	25"	24"	20	15	15	15	15	15	15	15	25"	25"	25"	25"	25	25	25	25	20
BRINE PUMP SUCTION PRESSURE, #G	35	35	35	30	30	30	30	35	35	35	35	35	35	35	35	30	30	30	30	35	35	35	35	35
BRINE PUMP DISCHARGE PRESSURE, #G	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
FEED PUMP SUCTION PRESSURE, #G	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
FEED PUMP DISCHARGE PRESSURE, #G	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	54	54	54	54	54	54	54	54	54	54	54	52	52	52	52	52	52	54	54	54	54	54	54	54
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
FEED DENSITY, 32NDS	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.3	1.3	1.2	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
	30	30	30	30	20	20	20	20	20	20	20	30	30	30	30	30	20	20	20	20	20	20	20	30
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

1-24-67

#2

1-23-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	04638000		
0000			
0100	04655000	1300	
0200	04656200	1200	
0300	04657400	1200	
0400	04658700	1300	
0500	04659900	1200	
0600	04661000		1100
0700	04662200		1200
0800	04663300		1100
0900	04664500		1200
1000	04665500		1000
1100	04666800	1300	
1200	04639100	1100	
1300	04640300	1200	
1400	04641600	1300	
1500	04642700	1100	
1600	04643800	1100	
1700	04645100	1300	
1800	04646300		1200
1900	04647500		1200
2000	04648700	1200	
2100	04649900	1200	
2200	04651200	1300	
2300	04652400	1100	
2400	04653700	1300	
		20950	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	293		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	340600		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 2076 (REV. 11-50) BACK

REMARKS

0000-0600
#1 & 2 EVAP DIST TO
#3 PORT & STBD POTABLE TANKS
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M. C. Roy Hill

0600-0800
#2 Evap. Dist. to #3 port & stbd.
Filled #2 No. 6 evap. tank. 3/4 can No. 6 evap.
@ 0500 shifted Dist. to #2 stbd. feed.

SIGNED R. Sheppard

0800-1200
#1 & 2 EVAP. DIST TO
#2 STBD FEED.....
@ 1030 Shifted DIST TO
#3 PORT & STBD.....
F.W. DIST. (24 Hrs) 28,600 gals
SIGNED E. J. Mayallones

Stocked in CDS

1200-1800
#1 & 2 EVAP DIST TO
#3 PORT & STBD POTABLE TANKS
ADDED 6 OZ CHLORINE PER 1000 GALS
SIGNED M. C. Roy Hill

1800-2000
#2 Evap. Dist. to #3 port & stbd.
@ 1700 Shifted Dist. to #2 stbd. feed.
@ 1900 shifted Dist. to #3 port & stbd.

SIGNED R. Sheppard

2000-2400
#1 & 2 EVAP. DIST TO
#3 PORT & STBD.....
(Added 8 OZ Chlorine
PER 1000 GALS DIST...
SIGNED E. J. Mayallones

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS OR BACK

MINUTES AT _

DATE _____

19

[illegible]

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	09455600		
0000			
0100	09474300	1400	
0200	09475600	1300	
0300	09477600	1700	1 HR 20 MIN
0400	09478600	1000	
0500	09479800	1200	
0600	09481400		1600 = 1 HR. 20 min.
0700	09482600		1200
0800	09483600		1000
0900	09484800		1200
1000	09486000		1200
1100	09487300	1300	
1200	09456900	1300	
1300	09458300	1400	
1400	09459700	1400	
1500	09461400	1400 ?	
1600	09462300	900	
1700	09463600	1300	
1800	09464800	1200	
1900	09466100	1300	
2000	09467300	1200	
2100	09468600	1300	
2200	09469900	1300	
2300	09471700	1800	1 HR 20 MIN
2400	09472900	12000	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	NO. 1	EFFECT	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	268		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	358900		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

1-23-67 #1
 0000-0400
 #1 & 2 EVAP DIST TO
 #3 PORT + STBD POTABLE TANK
 ADDED 6 OZ CHLORINE PER 1000 GALS
 1 HR. 20 min.
 SIGNED M. Roy Hill

0400-0800
 #1 Evap. dist. to #3 port + stbd.
 Filled #1 Hagecap Tank. 3/4 can Hagecap.
 @ 0500 Shifted dist to #1 stbd. feed.
 @ 0700 Shifted dist to #2 stbd feed.
 #1 port- 23'- Test 2 Drops
 #1 stbd- 22'- Test 2 Drops
 #2 port- 22'- Test 2 Drops
 #2 stbd- 18'- Test 2 Drops
 SIGNED R. Shappard

0800-1200
 #1 & 2 EVAP. DIST TO #
 2 STBD FEED.....
 @ 10:00 Shifted Dist
 to #3 Port & Stbd....
 (Added 8 OZ Chlorine
 per 1000 gals dist.
 F.W. DIST. 25 Hrs. 31,400 GALS
 SIGNED E. J. Magallanes

1-22-67
 1200-1600
 #1 & 2 EVAP DIST TO
 #3 PORT + STBD POTABLE
 ADDED 6 OZ CHLORINE PER 1000 GALS
 SIGNED M. Roy Hill

1600-2000
 #1 Evap. dist. to #3 port + stbd.
 Added 8 oz chlorine per 1000 Gals f.w. dist.
 SIGNED R. Shappard

2000-2400
 #1 & 2 EVAP. DIST TO
 #3 PORT & STBD.....
 (Added 8 OZ Chlorine
 per 1000 gals dist.
 SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

2017 in

MINUTES AT 2300-0100-0500

DATE 1-22

19 67

	1 - 29-67												1 - 22-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	6	6	6	7	7	7	7	7	7	7	7	6	6	6	6	7	7	7	7	7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	1	1	1	0	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	1
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	1	1	1	2"	2"	2"	2"	1	1	1	1	0	0	0	0	2"	2"	2"	2"	1	1	1	1	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	240	235	240	240	240	240	240	240	240	240	240	240	240	235	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	202	200	200	200	200	200	200	200	200	200	200	200	200	200	198	200	200	200	200	200	200	200	200	200
1ST EFFECT SHELL PRESSURE, *HG	11	11	11	10"	10"	10"	10"	11	11	11	11	11	11	11	11	10"	10"	10"	10"	11	11	11	11	11
2D EFFECT COIL DRAIN, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2D EFFECT SHELL PRESSURE, *HG	18	18	18	18"	18"	18"	18"	18	18	18	18	18	18	18	18	18"	18"	18"	18"	18	18	18	18	18
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	152	152	154	154	154	154	152	152	152	154	152	152	152	150	154	156	156	156	150	150	150	150	150
3D EFFECT SHELL PRESSURE, *HG	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
CONDENSATE TO COOLER, TEMPERATURE, °F	136	134	134	134	136	134	135	132	135	135	135	136	136	136	136	140	140	140	140	136	136	136	136	136
CONDENSATE FROM COOLER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
BRINE OVERBOARD, TEMPERATURE, °F	132	131	130	126	126	126	126	126	126	126	126	126	128	128	128	130	130	130	132	130	132	132	132	132
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	90	90	90	92	90	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	71	71	72	72	72	73	73	71	72	71	70	72	72	72	73	76	76	76	71	71	71	71	71	71
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	71	71	72	72	72	73	73	71	73	71	70	72	72	72	73	76	76	76	71	71	71	71	71	71
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	115	115	115	115	115	115	115	110	110	110	110	115	115	115	115	118	118	118	115	112	112	112	112	112
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	134	134	134	140	142	144	144	134	134	134	134	134	134	134	134	144	144	144	146	144	134	134	134	134
FEED TO 1ST EFFECT, TEMPERATURE, °F	154	155	156	162	164	168	168	154	154	154	154	156	156	156	156	168	168	168	168	154	156	156	156	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	100	102	100	100	102	102	102	102	102	102	102	102	102	102	104	104	104	102	98	98	98	98	102
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	23	23	23	24	24	24	24	24	24	24	24	23	23	23	23	23	23	23	23	23	23	23	23	23
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	25"	25"	26"	25"	25	25	25	25	22	22	22	22	25"	25"	25"	25"	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	32	32	32	30	30	30	30	35	35	35	35	32	32	32	32	30	30	30	30	32	32	32	32	32
FEED PUMP SUCTION PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
FEED PUMP DISCHARGE PRESSURE, #G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	54	55	55	54	54	54	54	54	54	54	54	52	53	53	53	54	54	54	54	54	54	54	54	54
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	20	20	20	20	20	20	20	30	30	30	30	30	30	30	30	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	04608300		
0000			
0100	04625400	1200	
0200	04626700	1300	
0300	04628300	1600	1 HR 20 MIN
0400	04629400	1300	
0500	04636800	1200	
0600	04632300		1500 = 1 HR 20 MIN
0700	04633500		1200
0800	04634600		1100
0900	04635700		1100
1000	04636800		1100
1100	04638000	1200	7,000
1200	04608300	1200	
1300	04610800	1300	
1400	04611000	1200	
1500	04613200	1300	
1600	04614200	1000	
1700	04615400	1200	
1800	04616500	1100	
1900	04617700	1200	
2000	04618900	1200	
2100	04620100	1200	
2200	04621300	1200	
2300	04623000	1700	1 HR 20 MIN
2400	04624200	1200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	268		
HOURS TO DATE			
GALLONS BROUGHT FORWARD	310800		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

1-23-67 #2

0000-0800

#1 & 2 EVAP DIST TO
#3 PORT + STBD POTABLE TANK
ADDED 60Z CHLORINE PER 1000 GALS
1 HR 20 MIN

SIGNED Mc Roy Hill

0800-0800

#2 Evap. Dist. to #3 port & stbd.
Filled #2 No. 400 up Tank, 3/4 can Macrop
@ 0800 shifted dist. to #2 stbd. feed.

SIGNED R. Sheppard

0800-1200

#1 & 2 EVAP. DIST TO
#2 STBD FEED.....
@ 10:00 Shifted Dist. to
#3 PORT & STBD....
(Added 80Z chlorine
per 1000 gals Dist....
F.W. DIST. 25 Hrs = 29,800 GALS

SIGNED E. J. Nagallan

1-22-67

1200-1600

#1 & 2 EVAP DIST TO
#3 PORT + STBD POTABLE TANK
ADDED 60Z CHLORINE PER 1000 GALS

SIGNED Mc Roy Hill

1600-2000

#2 Evap. Dist. to #3 port & stbd.
Added 80Z chlorine per 1000 gals per dist.

SIGNED R. Sheppard

2000-2400

#1 & 2 EVAP. DIST TO
#3 PORT & STBD.....
(Added 80Z chlorine
per 1000 gals Dist....

SIGNED E. J. Nagallan