

DATE 30 AUGUST 1967REPAIR LIST REQUESTSUBJECT PIPE, #2 EVAPORATOR, 1ST EFFECT. SHELL DRAIN, RENEWAL OFDATA 4" x 14"-90° FLANGED SECTIONLOCATION EVAPORATOR FLATCONDITION HOLEDQUANTITY/SIZE ONE (1) 4" x 14", 90° BEND, GALV. STEEL FLANGEDRECOMMENDATION FURNISH LABOR AND MATERIAL TO REMOVE PIPE, FABRICATED
NEW SECTION AND REINSTALL*completed*
E. C. QUINN, C/E

SIGNATURE