

3ND-P&PO 9546

U.S.S.

GEN. JOHN Dope

PLANT NO.

TIME: ZONE DESCRIPTION

SET CLOCKS AHEAD OR BACK

MINUTES AT

DATE 7-10 1967

	HOUR ENDING																									
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400		
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7		
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	4	4	4	3	3	3	3	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4		
STEAM TO 1ST EFFECT, TEMPERATURE, °F	225	225	230	225	225	230	225	225	225	225	225	240	240	240	240	235	235	225	225	225	225	225	225	225		
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	210	208	208	208	208	208	208	210	210	210	210	208	208	208	208	208	208	208	210	210	210	210	210	210		
1ST EFFECT SHELL PRESSURE, "HG	7	7	8	8"	8"	8"	8"	7	7	7	7	7	7	7	7	7"	7"	7"	7"	7	7	7	7	7		
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	164	164	164	164	164	164	164	164	160	160	160	160	164	164	164	164	164	164	164	164	164		
2D EFFECT SHELL PRESSURE, "HG	21	21	21	21"	21"	21"	21"	21	21	21	21	21	21	21	21	21"	21"	21"	21"	21	21	21	21	21		
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	148	148	148	150	150	150	150	150	150		
3D EFFECT SHELL PRESSURE, "HG	27	27	27	27"	27"	27"	27"	27	27	27	27	27	27	27	27	27"	27"	27"	27"	27	27	27	27	27		
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	140	140	140	140	140	140	140	140	138	138	138	138	140	140	140	140	140	140	140	140	140		
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	92	92	92	92	92	92	92	92	92	94	94	94	94	94	94	94	94	94	94	94	94	94		
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	132	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130		
AIR EJECTOR DRAINS, TEMPERATURE, °F	106	106	100	100	96	96	96	96	96	96	96	98	98	98	98	100	98	100	100	100	100	100	100	100		
CIRC. WATER INJECTION, TEMPERATURE, °F	73	73	73	74	74	75	75	75	75	75	75	71	71	72	72	72	72	73	73	73	73	73	73	73		
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	73	73	73	74	74	75	75	75	75	75	75	71	71	72	72	72	72	73	73	73	73	73	73	73		
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	140	140	140	138	138	138	138	138	138	138	138	138	138	138	138	138	138	140	140	140	140	140	140	140		
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	156	156																							

7-11-67

2

7-10-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	06483000		
0000			
0100	06498900	1200	
0200	06500000	1100	
0300	06501100	1100	
0400	06502300	1200	
0500	06503500		1200
0600	06504600		1100
0700	06505700		1100
0800	06506900		1200
0900	06508000		1100
1000	06509200	1200	1200
1100	06510400	1200	
1200	06484100	1100	
1300	06485200	1100	
1400	06486300	1100	
1500	06487400	1100	
1600	06488500	1100	
1700	06489600		1100
1800	06490700		1100
1900	06491900		1200
2000	06493100		1200
2100	06494200		1100
2200	06495300		1100
2300	06496500		1200
2400	06497700	1200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	75		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	79600		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400

2 - EVAP DIST TO #1 POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

M. E. Roy Hill

0400-0800

2 Evap. Dist. to #1 Std. Feed

SIGNED

R. Sheppard

0800-1200

1 EVAP. DIST. TO
1 STD FEED.....
@ 0900 SHIFTED DIST.
TO # 3 CENTER.....

SIGNED

J. J. Nagallanes

Stocked in CDS

1200-1600

2 - EVAP DIST TO #3 POT

SIGNED

M. E. Roy Hill

1600-2000

@ 1400 shifted dist to #1 Std. Feed

SIGNED

R. Sheppard

2000-2400

2 EVAP. DIST. TO
1 STD FEED.....
@ 22:00 SHIFTED DIST TO
3 CENTER.....

SIGNED

J. J. Nagallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

3ND-P&PO 9540

UNDERWAY

U.S.S.

LOW PRESSURE DISTILLING PLANT OPERATING

CHEN. JOHN DOE

PLANT NO. II

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ~~OR~~ ^{AHEAD} BACK 20 MIN

MINUTES AT 2300-0100-0250 DATE 7-9

19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	8	7	7	7	7	7	7	7	10	7	8	7	7	7	7	7	7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	1	1	1	1	1	1	1	1	1	1	1	0	1	1	1	1	1	1	1	1	1	1	1	1
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	2	2	2	2	2	2	2	2	2	2	2	4	3	3	3	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	230	230	230	230	230	230	230	230	220	230	240	240	235	230	230	220	230	230	230	230	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	208	208	208	208	208	208	208	208	208	208	208	185	208	208	208	208	208	208	208	208	208	208	208	208
1ST EFFECT SHELL PRESSURE, *HG	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	162	162	162	162	164	164	164	164	164	164	164	160	160	160	160	164	164	164	164	164	164	164	164	164
2D EFFECT SHELL PRESSURE, *HG	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	148	148	150	150	148	148	148	148	150	150	150	150	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, *HG	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27	27
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	140	140	140	140	140	140	140	140	138	138	138	138	142	140	140	140	140	140	140	140	140
CONDENSATE FROM COOLER, TEMPERATURE, °F	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
BRINE OVERBOARD, TEMPERATURE, °F	132	132	132	132	132	132	132	132	132	132	132	130	130	130	130	132	132	132	132	132	132	132	132	132
STEAM TO AIR EJECTOR, PRESSURE, #G	98	98	98	94	96	96	96	96	96	96	96	98	98	98	98	100	98	96	98	98	98	98	98	98
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	69	70	70	70	70	70	69	69	69	69	69	69	69	69	69	67	68	69	69	67	67	67	67	68
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	69	70	70	70	70	70	69	69	69	69	69	69	69	69	69	67	68	69	69	67	67	67	67	68
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	139	138	138	138	138	138	138	135	135	135	135	138	138	138	138	138	138	138	138	138	138	138	138	138
FEED TO 1ST EFFECT, TEMPERATURE, °F	156																							

7-10-67

#2

7-9-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	06454800		
0100	06471000	1100	
0200	06472100	1100	
0300	06473600	1500	1 HR 20 MIN
0400	06474700	1100	
0500	06475900		1200
0600	06477300		1400
0700	06478500		1200
0800	06479600		1100
0900	06480700		1100
1000	06481800		1100
1100	06483000		1200
1200	06485900	1100	
1300	06487100	1200	
1400	06488200	1100	
1500	06489400	1200	
1600	06490600	1200	
1700	06491700	1100	
1800	06492800	1100	
1900	06494000	1200	
2000	06495100		1100
2100	06496200		1100
2200	06497300		1100
2300	06498800		1500 (1 HR 20 MIN)
2400	06499900	1100	

0000-0400

#2-EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

1 HR-20 min

SIGNED

M^C Roy Hill

0400-0800

#2 Evap. Dist. to #1 Stbd Feed

1 HR 20 MIN

SIGNED

R. Sheppard

0800-1200

#-2 EVAP. DIST. TO
#-1 STBD FEED-----

SIGNED

E. J. Gallanes

Stocked in CDS

1200-1600

#2-EVAP DIST #3 CENTER POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

M^C Roy Hill

1600-2000

#2 Evap Dist. to #3 &
Added 80z chlorine per 1000 Gals
@ 1900 shifted dist. to #1 Stbd Feed

SIGNED

R. Sheppard

2000-2400

#-2 EVAP. DIST. TO
#-1 STBD FEED-----

SIGNED

E. J. Gallanes

For disposal of this record see current Records Disposal Instructions for Vessels
of the U. S. Navy.

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	45		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	51400		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

3ND- P&PO 9546

U. S. S.

PLANT NO.

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

MINUTES AT 2300-0100-0800 DATE _____**DATA**[illegible]

7-10-67 #1

7-9-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11351500		
0000			
0100	11372900	1500	
0200	11374400	1500	
0300	11376300	1900	1 HR 20 MIN
0400	11377800	1500	
0500	11379300	1500	
0600	11381100	1800	1 HR 20 MIN
0700	11382600	1500	
0800	11384100	1500	
0900	11385600	1500	
1000	11387100	1500	
1100	11388600	1500	
1200	11352900	1400	
1300	11354500	1600	
1400	11356000	1500	
1500	11357500	1500	
1600	11359100	1600	
1700	11360600	1500	
1800	11362100	1500	
1900	11363600	1500	
2000	11365100	1500	
2100	11366600	1500	
2200	11368100	1500	
2300	11370000	1900	(1 HR 20 MIN)
2400	11371400	1400	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	45		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	65600		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400
#1 EVAP DIST TO #3 POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED McRay Hill

0400-0800
#1 Evap Dist. to #3 &
Add'd 8 OZ chlorine per 1000 gals
#1 port-21 - Test 2 Drops
#1 std-21 - Test 2 Drops
#2 port-22 - Test 2 Drops
#2 std-22 - Test 2 Drops
SIGNED R. Shippard

0800-1200
#1 Evap. Dist to
#3 CENTER
(Added 8 OZ per 1000
gals Dist.)
SIGNED E. J. Nagallane

Stocked in CDS

1200-1600
#1-EVAP DIST TO #3 CENTER POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED McRay Hill

1600-2000
#1 Evap. Dist. to #3 &
Add'd 8 OZ chlorine per 1000 gals
SIGNED R. Shippard

2000-2400
#1 EVAP. DIST. TO
#3 CENTER
(Added 8 OZ a/2 for int
per 1000 gals Dist.)
SIGNED E. J. Nagallane

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

3ND-P&PO 9540

U. S. S.

PLANT NO.

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

MINUTES AT 2300 - C/CC - 0500

DATE _____

1965

	7-9-67																7-8-67							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	9	10	9	9	9	9	9	9	9	9	9	9	9	9	8	10	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	1	1	1	1	1	1	1	1	1	1	1	2	2	2	2	1	1	1	1	1	1	1	1	1
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	5	5	5	5"	5"	5"	5"	5	5	5	5	3"	3"	3"	3"	5"	5"	5"	5"	5	5	5	5	5
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	230	230	230	230	235	235	230	230	230	235	235	235	230	230	225	225	225	225	225	225	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	15"	15"	15"	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	140	140	140	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118
CONDENSATE FROM COOLER, TEMPERATURE, °F	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
BRINE OVERBOARD, TEMPERATURE, °F	115	115	116	116	116	116	116	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118	118
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	66	66	66	66	66	66	66	66	66	66	66	64	64	64	64	64	64	64	66	66	66	66	66	66
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	66	66	66	66	66	66	66	66	66	66	66	64	64	64	64	64	64	64	66	66	66	66	66	66
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	170	170																			

7-9-67

4-1

7-8-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11315300		
0000			
0100	11335800	1400	
0200	11337300	1500	
0300	11339200	1900	1 HR-20 MIN
0400	11340700	1500	
0500	11342200	1500	
0600	11344100	1900	1 HR-20 MIN
0700	11345600	1500	
0800	11347000	1400	
0900	11348500	1500	
1000	11350000	1500	
1100	11351500	1500	
1200	11352900	1400	
1300	11354300	1400	
1400	11355700	1500	
1500	11357100	1500	
1600	11358500	1500	
1700	11359900	1500	
1800	11361300	1500	
1900	11362700	1400	
2000	11364100	1400	
2100	11365500	1340	
2200	11366900	1400	
2300	11368300	1900 (1 HR-20 MIN)	
2400	11369700	1400	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	20		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	29500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			

APPROVED

(Engineer Officer, U. S. N.)

NAVSHIPS 3676 (REV. 11-50) BACK

0000-0400

#1 - EVAP DIST TO #3 CENTER POT

SIGNED

M. R. Roy Hill

0400-0800

#1 Evap. Dist. To #3 &
Added 8 oz chlorine per 1000 gals

#1 port-20'-Test 2 drops
 #1 stbd-22'-Test 2 drops
 #2 port-22'-Test 2 drops
 #2 stbd-22'-Test 2 drops

SIGNED

R. Shippard

0800-1200

#1 - 1 EVAP. DIST. TO
 #3 CENTER.....
 (Added 8 oz chlorine
 to each 1000 gals Dist.)

SIGNED

E. J. J. Gallanes

Stocked in CDS

1200-1600

#1 - EVAP DIST TO #3 CENTER POT

SIGNED

M. R. Roy Hill

1600-2000

#1 Evap dist. To #3 &
Added 8 oz chlorine per 1000 gals

SIGNED

R. Shippard

2000-2400

#1 - 1 EVAP. DIST. TO
 #3 CENTER.....
 (Added 8 oz chlorine
 per 1000 gals Dist.)

SIGNED

E. J. J. Gallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

7-9-67

H-2

7-8-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	06426800		
0000			
0100	06442800		1100
0200	06443900		1100
0300	06445400		1500 1 Run
0400	06446600		1200
0500	06447800		1200
0600	06449200		1400 1 HR. 20 min
0700	06450300		1100
0800	06451400		1100
0900	06452500		1100
1000	06453700		1200
1100	06454800		1100
1200	06457800	1100	
1300	06458900	1000	
1400	06459400	1000	
1500	06460400	1100	
1600	06462100	1200	
1700	06463300	1200	
1800	06464500	1200	
1900	06465700	1200	
2000	06466800		1100
2100	06467900		1100
2200	06469100		1200
2300	06470500		1200 (1 HR 20 MIN)
2400	06471700		1200

0000-0800

#2 - EVAP DIST TO #1 STBD FEED

1200-1800

#2 EVAP DIST TO #3 CENTER PORT

SIGNED

M. J. Rayhill

SIGNED

M. J. Rayhill

0800-1200

#2 Evap. Dist. TO #1 & 2
S+66 Feed

1200-1800

#2 Evap. Dist. TO #3 &
Added 8 oz chlorine per 1000 gals

SIGNED

R. Shppard

SIGNED

R. Shppard

0800-1200

#2 Evap. Dist. TO
#1 & 2 STBD FEED...

1200-1800

#2 Evap. Dist. TO
#1 & 2 STBD FEED...

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	20		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	23300		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

SIGNED

E. J. Magallanes

SIGNED

E. J. Magallanes

SND-P&PO 9546

U. S. S.

PLANT NO.

TIME: ZONE DESCRIPTION

SET CLOCKS **AHEAD OR BACK** 20 min

MINUTES AT 2300-0100-0500 DATE 7

1

	7-8-67												7-7-67											
	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	10	10	10	9	9	9	9	9	9	9	9						9	9	9	9	10	10	10	10
STEAM FROM REG. VALVE, PRESSURE #G	0	0	0	0	0	0	0	0	0	0	0						1	1	1	1	1	1	1	0
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	5	5	5	5"	5"	5"	5"	5	5	5	5						5"	5"	5"	5"	5	5	5	5
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	225	225	225	225	225	225	230	230						220	225	220	230	230	230	235	235
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	185	185	185	185	185	185	185	185	185	185	185						180	182	182	185	180	180	185	185
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	14"	14"	14"	14	14	14	14						14"	14"	14"	14"	14	14	14	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	162	164	162	164	160	160	160	160						162	164	164	164	160	164	168	168
2D EFFECT SHELL PRESSURE, "HG	15	15	15	15"	15"	15"	15"	16	16	16	16						15"	15"	15"	15"	15	15	15	15
3D EFFECT COIL DRAIN, TEMPERATURE, °F	140	140	140	140	144	142	144	136	136	136	136						132	134	134	134	130	130	134	134
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25						25"	25"	25"	25"	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	112	112	112	114	114	114	114	110	110	114	114						118	118	118	118	118	110	110	110
CONDENSATE FROM COOLER, TEMPERATURE, °F	80	80	80	80	80	80	80	80	80	80	80						82	82	82	82	80	80	80	80
BRINE OVERBOARD, TEMPERATURE, °F	110	110	110	110	110	110	110	110	110	110	110						110	110	110	112	110	110	116	116
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92						92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	60	61	63	63	63	64	64	64	64	64	64						59	62	63	63	63	63	63	63
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	66	67	67	63	63	64	64	64	64	64	64						59	62	63	63	63	63	63	63
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	169	169	169	170	168	166	166	164	160	162	167						165	170	168	166	162	162	165	164
CIRC. WATER OVERBOARD, TEMPERATURE, °F	94	94	94	100	100	100	100	100	100	102	102						102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	6	6	6	6	6	6	6	6	6	6	6						6	6	6	6	6	6	6	6
CIRC. PUMP DISCHARGE PRESSURE, #G	17	17	17	17	17	17	17	17	17	17	17						17	17	17	17	17	17	17	17
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25						25"	25"	25"	25"	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	30	30	30	30	30	30	30	30	30	30	30						30	30	30	30	30	30	30	30
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0						0	0	0	0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	56	56	56	56	56	56	56	56	56	56	56						56	56	56	56	56	56	56	56
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10						10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05						1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	40	40	40	40	40	40	40	40	40	40	40						40	40	40	40	40	40	40	40
1ST EFFECT DRAINS, SALINITY—E. P. M.	53	53	53	53	53	53	53	53	53	53	53						53	53	53	53	53	53	53	53
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0						0	0	0	0	0	0	0	0

1

DISTILLED WATER RECORD				REMARKS			
HOUR ENDING	METER READING	GALLONS		0000-0400	1200-1600		
		SHIPS TANKS*	FEED TANKS*				
0000				# 1 Evap. Dist. To #3 & #4			
0100	11300000	1400					
0200	11301500	1500					
0300	11303400	1300	1.30 MIN				
0400	11304900	1500					
0500	11306300	1400					
0600	11308300	2000	1.40-20				
0700	11309900	1500					
0800	11311200	1400	1.40				
0900	11312600	1400	1.40				
1000	11313900	1300		SIGNED <u>M. R. Hill</u>			
1100	11315300	1400					
1200						0000-0400 # 1 Evap. Dist. To #3 & #4 Added 8 oz chlorine per 1000 gals dist	1200-1600 # 1 Evap. Dist. To #3 & #4 Added 8 oz chlorine per 1000 gal F.W. Dist.
1300							
1400							
1500							
1600	11285800						
1700	11287200	1400					
1800	11288800	1400					
1900	11290300	1500					
2000	11291800	1500					
2100	11293300	1500					
2200	11294900	1600					
2300	11296000	1100	(40 MIN)				
2400	11298600	2000	1.30-01 MIN				

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-1200		1200-2400	
# 1 Evap. Dist. To #3 & #4	# 1 Evap. Dist. To #3 & #4	# 1 Evap. Dist. To #3 & #4	# 1 Evap. Dist. To #3 & #4
# 3 CENTER LINE	# 3 CENTER LINE	# 3 CENTER LINE	# 3 CENTER LINE
(Added 8 oz chlorine to each 1000 gals Dist)	(Added 8 oz chlorine to each 1000 gals Dist)	(Added 8 oz chlorine to each 1000 gals Dist)	(Added 8 oz chlorine to each 1000 gals Dist)
SIGNED <u>R. Shppard</u>	SIGNED <u>R. Shppard</u>	SIGNED <u>R. Shppard</u>	SIGNED <u>R. Shppard</u>
SIGNED <u>E. J. Gallan</u>	SIGNED <u>E. J. Gallan</u>	SIGNED <u>E. J. Gallan</u>	SIGNED <u>E. J. Gallan</u>

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

3ND-P&PO 9546

U. S. S.

LOW PRESSURE DISTILLING PLANT
 THER. JOHN Pope

PLANT NO.

II

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

07-08-1968

420 m

MINUTES AT 2300-0100-0200

DATE 7

19

	7-8-67												7-7-67											
	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	8	8	8	8	7	8	8	8	8					8	8	8	8	8	8	8	8	7
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	1	1	1	1	1	1	1	1					1	1	1	1	0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	2	2	2	2	2	2	2	1 1/2	2	2	2					2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	210		130	220	220	220	220	220	220	230	230					220	225	220	225	225	225	230	230	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	208		204	206	206	206	206	206	206	206	206					206	206	206	206	208	208	208	208	208
1ST EFFECT SHELL PRESSURE, #HG	6 1/2	5 1/2	7 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6	6	6	6					6 1/2	6 1/2	6 1/2	6 1/2	6	6	5	5	5
2D EFFECT COIL DRAIN, TEMPERATURE, °F	153		153	156	156	160	160	154	154	150	150					160	160	160	160	162	160	162	162	162
2D EFFECT SHELL PRESSURE, #HG	20	1	20	20 1/2	20 1/2	20 1/2	20 1/2	20	20	20	20					20 1/2	20 1/2	20 1/2	20 1/2	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150		150	146	146	150	150	148	148	148	148					150	150	150	150	152	150	152	152	152
3D EFFECT SHELL PRESSURE, #HG	27	27	27	27 1/2	27 1/2	27 1/2	27 1/2	27	27	27	27					27 1/2	27 1/2	27 1/2	27 1/2	27	27	27	27	27
CONDENSATE TO COOLER, TEMPERATURE, °F	130		130	136	136	138	138	138	138	138	138					144	144	144	142	144	144	144	144	144
CONDENSATE FROM COOLER, TEMPERATURE, °F	80		80	88	88	90	90	90	90	90	90					94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	120		120	124	124	128	128	126	126	126	126					128	128	128	126	124	124	124	124	124
STEAM TO AIR EJECTOR, PRESSURE, #G	94		94	94	94	94	94	94	94	94	94					94	94	94	94	90	90	90	90	90
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	60		60	63	63	64	64	64	64	64	64					59	62	63	63	63	63	63	63	62
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	60		60	63	63	64	64	64	64	64	64					59	62	63	63	63	63	63	63	62
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																				102	102			
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	140		140	136	138	138	138	140	140	138	138					138	138	138	138	150	150	162	162	162
FEED TO 1ST EFFECT, TEMPERATURE, °F	150		150	156	156	156	156	158	158	158	158					156	156	156	156	162	162	162	162	162
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100		100	100	100	100	100	102	102	102	102					100	100	100	100	102	102	106	106	104
CIRC. PUMP SUCTION PRESSURE, #G	5		5	5	6	6	6	6	6	6	6					5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	22		22	22	22	22	22	22	22	22	22					22	22	22	22	22	22	22	22	21
BRINE PUMP SUCTION PRESSURE, #G	25		25	25	25	25	25	25	25	25	25					25	25	25	25	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	30		30	38	38	38	37	37	37	37	37					34	34	32	32	30	31	30	30	30
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2		2	2	2	2	2	2	2	2	2					2	2	2	2	2	2	2	2	2
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	47		47	47	48	48	48	48	48	48	48					47	47	47	47	46	46	46	46	48
F. W. PUMP DISCHARGE PRESSURE	10		10	10	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02		1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02					1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.0		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.0		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	06414200	1100	
0200	06416100	1200	
0300	06417600	1500	16:20 min
0400	06418700	1100	
0500	06419900	1200	
0600	06421300		1400 (1 hr - 20 min)
0700	06422400		1100
0800	06423500		1100
0900	06424600		1100
1000	06425700		1100
1100	06426800		1100
1200			
1300			
1400			
1500			
1600	06403500		
1700	06404700	1200	
1800	06406000	1300	
1900	06407300	1300	
2000	06408600	1300	
2100	06409800	1200	
2200	06411000	1200	
2300	06411800	800 (40 MIN)	
2400	06413500	2000 (1 hr 40 min)	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

7-8-67
#2 EVAP DIST TO #3 CENTER PBT
SIGNED M. R. Sy Hill

0000-0800 #2 Evap. Dist. TO #3 &
@ 0500 #2 Evap. Dist. TO #1 STD.
SIGNED R. Shppard

0800-1200 #2 Evap. Dist. TO
#3 CENTER LINE
(Added 8 oz Chlorine
TO EACH 1000 gals Dist.
@ 0900 Dist. TO #1 STD.
SIGNED J. A. Magallanes

7-7-67
SIGNED

1200-1600 #2 Evap. Dist. TO #3 center
Added 8 oz chlorine per
1000 gal F.W. Dist
SIGNED R. Shppard

1600-2000 #2 Evap. Dist. TO
#3 CENTER LINE
(Added 8 oz chlorine
TO EACH 1000 gals Dist.
SIGNED J. A. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GREEN, NO HAD DOPE

PLANT NO.

AHEAD
OR
BACK

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

MINUTES AT

DATE

7-21

1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	9	9	9	9	10	10	10	10	10	10	10	10	10	10	9	8	8	8	8	9	
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	1"	1"	1"	1"	1	1	1	1	1	1	1	1	1"	1"	1"	1"	1	1	1	1	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	235	235	240	240	240	240	240	240	235	235	240	240	240	240	240	240	240	240	235	235	235	235
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195	200	200	200	200	195	195	195	195	195	195	195	195	195	195	195	195	
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	15"	15"	15"	15	15	15	15	15	15	14	14	15"	15"	15"	15"	15	15	15	15	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	160	162	162	164	164	164	164	158	158	158	160	160	162	162	162	162	160	160	160	160	
2D EFFECT SHELL PRESSURE, "HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15"	15"	15"	15"	15	15	15	15	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	160	160	160	160	150	148	148	148	
3D EFFECT SHELL PRESSURE, "HG	24	24	24	24"	24"	24"	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
CONDENSATE TO COOLER, TEMPERATURE, °F	125	125	125	125	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	
CONDENSATE FROM COOLER, TEMPERATURE, °F	95	95	95	95	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	
BRINE OVERBOARD, TEMPERATURE, °F	125	125	125	125	124	124	124	128	128	128	128	126	126	126	126	126	126	126	126	126	126	126	126	
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	85	85	85	85	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	85	85	85	85	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	162	162	162	162	162	162	162	162	162	162	162	162	162	164	164	164	164	164	164	164	164	164	164	
CIRC. WATER OVERBOARD, TEMPERATURE, °F	105	105	105	105	106	106	106	106	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	
BRINE PUMP SUCTION PRESSURE, #G	25	24	24	24"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	
BRINE PUMP DISCHARGE PRESSURE, #G	30	30	30	30	28	28	28	28	28	28	28	28	28	28	30	30	30	30	30	30	30	30	30	
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	20	20	20	20	40	40	20	20	20	20	20	20	20	20	20	20	
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

7-22-67

#1

7-21-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11774100		
0000			
0100	11774200		1400
0200	11774300		1400
0300	11774800	1400	
0400	11778200	1400	
0500	11778600	1400	
0600	11801000	1400	
0700	11802400	1400	
0800	11803700	1300	
0900	11805100	1400	
1000	11806500	1400	
1100	11807900	1400	
1200	11775300	1400	
1300	11777000	1500	
1400	11778400	1400	
1500	11779800	1400	
1600	11781200	1400	
1700			
1800	11784200	3000	
1900	11785600	1400	
2000	11787000	1400	1400
2100	11788400	1400	1400
2200	11789700	1300	1300
2300	11791200	1400	1500
2400	11792600		1400

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	320		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	488200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-56) BACK

REMARKS

0000-0400
#1 EVAP DIST TO #3 DIST FEED
0130 SWITCH TO #3 & POT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED ME Roy Hill

0400-0800
#1 Evap. Dist. TO #3 &
Added 8 oz chlorine per 1000 gals

0800-1200
#1 EVAP. DIST. TO
#3 @ ENTER
(Added 8 oz chlorine
Per 1000 gal Dist.)

SIGNED E. J. Nagallanes

Stocked in CDS

1200-1600
#1 EVAP DIST TO #3 PORT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED ME Roy Hill

1600-2000
#1 Evap. Dist. TO #3 port
Added 8 oz chlorine per 1000 gals dist.

2000-2400
#1 EVAP. DIST. TO
#1 STBD FEED

SIGNED E. J. Nagallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY XU. S. S. TEN. John PopePLANT NO. 1

AT ANCHOR _____

TIME: ZONE DESCRIPTION _____

AHEAD
OR
BACK 20 minMINUTES AT 2300-0100-0500 DATE 7-2219 67

	7-23-67												7-23-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	1"	1"	1"	1"	1	1	1	1	1	1	1	1	1"	1"	1"	1"	1	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	235	235	240	240	240	235	240	240	240	240	235	230	230	235	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195	195	195	195	195	195	195	195	195	195	195	195	195	200	200	200	200	200
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	15"	15"	15"	15	15	15	15	14	14	14	14	15	15	15	15	15	15	15	15	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	162	162	164	164	164	164	164	164	156	156	156	156	160	160	162	162	162	162	162	162	162
2D EFFECT SHELL PRESSURE, "HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	152	152	152	152	152	148	148	148	148	148	148	150	150	150	150	150	150	150
3D EFFECT SHELL PRESSURE, "HG	25	25	25	24	24	24	24"	24	24	24	24	25	25	25	25	25	25	25	25	25	25	25	25	24
CONDENSATE TO COOLER, TEMPERATURE, °F	128	128	128	128	128	128	128	128	130	130	130	126	126	126	126	128	128	128	128	130	130	130	130	130
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	98	98	98	98	98	98	96	96	96	96	96	96	96	96	98	98	98	98	98
BRINE OVERBOARD, TEMPERATURE, °F	128	126	126	120	120	120	120	120	120	120	120	126	126	126	126	118	118	118	118	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	96	96	96	96	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	85	85	85	85	85	85	85	87	87	87	87	84	84	84	84	84	84	84	84	85	85	85	85	85
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	85	85	85	85	85	85	85	87	87	87	87	84	84	84	84	84	84	84	84	85	85	85	85	85
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	162	162	162	162	162	162	162	162	162	162	162	164	164	164	164	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

7-23-67

#-1

7-22-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11807900		
0000			
0100	11821400	1400	
0200	11835700	1300	
0300	11832500	500	1400 M.H.
0400	11831900	1400	
0500	11833300	1400	
0600	11835100	1800	1 HR. 20 M.
0700	11836500	1400	
0800	11837900	1400	
0900	11839300		1400
1000	11840600		1200
1100	11842000		1400
1200	11839400	1500	
1300	11815700	1300	
1400	11815100	1500	
1500	11813300	1300	
1600	11814700	1400	
1700	11816300	1560	
1800			
1900	11818900	2706	
2000	11820100	1200	1200
2100	11821400	1300	1300
2200	11822800	1400	1400
2300	11824200		1400
2400	11826000		1800

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	344		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	522000		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400

1 EVAP DIST TO #3 PORT PAT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

Mc Roy Hill

0400-0800

1 Evap. Dist. To #3 port.
Add-d 8 oz chlorine per 1000 Gals.

SIGNED

R. Sheppard

0800-1200

#- 1 EVAP. DIST. TO
#- 1 STBD FEED

SIGNED

E. J. Vagallanes

REMARKS

1200-1600

1 EVAP DIST TO #3 PORT PAT

SWITCH TO PORT #3

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

Mc Roy Hill

1600-2000

1 Evap. Dist. To #3 &
Add-d 8 oz chlorine per 1000 Gals.

SIGNED

R. Sheppard

2000-2400

#- 1 EVAP. DIST TO
#- 1 STBD FEED

SIGNED

E. J. Vagallanes

7-24-67

#2

7-23-67

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	06774600	1600	
0200	06776400	1800	
0300	06778100	1700	
0400	06779800	1700	
0500	06781500	1700	
0600	06783200	1700	
0700	06785000	1800	
0800	06786700	1700	
0900	06788200	1500	
1000	06790000	1800	
1100	06791600	1600	
1200	06793200		
1300	06794800		
1400	06796400	1700	
1500	06798000	1800	
1600	06799600	1900	
1700	06761700	1800	
1800	06763300	1800	
1900	06764900	1800	
2000	06766500	1500	
2100	06768100	1400	
2200	06769700	1400	
2300	06771300	1700	
2400	06772900	1600	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE	24		
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE	37,100		
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400

#2 EVAP DIST TO #3 PORT
SWITCH TO #3 PORT PORT 0245
ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

McRay Hill

0400-0800

#2 Evap. Dist to #3 port
Added 8 oz chlorine per 1000 gals

SIGNED

R. S. Skypard

0800-1200

#2 Evap. dist. to #3 P
Added 8 oz. chlorine per 1000 gal.

SIGNED

R.D. S. McInnis

1200-1600

#2 EVAP DIST TO #3 PORT PORT
ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

McRay Hill

1600-2000

#2 Evap. Dist to #3 &
Added 8 oz per 1000 gals dist.

SIGNED

R. S. Skypard

2000-2400

#2 Evap. dist. to #3 &
Added 8 oz. chlorine per 1000 gal.

SIGNED

R.D. S. McInnis

791600
06754500
37100

7-24-67 #1 7-23-67

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11842000		
0000			
0100	11860400	1500	
0200	11861800	1400	
0300	11863200	1400	
0400	11864500	1300	
0500	11865900	1400	
0600	11867200		1300
0700	11868600		1400
0800	11869800		1200
0900	11870900		1100
1000	11872300		1400
1100	11873500		1200
1200	11842900	1100	
1300	11844200	1400	
1400	11845500	1300	
1500	11846900	1400	
1600	11848300	1400	
1700	11849700	1400	
1800	11851100	1400	
1900	11852500	1400	
2000	11853500	1000	
2100	11854700	1200	
2200	11856100	1400	
2300	11857300	1200	
2400	11858900	1600	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	369		
HOURS THIS DATE	24		
HOURS TO DATE	393		
GALLONS BROUGHT FORWARD	557100		
GALLONS THIS DATE	31500		
GALLONS TO DATE	588600		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0800
#1 EVAP DIST TO #3 PORT
SWITCH #3 PORT POT. 0245
ADDED 80% CHLORINE PER 1000 GALS
SIGNED McRoy Hill

0800-1200
#1 Evap. Dist. TO #3 port
@ 0510 shifted dist to #1 still feed
#1 part-21- Test 2 drops
#1 still-15- Test 2 drops
#2 part-23- Test 2 drops
#2 still-20- Test 2 drops
SIGNED R. Sheppard

0800-1200
#1 Evap. dist. #1 still.
SIGNED R.D.S. McEinnis

1200-1800
#1 EVAP DIST TO #3 PORT POT
ADDED 80% CHLORINE PER 1000 GALS
SIGNED McRoy Hill

1800-2000
#1 Evap. Dist. TO #3 &
@ 1730 added 5 Gals chlorine TO
#3 & - 80% per 1000 Gals Thru
After
SIGNED R. Sheppard

2000-2400
#1 Evap. dist. to #3 &
Added 80% Chlorine per 1000 gal.
SIGNED R.D.S. McEinnis

73500
11842000
31500

344
25
19

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY OKINAWA TO DA NANGU. S. S. GEN. POPE (TAP-110)PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE 24 JULY, 19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	2"	2"	2"	2"	1"	1"	1"	1"	1"	1"	1"	1"	1"
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	238	240	240	240	240	265	250	230	222	240	240	240	240	240	240	240	240	250	245	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	192	192	192	192	190	190	190	190	190	190	190	190	192	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	166	164	168	168	168	168	168	168	168	168	164	164	164	164	168	168	170	170	166	168	168	168	166
2D EFFECT SHELL PRESSURE, "HG	21	21	21	20	20	20	20	20	20	20	20	22	22	21	21	20	20	20	20	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	150	150	150	152	150	150	150	150	148	148	148	148	150	150	150	150	148	150	147	147	146
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	135	135	136	136	136	136	136	136	136	134	134	130	130	130	130	134	134	134	134	134	134	134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	104	104	104	102	102	102	102	102	102	101	101	102	102	102	104	104	104	104	104	104	104	104	104	104
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	132	132	130	126	128	128	128	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	44	44	44	40	42	42	42	42	42	42	44	44	44	44	44	40	40	42	42	42	42	42	42	42
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	150	150	150	150	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	170	172	172	170	168	170	170	170	168	168	168	168	168	168	168	170	168	168	170	170	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	2	2	2	2					3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18					18	18	18	18	18	18	18	18	18
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	24	24	24	24					25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	30	30	30	30	30	30	30	24	22	22	22					25	25	25	25	25	25	25	25	25
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	3	3	3	3	3	3	2	2	1	1	1	1	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	25	27	8	8	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0.01	0.01	0.01	0.01	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

@1100 06791600 24 hr. 37,100 gal.
7-24-67

2

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	06791600		
0000			
0100	06815100	1700	
0200	06816600	1500	
0300	06818300	1700	
0400	06820100	1800	
0500	06821800	1700	
0600	06823600	1800	
0700	06825300	1700	
0800	06826900	1600	
0900	06828400	1500	
1000	06829900	1500	
1100	06830700	1500	
1200	06793400	1600	
1300	06795100	1700	
1400	06796600	1700	
1500	06798600	1800	
1600	06800300	1700	
1700	06802200	1900	
1800	06803900	1700	
1900	06805400	1700	
2000	06807200	1600	
2100	06808800	1600	
2200	06810400	1600	
2300	06811900	1500	
2400	06813400	1500	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	24		
HOURS THIS DATE	24		
HOURS TO DATE	48		
GALLONS BROUGHT FORWARD	37,100		
GALLONS THIS DATE	38,500		
GALLONS TO DATE	75,600		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400 #2 - EVAP DIST TO #3 STD POT ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>McRoy Hill</u>	1200-1600 #2 - EVAP DIST TO #3 STD FEED ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>McRoy Hill</u>
0400-0800 #2 Evap. Dist. To #3 std Added 8 oz chlorine per 1000 gals SIGNED <u>R. Shupard</u>	1600-2000 #2 Evap. Dist. To #3 std Added 8 oz chlorine per 1000 gals. SIGNED <u>R. Shupard</u>
0800-1200 #2 Evap. dist. to #35 Added 8 oz chlorine/1000 gal. SIGNED <u>R.D.S. McBinnis</u>	2000-2400 #2 Evap. dist to #35. Added 8 oz. chlorine 1000 gal. SIGNED <u>R.D.S. McBinnis</u>

06830100
0791600
38500

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY OKINAWA TO DANANGU. S. S. GEN. POPE (TAP 110)PLANT NO. I

AT ANCHOR

TIME: ZONE DESCRIPTIONSET CLOCKS AHEAD OR BACKMINUTES AT -DATE 24 July, 19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2"	2"	2"	0	0	0	0	1	1	1	1	1	1	1	1"	2"	2"	2"	2"	2"	2"	2"	2"	2"
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	235	235	232	230	230	230	230	240	240	240	240	240	236	236	235	236	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	195	195	195	195	202	202	202	202	197	197	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	15	15	16	14"	14"	14"	14"	14	14	15	15	14	14	14	14	15"	15"	15"	15"	15	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	160	162	162	164	160	160	156	154	160	160	160	160	162	162	164	164	162	166	166	158	156
2D EFFECT SHELL PRESSURE, "HG	16	16	16	16"	15"	15"	15"	15	15	16	16	16	16	16	16	16"	16"	16"	16"	16	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	150	148	148	148	148	146	146	146	146	150	150	150	150	152	154	150	150	150
3D EFFECT SHELL PRESSURE, "HG	24	24	24	24"	24"	24"	24"	24	23	23	23	24	24	24	24	24"	24"	24"	24"	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	126	126	126	128	128	128	128	128	128	128	128	126	126	126	126	128	128	128	128	128	128	128	128	128
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	98	98	98	98	99	99	98	97	98	98	98	98	98	98	98	98	98	98	98
BRINE OVERBOARD, TEMPERATURE, °F	120	126	126	126	126	125	125	125	125	125	125	125	125	125	125	125	125	125	124	124	124	125	125	125
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	87	87	86	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	87	87	86	87	87	87	87					87	87	87	87	87	87	87	87					87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	108	108	110	110	110	110	104	104	104	108	108	108	108	108	108	108	108	108	108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13
BRINE PUMP SUCTION PRESSURE, #G	20	20	20	20"	20"	20"	20"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25"	25"	25"	25"	25"
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	24	22	22	22	13	14	14	14	14	14	14	14	22	22	22	20	20	20	18	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	2	2	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	61	61	61	61	61	61	61	62	62	63	63	62	62	61	61	60	60	60	60	60	60	60	60	61
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	29	25	25	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	2	2	2	2	20	20	20	20	20	20	20	20	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

7-24-67
 1100 11873500

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11873500		
0000			
0100	11891200	1300	
0200	11894400	1200	
0300	11893900	1400	
0400	11895000	1100	
0500	11896300		1300
0600	11897800		1500
0700	11899000		1200
0800	11900200		1200
0900	11901500		1300
1000	11902800	1300	1300
1100	11904100	1300	1300
1200	11894700	1400	1400
1300	11876100	2200	1200
1400	11877400	1300	1300
1500	11878600	1200	1200
1600	11879900		1300
1700	11881300		1400
1800	11882600		1300
1900	11883900		1300
2000	11885000		1100
2100	11886300		1200
2200	11887500		1200
2300	11888700		1200
2400	11889900	1200	

0000-0400
 #1 - EVAP DIST TO #3 STBD PORT
 ADDED 8 OZ CHLORINE PER 1000 GALS
 SIGNED McRay Hill

1200-1600
 #1 EVAP DIST TO #1 STBD PORT
 SIGNED McRay Hill

0400-0800
 @0400 #1 Evap. Dist. to #1 & 2 STBD
 @0600 Dist to #1 port & STBD-Feed
 @0700 Dist to #1 STBD Feed-only
 #1 port-21' - Test 2 drops
 #1 STBD-21' - Test 2 drops
 #2 port-23' - Test 2 drops
 #2 STBD-23' - Test 2 drops
 SIGNED R. Shippard

1600-2000
 #1 Evap. Dist. to #1 & 2 STBD-Feed
 @1900 shifted Dist. to #1 STBD-only
 SIGNED R. Shippard

0800-1200
 #1 Evap. dist. to #15
 @0930 dist. to #35
 Added 8 oz. chlorine/1000 gal.
 SIGNED R.D.S. McQuinn

2000-2400
 #1 Evap dist. to #1 STBD.
 @2300 shifted to #35
 SIGNED R.D.S. McQuinn

NAVSHIPS 3676 (REV. 11-50) BACK
 8700 11800
 3900 11904100
 4800 11904100
 30600
 Stocked in CDS
 For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.
 PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY WHITE BEACH TO DA NANG

U. S. S. GEN. POPE (TAP-110)

PLANT NO. 2

AT ANCHOR _____

TIME: ZONE DESCRIPTION

AHEAD OR SET CLOCKS BACK

MINUTES AT

DATE 25 July 19 67

	HOUR ENDING																								
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	5	
STEAM FROM REG. VALVE, PRESSURE #G	8	2	2	2	2	2	2	2	2	1	1	4	4	4	3	3	3	3	2	2	2	2	2	1	
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	235	240	240	240	240	245	225	240	240	240	240	240	240	240	240	240	240	245	240	245	230	230	
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	192	190	192	192	192	192	190	190	190	190	190	192	192	192	192	192	190	
1ST EFFECT SHELL PRESSURE, "HG	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	166	166	166	166	166	166	166	164	166	166	166	164	164	164	164	166	166	166	166	166	166	166	166	
2D EFFECT SHELL PRESSURE, "HG	20	20	20	20	20	20	20	20	20	20	20	21	21	21	21	20	20	20	20	20	20	20	20	20	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	148	150	150	150	150	150	150	150	148	148	148	148	150	150	150	152	150	150	150	150	150	150	
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	
CONDENSATE TO COOLER, TEMPERATURE, °F	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	
CONDENSATE FROM COOLER, TEMPERATURE, °F	104	104	104	104	104	104	104	102	102	102	102	102	102	102	104	104	104	104	104	104	104	104	104	104	
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	130	130	130	130	130	128	128	128	128	128	128	130	130	130	130	125	125	125	128	128	128	
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	
AIR EJECTOR DRAINS, TEMPERATURE, °F																									
CIRC. WATER INJECTION, TEMPERATURE, °F	80	80	80	80	80	80	80	80	79	79	80	80	80	80	80	80	80	80	80	80	80	80	80	80	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																									
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																									
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																									
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	150	150	148	150	150	150	150	150	146	150	150	150	150	150	150	152	152	152	152	152	152	150	15		

DISTILLED WATER RECORD				REMARKS	
HOUR ENDING	METER READING	GALLONS			
		SHIPS TANKS*	FEED TANKS*		
	06830100				
0000					
0100	06852300	1700			
0200	06853900	1600			
0300	06855600	1600			
0400	06857200	1600			
0500	06859100	1900			
0600	06860800	1700			
0700	06862400	1600			
0800	06864000	1600			
0900	06865700	1700			
1000	06867400	1700			
1100	06868800	1400			
1200	06831500	1400			
1300	06833000	1500			
1400	06834100	1100			
1500	06836000	1500			
1600	06837800	1500			
1700	06839200	1700			
1800	06840800	1600			
1900	06842600	1800			
2000	06844200	1600			
2100	06845700	1500			
2200	06847300	1600			
2300	06849000	1700			
2400	06850600	1600			

SCALING RECORD				REMARKS	
	EFFECT				
	NO. 1	NO. 2	NO. 3		
DATE LAST SCALED					
HOURS BROUGHT FORWARD	48				
HOURS THIS DATE	24				
HOURS TO DATE	72				
GALLONS BROUGHT FORWARD	75,600				
GALLONS THIS DATE	38,700				
GALLONS TO DATE	114,300				
CHECKED (Signature)					
APPROVED					
(Engineer Officer, U. S. N.)					

REMARKS	
0000-0800 # 2 - EVAP DIST TO #35 ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>M. Roy Hill</u>	1200-1800 # 2 - EVAP DIST TO #35 ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>M. Roy Hill</u>
0800-1200 # 2 Evap. Dist. to #3 & Added 8 oz chlorine per 1000 gals. SIGNED <u>R. Shippard</u>	1600-2000 # 2 Evap. Dist. to #3 & still Added 8 oz chlorine per 1000 gals. dist. SIGNED <u>R. Shippard</u>
0800-1200 # 2 Evap. dist. to #3 & Added 8 oz. chlorine/1000 gal. Dist. about 1000 gal. to bilges. SIGNED <u>R.D. McBinnis</u>	2000-2400 # 2 Evap. dist. to #35 Added 8 oz. chlorine/1000 gal. SIGNED <u>R.D. McBinnis</u>

1 P 23'0" 2 P 23'0"
15 22'4" 25 21'3"

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY WHITE BEACH TO DANANGU. S. S. GEN. POPE (TAP 110)PLANT NO. 1

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE 25 July, 19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	10	10	10	8	8	8	8	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	2	2	2	2	2	2	2	2	3	3	3	2	1	1	1	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	1	1	1	0	0	0	1"	1"	1"	0	0	1	2	2	2	0	0	0	0	1	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	235	240	240	240	240	235	230	232	240	240	240	240	240	240	240	240	240	235	235	230	232	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195	195	197	198	198	198	198	198	198	195	194	195	195	202	202	202	198	195
1ST EFFECT SHELL PRESSURE, #HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15"	15"	15"	15"	15	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	162	162	162	162	158	158	158	158	158	158	158	158	164	164	164	164	160	158	156	158	158
2D EFFECT SHELL PRESSURE, #HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16"	16"	16"	16"	16	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	148	148	150	150	146	144	146	146	146	146	146	146	150	150	150	150	148	148	146	148	148
3D EFFECT SHELL PRESSURE, #HG	24	24	24	24"	24"	24"	24"	24	23	24	24	24	24	24	24	24"	24"	24"	24"	23	23	23	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	125	125	125	126	126	126	124	124	125	125	125	126	126	126	126	128	128	128	128	128	128	128	128	128
CONDENSATE FROM COOLER, TEMPERATURE, °F	95	95	95	96	96	96	94	94	94	94	94	98	98	98	98	98	98	98	98	98	98	98	98	98
BRINE OVERBOARD, TEMPERATURE, °F	126	126	126	120	120	120	118	118	118	120	120	126	126	126	126	125	125	125	125	126	126	125	125	126
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	86	86	86	85	85	85	83	80	79	79	80	85	85	85	85	88	88	88	88	88	88	87	87	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	86	86	86	85	85	85	83					85	85	85	85	88	88	88	88					84
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	162	162	162	162	162	162	162	158	158	158	158	162	162	162	162	162	162	162	162	162	160	162	162	162
CIRC. WATER OVERBOARD, TEMPERATURE, °F	105	105	105	106	106	106	104	104	103	103	103	105	105	105	105	108	108	108	108	108	108	108	108	108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	13	13	13	12	12	12	12	13	13	12	12	13	13	13	13	13	13	13	13	13	13	13	13	13
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	26	26	26	26	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	17	17	17	18	18	18	20	18	17	17	17	20	20	20	20	20	20	20	20	17	17	17	17	17
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	2	2	1	1	1
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	62	62	62	62	62	62	62	60	60	60	60	61	61	61	61	62	62	62	62	64	64	63	64	64
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	7	7	10	10	0	0	10	10	10	10	10	10	29	29	29
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	2	2	2	2	20	20	20	20	20	20	20	20	2	2	2	2	2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11904100		
0000			
0100	11911200	1200	
0200	11922400	1200	
0300	11923700	1300	
0400	11924800	1100	
0500	11926300	1600	1500
0600	11927500		1200
0700	11928200		1200
0800	11929900		1200
0900	11931200		1300
1000	11932500	1300	#
1100	11933800	1300	
1200	11935400	1300	
1300	11936600	1300	
1400	11937100	1200	
1500	11938000	1200	
1600	11940300	1300	
1700	11941600	1300	
1800	11942800		1200
1900	11944100		1300
2000	11945200		1100
2100	11946400		1200
2200	11947600		1200
2300	11948800		1200
2400	11942000	1200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	417		
HOURS THIS DATE	24		
HOURS TO DATE	441		
GALLONS BROUGHT FORWARD	619,200		
GALLONS THIS DATE	29,700		
GALLONS TO DATE	648,900		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	#1 EVAP DIST TO #35. ADDED 80% CHLORINE PER 1000 GALS SIGNED <u>McRae Hill</u>
0400-0800	@ 0400 #1 EVAP. DIST. TO #1 STD #1 port-23' - Test 2 Drops #1 std-23' - Test 2 Drops #2 port-23' - Test 2 Drops #2 std-23' - Test 2 Drops SIGNED <u>R. Sheppard</u>
0800-1200	#1 Evap. dist. to #15 @ 0900 shifted dist. to #35 SIGNED <u>RDS McDinnis</u>
1200-1600	#1 - EVAP DIST TO #35 ADDED 80% CHLORINE PER 1000 GALS SIGNED <u>McRae Hill</u>
1600-2000	#1 EVAP. DIST TO #3 STD @ 1700 #1 EVAP. DIST. TO #1 STD. FILL SIGNED <u>R. Sheppard</u>
2000-2400	#1 Evap. dist. to #15. @ 2210 shifted dist. to #35 SIGNED <u>RDS McDinnis</u>

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. POPE (TAP-110)

PLANT NO. 2

AT ANCHOR DA NANG

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE 26 July 1967

	7-27-67												7-26-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	7	8	8	7	7	8	8	8	8	8	8	7	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	3"	3"	3"	3"	3"	3"	3"	3"	3"	2"	3"	4"	4"	4"	4"	4"	4"	4"	4"	4"	2"	2"	2"	2"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"	1"
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	235	235	240	240	240	240	235	240	235	235	235	240	240	235	240	240	240	240	240	240	235	235	235
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	190	190	190	190	194	192	192	192	195	195	195	190	190	190	190	190	190	192	190	190	194
1ST EFFECT SHELL PRESSURE, "HG	8	8	8	7"	7"	7"	7"	7	7	7	7	7	7	7	7	7"	7"	7"	7"	7	5	5	5	8
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	164
2D EFFECT SHELL PRESSURE, "HG	20	20	20	20"	20"	20"	20"	20	20	20	20	20	20	20	20	20"	20"	20"	20"	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	154	154	154	152	150	150	150	152	152	152	152	148	148	148	148	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, "HG	25	26	26	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	136	136	136	136	136	136	136	136	136	136	136	136	132	132	132	134	134	134	134	136	136
CONDENSATE FROM COOLER, TEMPERATURE, °F	100	100	100	100	102	102	102	102	102	102	102	98	98	98	98	98	98	98	98	98	98	98	98	99
BRINE OVERBOARD, TEMPERATURE, °F	126	126	126	130	130	130	130	130	128	130	130	129	129	129	129	120	120	120	120	120	120	120	120	126
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	85	86	86	85	85	85	86	85	85	84	84	80	82	85	82	83	83	83	83	83	83	83	83	83
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	85	86	86	85	85	85	86					80	82	85	82	83	83	83	83	83				83
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	156	156	156	150	152	152	152	150	152	152	152	156	156	156	156	150	150	150	150	150	150	150	150	150
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	168	170	170	170	166	166	166	166	170	170	170	166	170	170	172	172	172	170	168	164	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	104	104	104	104	104	104	104	106	106
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	24	24	24	24	24	25	25	25	25	25	25	25	25	25	25	24	24	24	24	24	24	24	24	24
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	2"	2"	2"	2"	1	1	1	1	1	1	1	1	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	46	46	46	46	46	46	46	44	44	44	44	35	35	35	35	47	47	48	48	48	47	48	47	46
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	3	3	3	5	30	30	30	30	30	30	20	20	20	20	20	20	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.2
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	06868800	#3	
0000			
0100	06889700	1500	
0200	06891300	1600	
0300	06892900	1600	
0400	06894600	1700	
0500	06896200	1600	
0600	06897800	1400	
0700	06899300	1500	
0800	06900800	1500	
0900	06902100	1300	
1000	06903600	1500	
1100	06905100	1500	
1200	06869400	600	
1300	06871000	1600	
1400	06872600	1600	
1500	06874100	1500	
1600	06875600	1500	
1700	06877200	1400	
1800	06878800	1600	
1900	06880400	1600	
2000	06881900	1500	
2100	06883400	1500	
2200	06885000	1600	
2300	06886500	1500	
2400	06888200	1700	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	72		
HOURS THIS DATE	29		
HOURS TO DATE	96		
GALLONS BROUGHT FORWARD	114,300		
GALLONS THIS DATE	32,300		
GALLONS TO DATE	152,600		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	# 2 - EVAP DIST TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>McRoy Hill</u>
0400-0800	# 2 Evap. Dist. to #3 & Added 8 oz chlorine per 1000 gals SIGNED <u>R. Sheppard</u>
0800-1200	# 2 Evap. Dist. to #3 & Added 8 oz. chlorine per 1000 gal. SIGNED <u>PRD McRoy Hill</u>
1200-1600	# 2 EVAP DIST TO #3 S SHIPPED TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS SIGNED <u>McRoy Hill</u>
1600-2000	# 2 Evap. Dist. to #3 & 16 Added 8 oz chlorine per 1000 gals SIGNED <u>R. Sheppard</u>
2000-2400	# 2 Evap. dist. to #3 & Added 8 oz. chlorine per 1000 gal. SIGNED <u>CRD McRoy Hill</u>

905100
865800
38300
6100

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. POPE (TAP-110)

PLANT NO. 1

AT ANCHOR DA NANG

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE 26 July 1967

	7-27-67												7-26-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	9	9	9	9	9	9	9	9	9	9	9	9	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3	3	3	3	3	4	3	3	2	2	2	2	2	3	3	3	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	1	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	230	235	240	240	240	240	235	235	230	230	230	230	230	230	240	240	240	240	240	235	230	225	225
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	198	198	198	198	200	200	200	200	190	190	190	190	195	195	195	195	195	195	195	200	195
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	14"	14"	14"	14	14	14	14	14	14	14	14	14"	14"	14"	14"	14	14	14	14	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	164	164	164	164	164	164	160	162	158	158	158	158	164	164	164	164	164	164	164	164	160
2D EFFECT SHELL PRESSURE, "HG	16	16	16	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15"	15"	15"	15"	15	15	15	15	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	150	150	150	150	150	148	148	148	148	148	148	148	152	152	152	152	152	152	152	148	148
3D EFFECT SHELL PRESSURE, "HG	23	23	23	24"	24"	24"	24"	23	23	23	23	23	23	23	23	24"	24"	24"	24"	24	24	24	23	23
CONDENSATE TO COOLER, TEMPERATURE, °F	126	126	126	126	126	126	126	126	126	126	126	122	122	122	122	124	124	124	124	124	124	124	124	126
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	97	97	97	97	97	97	97	97	97	97	94	94	94	94	94	94	94	94	98
BRINE OVERBOARD, TEMPERATURE, °F	122	122	122	120	120	120	120	122	122	122	122	124	124	124	124	118	118	118	118	118	118	120	120	122
STEAM TO AIR EJECTOR, PRESSURE #G	92	92	92	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	85	86	86	86	85	85	86	85	84	84	84	82	82	82	82	83	83	83	83	83	83	82	84	84
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	85	86	86	85	85	85	86					82	82	82	82	83	83	83	83	83				84
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	162	162	162	162	160	162	160	160	160	160	160	160	160	162	162	162	162	160	158	160	160
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	106	108	108	108	108	108	109	108	108	108	104	104	104	104	104	104	104	104	104	104	103	104	104
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	12	12	12	12	12	12	12	13	13
BRINE PUMP SUCTION PRESSURE, #G	20	20	20	20"	20"	20"	20"	20	20	20	20	20	20	20	20	20"	20"	20"	20"	20	20	20	20	20
BRINE PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	20	19	20	20	19	18	18	18	18	20	18	18	18	18	19	19	18	18
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	63	63	63	65	65	60	60	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	63	63
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	8	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11933800		
0000			
0100	11951800	1300	
0200	11953100	1300	
0300	11954400	1300	
0400	11955800	1400	
0500	11957200	1400	1400
0600	11958500		1300
0700	11959800		1300
0800	11960900		1100
0900	11962200		1300
1000	11963400		1200
1100	11964700	1300	
1200	11935100	1300	
1300	11936400	1300	
1400	11937700	1300	
1500	11938900	1200	
1600	11940200	1300	
1700	11941500	1300	
1800	11942800	1300	
1900	11944100	1300	
2000	11945300	1200	
2100	11946600	1300	
2200	11947900	1300	
2300	11949200	1300	
2400	11950500	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	441		
HOURS THIS DATE	29		
HOURS TO DATE	465		
GALLONS BROUGHT FORWARD	698,900		
GALLONS THIS DATE	16,100		
GALLONS TO DATE	671,800		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	1200-1600
# I EVAP DIST TO #3 & POT	# I EVAP DIST TO #3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS	SHIFTED TO # & POT
	ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED <u>M. R. Hall</u>	SIGNED <u>M. R. Hall</u>
0400-0800	1600-2000
@ 0400 #1 EVAP. DIST. TO #1 STBL	#1 EVAP. DIST. TO #3 &
	ADDED 8 OZ CHLORINE PER 1000 GALS
#1 part. 23' - Test 2 drops	
#1 STBL 21' - Test drops	
#2 part. 23' - Test 2 drops	
#2 STBL 21' - Test 2 drops	
SIGNED <u>R. Shippard</u>	SIGNED <u>R. Shippard</u>
0800-1200	2000-2400
#1 Evap. dist to #1 S	#1 Evap. dist. to #3 &
@ 1030 shifted dist. to #3 &	Added 8 oz. chlorine per gal.
SIGNED <u>E. E. McDaniel</u>	SIGNED <u>E. E. McDaniel</u>

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY DA NANG TO HONG TAUU. S. S. GEN. ROPE (TAP-110)PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE 27 July, 1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	1"	1"	1"	1"	1"	1"	0	0	0	0	0	0	1"	1"	1"	1"	1"	1"	1"	1"	1"
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	240	240	240	240	240	240	240	215	230	230	230	230	230	230	240	240	240	240	240	240	240	235	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	190	190	190	190	192	192	190	190	190	190	190	190	190	190	190	190	190	190	190	192	190
1ST EFFECT SHELL PRESSURE, "HG	8	8	8	7"	7"	7"	7"	7	6"	7"	7	8	8	8	7	8"	8"	8"	8"	8"	8	8	8	8
2D EFFECT COIL DRAIN, TEMPERATURE, °F	161	161	162	164	164	164	164	162	164	162	162	164	164	164	164	166	166	166	166	166	166	166	166	166
2D EFFECT SHELL PRESSURE, "HG	20	20	20	20"	20"	20"	20"	20	21"	21"	21	20	20	20	20	20"	20"	20"	20"	20"	20"	20"	20"	20"
3D EFFECT COIL DRAIN, TEMPERATURE, °F	145	145	145	148	148	148	148	148	146	146	146	146	146	146	146	148	148	148	148	150	150	148	146	146
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	27"	27"	27	25	25	25	25	25"	25"	25"	25"	25"	25"	25"	25"	25"
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	132	132	132	132	132	132	130	130	132	132	132	132	132	132	132	132	132	132	132	132	130
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	98	98	98	98	98	98	98	98	96
BRINE OVERBOARD, TEMPERATURE, °F	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	94	94	92	92	92	90	90	90	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	82	82	82	83	83	83	82	83	83	83	83	82	82	82	82	85	80	81	82	82	80	80	80	81
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	82	82	82	83	83	83	82					82	82	82	82	85	80	81	82	82				81
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	145	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25"	25"	25"	25"	25"
BRINE PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3"	3"	3"	3"	3"	3	3	3	3"	2"	2	0	0	0	0	0	0	0	0	0	-2	-2	-2	✓
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	44	44	44	44	44	44	44	42	42	41	41	41	41	41	41	41	41	41	41	41	41	41	41	41
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	9	28	28	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	10	10	10	10	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	05405100		
0000			
0100	06923100	1400	
0200	06928600	1500	
0300	06930200	1600	
0400	06931600	1400	
0500	06933100	1560	
0600	06934600	1500	
0700	06936100	1500	
0800	06937400	1500	
0900	06938700	1300	
1000	06940100	1400	
1100	06941600	1500	
1200			
1300	06946900	1600	
1400	06948300	1600	
1500	06949000	1700	
1600	06949000	1700	
1700	06949000	1500	
1800	06949000	1700	
1900	06949000	1700	
2000	06948200	1400	
2100	06949700	1500	
2200	06921200	1500	
2300	06922700	1500	
2400	06924200	1500	
	06925100	1400	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	96		
HOURS THIS DATE	23		
HOURS TO DATE	119		
GALLONS BROUGHT FORWARD	150,000		
GALLONS THIS DATE	36,500		
GALLONS TO DATE	187,100		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	1200-1600
# 2 - EVAP DIST TO # 3 & Pot ADDED 8.52 CHLORINE PER 1000 GALS SIGNED <u>M. R. Hill</u>	# - 2 - EVAP DIST TO # 3 & Pot ADDED 8.52 CHLORINE PER 1000 GALS SIGNED <u>M. R. Hill</u>
0400-0800	1600-2000
# 2 Evap. Dist. To # 3 & Add-d 8.02 chlorine per 1000 Gals. SIGNED <u>R. Shippard</u>	# 2 Evap. Dist. To # 3 & Add-d 8.02 chlorine per 1000 Gals. SIGNED <u>R. Shippard</u>
0800-1200	2000-2400
# 2 Evap. dist. to # 3 & Added 8 oz. chlorine/1000 gal. @ 1025 shifted dist. to # 15. @ 1115 Sec. # 2 Evap. SIGNED <u>RDS Medina</u>	# 2 Evap. dist. to # 3 & SIGNED <u>RDS Medina</u>

06941600
05100
36500

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY DA NANG TO VUNG TAUU. S. S. GEN. POPE (TAP-110)PLANT NO. 1

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE 27 July, 19 67

	HOUR ENDING																								
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	
STEAM TO REG. VALVE, PRESSURE, #G	4	4	4	4	4	4	4	4				0	4	4	4	4	4	4	4	4	4	4	4	4	
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	2	2	2	2	2				2	3	3	3	3	3	3	3	3	3	3	3	3	
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	2	0	0	0	0	0	0	0				1	1	1	1	0	0	0	0	0	0	0	0	0	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	235	235	235	235	230				230	231	230	230	240	230	235	235	235	235	230	230	225	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	200	200	200	200	200	196	196	198				190	190	190	190	198	198	198	200	200	200	195	197	200	195
1ST EFFECT SHELL, PRESSURE, #HG	14	14	14	14	14	14	14	17				14	14	14	14	14	14	14	14	14	14	14	14	14	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	164	164	164	164	164				158	158	158	158	162	164	164	164	164	160	160	158	158	
2D EFFECT SHELL, PRESSURE, #HG	16	16	16	16	16	16	16	16				16	16	16	16	16	16	16	16	16	16	16	16	16	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	150	150	150	150	148				148	148	148	148	150	150	150	150	150	146	146	146	146	
3D EFFECT SHELL, PRESSURE, #HG	24	24	24	24	24	24	24	24				24	24	24	24	24	24	24	24	24	24	24	24	24	
CONDENSATE TO COOLER, TEMPERATURE, °F	122	122	122	122	122	122	122	122				124	124	124	124	124	124	124	122	122	124	124	124	120	
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94				94	94	94	94	94	94	94	92	92	92	92	92	92	
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	120	120	120	120	122				120	120	120	120	120	120	118	118	120	120	122	122	120	
STEAM TO AIR EJECTOR, PRESSURE, #G	4	4	4	4	4	4	4	4				4	4	4	4	4	4	4	4	4	4	4	4	4	
AIR EJECTOR DRAINS, TEMPERATURE, °F																									
CIRC. WATER INJECTION, TEMPERATURE, °F	82	82	82	83	83	83	82	83				82	82	82	82	75	80	81	82	82	80	80	80	81	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	82	82	82	83	83	83	82					82	82	82	82	75	80	81	82	82				81	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																									
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																									
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																									
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																									
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	160	160	160	160	162				160	160	160	160	158	160	162	162	162	160	158	156	156	
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	104	104	104	104	104	104				104	104	104	104	98	102	102	104	104	102	102	100	104	
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3				3	3	3	3	3	3	3	3	3	3	3	3	3	
CIRC. PUMP DISCHARGE PRESSURE, #G	13	13	13	13	13	13	13	13				13	13	13	13	13	13	13	13	13	13	13	13	13	
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25				20	20	20	20	25	25	25	25	25	26	26	26	26	
BRINE PUMP DISCHARGE PRESSURE, #G	19	19	19	20	20	20	20	19				20	20	20	20	20	20	20	20	20	19	19	19	19	
FEED PUMP SUCTION PRESSURE, #G																									
FEED PUMP DISCHARGE PRESSURE, #G																									
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	1				1	1	1	1	0	0	0	1	1	1	1	1	1	
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	61	61	61	61	61	61	61	61				62	62	62	62	62	62	61	61	61	62	62	62	61	
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	30				10	10	10	10	10	10	10	10	10	8	8	8	10	
FEED DENSITY, 32NDS																									
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05				1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	2				20	20	20	20	20	20	20	20	2	2	2	2	20	
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0				0	0	0	0	0	0	0	0	0	0	0	0	0	

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	11964700	#34	
0000			
0100	11982900	1200	
0200	11983900	1200	
0300	11985200	1300	
0400	11986400		1200
0500	11987600		1200
0600	11988900		1300
0700	11990100		1200
0800	11991100		1000
0900			
1000			
1100			
1200	11966100	1400	
1300	11967500	1400	
1400	11968800	1300	
1500	11970200	1400	
1600	11971600	1400	
1700	11972900		1300
1800	11974200		1300
1900	11975500		1300
2000	11976700	1200	
2100	11977800	1100	
2200	11979000	1200	
2300	11980300	1300	
2400	11981500	1200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	415		
HOURS THIS DATE	21		
HOURS TO DATE	486		
GALLONS BROUGHT FORWARD	21,800		
GALLONS THIS DATE	26,900		
GALLONS TO DATE	706,200		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	1200-1800
#1 EVAP DIST TO #3 & #4	#1 EVAP DIST TO #3 & #4
SHIFTED TO #1 STBD FEED @ 0240	ADDED 50Z CHLORINE PER 1000 GALS
SIGNED <u>M. Ray Hill</u>	SIGNED <u>M. Ray Hill</u>
0400-0800	1800-2000
#1 Evap. Dist to #1 & #2 STBD FEED	#1 Evap. Dist. to #1 STBD FEED
#1 part. 23' - Test 2 drops	
#1 6+66- 21' - Test 2 drops	
#2 part. 23' - Test 2 drops	
#2 6+66- 21' - Test 2 drops	
SIGNED <u>R. Shippard</u>	SIGNED <u>R. Shippard</u>
0800-1200	2000-2400
#1 Evap. Dist. to #1 & #2 STBD FEED	#1 Evap. Dist. to #3 & #4
Sec. Evap @ 0845	
SIGNED <u>R.D. McLean</u>	SIGNED <u>R.D. McLean</u>

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY VUNG TAU TO DA NANGU. S. S. GEN. POPE (TAP-110)PLANT NO. 1

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE

July 29, 1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	7	9	9	9	9	9	9	9		9	9	10	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	3		3	3	3	3	3	3	3	3	3		3	3	3	3	3	3	3	4	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G			1	1	1	1	1	1	1	1	1		2	1	1	1	1	1	1	1	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	242	242	237	240	240	240	240	240	230	222	220		234	234	240	240	240	240	240	240	230	230	230	205
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	205	200	200	200	200	200	200	200	202	203	203		184	184	190	200	200	200	200	200	203	203	203	203
1ST EFFECT SHELL, PRESSURE, "HG	15		15	15	15	15	15	15	15	15	15		13	14	14	14	14	14	14	15	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	160	160	160	160	158	158	158	158		160	158	160	160	160	162	162	160	158	158	158	158
2D EFFECT SHELL, PRESSURE, "HG	16	16	16	16	16	16	16	16	16	16	16		15	16	16	16	16	16	16	16	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	150	150	150	150	148	148	148	148		146	148	148	150	150	150	150	148	148	148	148	148
3D EFFECT SHELL, PRESSURE, "HG	24	24	24	24	24	24	24	24	24	24	24		24	24	24	24	24	24	24	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	124	124	124	124	125	125	125	125	125	125	125		119	119	120	120	120	120	122	122	122	122	122	122
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	96	96	96	98		90	90	90	90	90	90	92	92	92	92	92	92
BRINE OVERBOARD, TEMPERATURE, °F	115	115	115	118	118	118	118	118	118	120	120		114	114	115	115	115	115	115	115	115	115	115	115
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94		94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	84	84	84	84	84	84	84	84	84	84	84		80	80	81	81	81	81	81	82	83	84	82	83
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	84	84	84	84	84	84	84						80	80	81	81	81	81	81					83
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	158	160	160	160	160	158	158	158		158	158	160	160	160	162	162	162	160	158	158	158
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106		106	106	104	104	104	104	104	104	103	103	103	103
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	12		3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12		12	12	12	12	13	12	12	13	13	13	13	13
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25		24	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	19	19	19	20	20	19	19	18	18	18	18		22	22	24	20	20	20	20	17	19	19	19	19
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	6	6	6	0	1	2	2	2	2	2	2		1	1	1	1	1	1	1	1	2	2	2	1
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	62	62	62	62	61	61	61	60	60	60	61		62	62	63	62	62	62	62	62	63	63	63	63
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10		10	10	10	10	10	10	10	29	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02	1.02	1.02	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05		1.02	1.02	1.02	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0		0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD				REMARKS	
HOUR ENDING	METER READING	GALLONS		0000-0400	1200-1600
		SHIPS TANKS*	FEED TANKS*		
	11791100			# - EVAP DIST TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS. SIGNED <u>Mc Ray Hill</u>	Seeded # I - EVAP DIST TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS LIT OFF AT EVAP 1215 SIGNED <u>Mc Ray Hill</u>
0000					
0100	12005600	1300			
0200	12008100	1100			
0300	12008800	1300			
0400	12009200	1200			
0500	12010000		1300		
0600	12011700		1200		
0700	12013000		1300		
0800	12014200		1200		
0900	12015500		1300		
1000	12016700		1200		
1100	12018000		1300		
1200				0400-0800 #1 Evap. Dist. to #1 still prod #1 port 23 - Test 2 drops #1 still 11 - Test 2 drops #2 port 23 - Test 2 drops #2 still 20 - Test 2 drops SIGNED <u>R. Sheppard</u>	1200-2000 #1 Evap. Dist. to #3 & Add 8 oz chlorine per 1000 gals. SIGNED <u>R. Sheppard</u>
1300	11992000	500			
1400	11992500	500			
1500	11993000	1100			
1600	11994900	1100			
1700	11996000	1100			
1800	11997200	1200			
1900	11998400	1200			
2000	11999600	1200			
2100	12000700	1100			
2200	12001800	1100			
2300	12003000	1200			
2400	12004500	1300			

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD				0800-1200		2000-2400	
	EFFECT			#1 Evap. dist. to #1 s	#1 Evap. dist. to #3 & Added 8 oz. chlorine/1000 gal.		
	NO. 1	NO. 2	NO. 3				
DATE LAST SCALED							
HOURS BROUGHT FORWARD	486						
HOURS THIS DATE	23						
HOURS TO DATE	1509						
GALLONS BROUGHT FORWARD	706,200						
GALLONS THIS DATE	26,900						
GALLONS TO DATE	733,100						
CHECKED (Signature)							
APPROVED							
(Engineer Officer, U. S. N.)				SIGNED <u>RDS McQuinn</u>	SIGNED <u>RDS McQuinn</u>		

12018000
11791100
26900

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY VUNG TAU TO DA NANGU. S. S. GEN. POPE (TAP-110)PLANT NO. 1

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE 30 July, 19 67

	7-31-67												7-30-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	4	10	10	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	240	240	240	240	240	230	230	225	228	229	225	240	240	240	240	240	240	230	228	228	228	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	200	200	200	204	205	205	204	203	204	203	203	200	200	200	200	200	200	200	205	202	203	203	203	200
1ST EFFECT SHELL PRESSURE, #HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15	15"	15"	15"	15"	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	166	160	162	162	160	158	158	158	160	158	158	158	160	160	162	162	160	158	158	158	158
2D EFFECT SHELL PRESSURE, #HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16	16"	16"	16"	16"	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	150	150	150	150	148	148	146	146	148	148	146	146	150	150	150	150	148	146	146	146	140
3D EFFECT SHELL PRESSURE, #HG	24	24	24	24"	24"	24"	24"	24	24	24	24	24	24	24	24	24	24"	24"	24"	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	125	125	125	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	122
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
BRINE OVERBOARD, TEMPERATURE, °F	118	118	118	118	118	118	118	118	118	120	120	120	120	118	118	118	118	118	118	118	118	118	118	118
STEAM TO AIR EJECTOR, PRESSURE, #G	91	91	91	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	156	156	156	156	156	156	156	156	156	156	160	160	160	160	160	160	160	160	158	156	156	156	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	104	104	104	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	3	3	3	2	2	2	2	3	3	3	3	3	3	3	3	3	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	13	12	12	12	12	12	12	12	12	12	12	12	12	12	12
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	26	26	25	25	25	25	25	25"	25"	25"	25	25	26	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	17	17	17	18	18	18	18	17	18	18	17	19	19	19	19	18	18	18	18	17	17	17	17	17
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	2	2	2	2	1	1	1	1	1	1	1	1	2	2	2	2	2
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	63	63	63	62	62	62	62	63	63	63	63	60	60	60	60	61	61	61	61	63	63	63	63	63
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	30	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.1	0.1	0.1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	12018000		#15
0000			
0100	12034700	1300	
0200	12035900	1200	
0300	12037100	1200	
0400	12038200	1100	
0500	12039400		1200
0600	12040400		1200
0700	12041700		1100
0800	12042900		1200
0900	12043900		1000
1000	12044900	1000	1000
1100	12046100	1200	1200
1200	12049000	1300	1300
1300	12050600	1300	1300
1400	12051800	1200	1200
1500	12053000	1200	1200
1600	12054200		1200
1700	12055300		1100
1800	12056500		1200
1900	12057600		1100
2000	12058800		1200
2100	12060000		1200
2200	12061100		1100
2300	12062300		1200
2400	12063400	1100	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	1509		
HOURS THIS DATE	24		
HOURS TO DATE	1533		
GALLONS BROUGHT FORWARD	733,100		
GALLONS THIS DATE	28,100		
GALLONS TO DATE	761,200		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

7-31-67
#1 EVAP DIST TO #39 POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M. R. Ray

0800-0800
08400 #1 Evap. dist. to #142 6/66
#1 port - 22' - Test 2 drops
#1 6/66 - 22' - Test 2 drops
#2 port - 23' - Test 2 drops
#2 5/66 - 22' - Test 2 drops
SIGNED R. Sheppard

0800-1200
#1 Evap. dist. to #15
@0915 shifted dist. to #3 &
Added 8 oz. chlorine 1000 gal.
SIGNED R. S. McQuinn

REMARKS 7-30-67
#1 EVAP DIST TO #1 SIBD FEED
SIGNED M. R. Ray

1200-1900
#1 Evap. dist. to #1 5/66 - Feed
SIGNED R. Sheppard

2000-2400
#1 Evap. dist. to #15 Feed.
@2300 shifted to #3 &
SIGNED R. S. McQuinn