

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. POPE (TAP-110)

PLANT NO. 1

AT ANCHOR LAUS BANG

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE 31 July 1967

	8-1-67												2-31-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	10	10	9	9	9	9	9	9	9	9	9	10	9	9	9	9	9	9	9	1	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	1	1	1	1	1	1	1	1	3	3	3	3	3	3	3	1	2	1	1	1	1
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2"	2"	2"	2"	2"	2"	2"	2"	1	1	1	1	1	1	0	1"	1"	0	0	0	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	216	216	216	220	220	220	225	225	206	205	210	235	230	235	235	235	235	235	220	240	218	212	214	220
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	190	200	195	195	195	195	198	200	200	200	200	200	200	200	200	200	198	198	200	198	198	198
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	15"	15"	15"	15	15	15	15	15	15	15	15	15	15	15	15	15	15	16	16	14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	159	159	159	164	160	160	160	160	158	160	160	160	160	160	160	160	160	160	158	155	156	154	153	160
2D EFFECT SHELL PRESSURE, "HG	5	5	5	15"	16"	16"	16"	16	16	16	16	16	16	16	16	16	16	16	16	16	16	17	17	15
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	145	150	150	150	150	150	146	148	148	148	148	148	148	148	148	148	148	144	145	143	144	150
3D EFFECT SHELL PRESSURE, "HG	24	24	24	24"	24"	24"	24"	24	23	23	23	23	23	23	23	23	23	23	24	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	120	120	120	120	120	124
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	97	97	97	97	97	97	97	97	94	94	94	94	94	90
BRINE OVERBOARD, TEMPERATURE, °F	122	122	122	118	118	118	118	118	118	120	120	121	120	120	120	120	120	120	115	115	115	115	115	122
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	80	80	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	156	156	156	156	156	156	159	159	159	159	159	159	159	159	159	159	159	156	156	156	156	156	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	104	104	104	104	104	106	107	107	107	107	107	107	107	107	107	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	2	3	2	2	2	2	2	2	2	3	3	3	3	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	19	19	19	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	2"	2"	2"	2	2	2"	3"	3"	2	2	2	2	2	2	2	2	2	2	1	1"	0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	60	60	59	50	48	46	44	44	40	42	42	43	43	42	40	40	40	40	40	40	40	40	40	40
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	9	30	9	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	12046700		
0000			
0100	12046580	1300	
0200	12046700	1200	
0300	120463900	1200	
0400	12045100	1200	
0500	12046400	1300	
0600	12047700	1300	
0700	12048900	1200	
0800	12070000	1100	
0900	12071200	1200	
1000	12072400	1200	
1100	12073400	1000	
1200	12047300	1200	
1300	12048400		1100
1400	12049500		1100
1500	12050600		1100
1600	12051700		1100
1700	12052800		1100
1800	12053900		1100
1900	12054900		1000
2000	12055900	1000	
2100	12057000	1100	
2200	12058100	1100	
2300	12059200	1100	
2400	12060200	1100	

* Indicate under REMARKS number of tanks being filled.

8-1-67
#1 EVAP DIST TO #3 & PAT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED McRay Hill

0800-0900 #1 Evap. Dist. TO #3 &
Added 8 oz chlorine per 1000 gals.
#1 port - 22' - 7x st 2 drops
#1 6x6d - 20' - 7x st 2 drops
#2 port - 23' - 7x st 2 drops
#2 6x6d - 23' - 7x st 2 drops
SIGNED R. Shippard

0800-1200 Dist. to #3 &
Added 8 oz. chlorine/1000 gal.
SIGNED R. S. McInnis

REMARKS 7-31-67
#1 EVAP DIST TO #1 STBD FRED
SHIFTED TO #1 STBD FRED 1300
SIGNED McRay Hill

1200-1600 #1 Evap. Dist. TO #2 6x6d - Fred
@1900 shifted dist. TO #3 &
SIGNED R. Shippard

2000-2400 Dist. to #3 &
Added 8 oz. chlorine/1000 gal.
SIGNED R. S. McInnis

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	1533		
HOURS THIS DATE	24		
HOURS TO DATE	1557		
GALLONS BROUGHT FORWARD	761,200		
GALLONS THIS DATE	17,300		
GALLONS TO DATE	788,500		
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. POPE (TAP-110)PLANT NO. 1AT ANCHOR DA NANG

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS MINUTES AT

DATE

1 August 1969

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	9	9					9	9	10	10	10	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	1	1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	3"	3"	3"	3"	3"	3"	3"					2"	2"	2"	2"	2"	2"	2"	2"	2"	2"	2"	2"	3"
STEAM TO 1ST EFFECT, TEMPERATURE, °F	218	218	218	220	220	220	225					216	216	218	218	205	220	220	220	230	205	205	210	210
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195					195	195	195	195	198	195	195	195	195	198	195	197	195
1ST EFFECT SHELL PRESSURE, "HG	15"	14"	14"	15"	15"	15"	15"					15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"	15"
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	162	164	164	164					158	158	158	158	158	164	164	164	168	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	16"	16"	16"	16"	16"	16"	16"					16"	16"	16"	16"	16"	16"	16"	16"	16"	16"	16"	16"	16"
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	150	150	150	150					148	148	148	148	148	150	150	150	152	150	146	146	148
3D EFFECT SHELL PRESSURE, "HG	24"	24"	24"	24"	24"	24"	24"					24"	24"	24"	24"	24"	24"	24"	24"	24"	25"	25"	24"	24"
CONDENSATE TO COOLER, TEMPERATURE, °F	126	126	126	124	124	124	124					124	124	124	124	124	126	126	126	130	129	129	129	126
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	95	96	95	96					96	96	96	96	96	96	96	96	98	97	97	97	96
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	118	118	118	115					121	121	121	121	122	120	120	120	124	122	122	122	110
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92					92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	84	84	84	83	82	80	75					84	84	84	84	84	84	84	84	84	84	84	85	84
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	84	84	84	83	82	80	75					84	84	84	84	84	84	84	84	84	84	84	85	84
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	154	154	154	154	154	154	154					154	154	154	154	154	154	154	154	154	152	154	156	155
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	106	106	106	106	104					108	108	108	108	107	106	106	106	107	107	107	109	108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	2	2	2	2					2	2	2	2	2	2	2	2	2	2	2	3	2
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12					12	12	12	12	12	12	12	12	12	12	12	12	12
BRINE PUMP SUCTION PRESSURE, #G	24	24	24	25"	25"	25"	25"					25"	25"	25"	25"	25"	25"	25"	25"	25"	25"	25"	25"	25"
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	24	24	22	22					20	20	20	20	20	20	20	20	20	23	13	22	10
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	2	1	2"	2"	2"	2"					2	2	2	2	2	2	2	2	2	3"	3"	4"	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	40	40	40	40	40	40	38					40	40	40	40	40	40	40	40	40	35	35	35	40
F. W. PUMP DISCHARGE PRESSURE	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0	0	0	0	0	0
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
<i>Chemical Test</i>	3.0	3.0	3.0	3.0	3.0	3.0	3.0					3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.02	0.02	0.02	0.02	0.02	0.02	0.02					0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	12073400	34	
0000			
0100	12090200	1300	
0200	12091600	1400	
0300	12092300	1300	
0400	12094100	1200	
0500	12095400	1300	
0600	12096700	1300	
0700	12098000	1300	
0800	12099100	1100	
0900	12100500	1400	
1000	12101800	1300	
1100	12103100	1300	
1200	12094700		1300
1300	12095900		1200
1400	12097200		1300
1500	12098500		1300
1600	12079500		1000?
1700	12080800		1300
1800	12082000	1200	
1900	12083200	1200	
2000	12084400	1200	
2100	12085500	1100	
2200	12086100	600	
2300	12087600	1500	
2400	12088900	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	1557		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	788,500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS	
0000-0400	#1 EVAP DIST TO #1 3000 GAL #3 & POT SIGNED <u>McRay Hill</u>
0400-0800	#1 Evap. Dist. TO #1 & 2 Added 8 oz chlorine per 1000 gals #1 port. 22' - Test 2 drops #1 6' 6" - 19' - Test drops #2 port. 22' - Test 2 drops #2 6' 6" - 22' - Test 2 drops SIGNED <u>P. Sheppard</u>
0800-1200	#1 EVAP. DIST. TO #3 CENTER --- Added 8 oz. chlorine per 1000 gals. DIST. SIGNED <u>E. J. McFall</u>
1200-1600	Dist. to #3 & 1145 shifted dist. to #15 SIGNED <u>McRay Hill</u>
1600-2000	#1 Evap. Dist. TO #1 6' 6" - F and @1700 Shifted Dist. TO #3 & Added 8 oz chlorine per 1000 gals Dist. SIGNED <u>P. Sheppard</u>
2000-2400	Dist. to #3 & Added 8 oz. chlorine 1000 gal. @2040 Brine pump lost suction once. Donnowhly. SIGNED <u>E. J. McFall</u>

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY XU. S. S. Green Lake T-AP-110PLANT NO. 2

AT ANCHOR _____

TIME: ZONE DESCRIPTION _____

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT _____

DATE 8-2-19 67

	8-3-67								8-2-67															
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	7	7	7	7	7	7	7																	7
STEAM FROM REG. VALVE, PRESSURE, #G	4"	4"	4"	4"	4"	4"	4"																	4"
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	1	1	1	1	1	1	1																	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	214	214	214	220	220	220	220																	210
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	195	195	195	196																	190
1ST EFFECT SHELL PRESSURE, #HG	6	6	6	6"	6"	6"	6"																	6
2D EFFECT COIL DRAIN, TEMPERATURE, °F	168	168	168	172	172	172	174																	168
2D EFFECT SHELL PRESSURE, #HG	21	21	21	20"	20"	20"	20"																	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	156	156	156	156																	156
3D EFFECT SHELL PRESSURE, #HG	21	21	21	23"	23"	23"	23"																	21
CONDENSATE TO COOLER, TEMPERATURE, °F	146	146	146	142	142	144	144																	140
CONDENSATE FROM COOLER, TEMPERATURE, °F	105	105	105	102	102	104	104																	108
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130																	126
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94																	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	86	86	86	87	87	87	87																	87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	86	86	86	87	87	87	87																	87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	160	160	160	160	160	162	162																	160
FEED TO 1ST EFFECT, TEMPERATURE, °F	174	174	174	174	174	174	174																	174
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	106	106	108	108																	10
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	2	2	2	2																	4
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18																	18
BRINE PUMP SUCTION PRESSURE, #G	21	21	21	22"	22"	22"	22"																	22
BRINE PUMP DISCHARGE PRESSURE, #G	18	18	18	20	20	20	20																	15
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	4"	4"	4"	3"	3"	3"	3"																	4"
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35																	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10																	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02	1.02	1.02	1.02	1.02	1.02	1.02																	1.02
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.4	0.4	0.4	0.3	0.3	0.3	0.3																	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0																	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

2

DISTILLED WATER RECORD				REMARKS	
HOUR ENDING	METER READING	GALLONS		0000-0400	1200-1800
		SHIPS TANKS*	FEED TANKS*		
0000				# 2 - EVAP DIST TO # 3d POT	
0100	06944000	1500			
0200	06946000	1400		0300 SHIFTED TO # 3 PORT POT	
0300	06947500	1500			
0400	06949000	1500		ADDED 8 OZ CHLORINE PER 1000 GALS	
0500	06950500	1560			
0600	06951600	1100			
0700	06953000	1400		0345 SHIFTED TO FWD PEAK	
0800	06954200	1200			
0900	06955500	1300		SIGNED <u>McRoy Hill</u>	SIGNED _____
1000	06956900	1400			
1100	06958300	1400			
1200					
1300				0400-0800 # 2 Evap. Dist. to fwd peak	1800-2000
1400				Added 8 oz chlorine per 1000 Gals	
1500					
1600					
1700					
1800					
1900					
2000					
2100					
2200					
2300					
2400	06943100	1400			
* Indicate under REMARKS number of tanks being filled.				SIGNED <u>R. Chappard</u>	SIGNED _____
SCALING RECORD				2000-2400	
	EFFECT			0800-1200	
	NO. 1	NO. 2	NO. 3		
DATE LAST SCALED				# 2 Evap. Dist. to	
HOURS BROUGHT FORWARD				Forward Peak	
HOURS THIS DATE				Added 8 oz chlorine	
HOURS TO DATE				per 1000 gals Dist.	
GALLONS BROUGHT FORWARD					
GALLONS THIS DATE				SIGNED <u>E. A. McRoy</u>	SIGNED _____
GALLONS TO DATE					
CHECKED (Signature)					
APPROVED					
(Engineer Officer, U. S. N.)					

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. JOHN Dope

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

MINUTES AT

DATE

8-7-67

	8-3-67								8-2-67															
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	10	10	10	10					9	9	9	9	9	8	8	8					8
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	1	1	1	1					1	1	1	1	1	1	1	1					1
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2"	2"	2"	2"	2"	2"	2"					3	3	3"	3"	2"	2"	2"	2"					2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	224	220	220	220	220	220	220					220	220	218	218	214	210	210	210					220
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	230	225	225	195	195	195	195					220	220	190	190	200	200	200	200					200
1ST EFFECT SHELL PRESSURE, "HG	14	14	14	14"	14"	14"	14"					14	14	14	14	14"	14"	14"	14"					14
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	160	160	162	162	162	164					160	160	160	160	164	164	164	164					160
2D EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"					16	16	16	16	16"	16"	16"	16"					16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	145	150	150	150	152					148	148	148	148	150	150	150	150					148
3D EFFECT SHELL PRESSURE, "HG	23	23	23	23"	23"	23"	23"					23	23	23	23	23"	23"	23"	23"					23
CONDENSATE TO COOLER, TEMPERATURE, °F	128	128	128	128	128	128	128					130	130	130	130	130	126	127	127					128
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	98	98					98	98	98	98	98	96	96	97					98
BRINE OVERBOARD, TEMPERATURE, °F	124	124	124	118	118	118	118					122	122	122	122	120	120	120	120					124
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92					92	92	92	92	92	92	92	92					92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	80	86	86	87	87	87	87					84	84	84	84	84	84	85	85					87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	80	86	86	87	87	87	87					84	84	84	84	84	84	85	85					87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	160	160	162	160					160	160	162	162	160	160	158	158					160
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	108	108					110	110	110	110	106	106	106	106					106
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3					14	14	14	14	13	13	13	13					13
CIRC. PUMP DISCHARGE PRESSURE, #G	13	13	13	13	13	13	13					14	14	14	14	13	13	13	13					13
BRINE PUMP SUCTION PRESSURE, #G	24	24	24	24"	24"	24"	24"					24	24	24	24	24"	24"	24"	24"					24
BRINE PUMP DISCHARGE PRESSURE, #G	24	24	24	24	24	24	24					24	24	24	24	24	24	24	24					24
FEED PUMP SUCTION PRESSURE, #G	20	20	20	20	20	20	20					20	20	20	20	20	24	24	24					24
FEED PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20					20	20	20	20	20	24	24	24					24
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3"	3"	3"	0	0	0	0					3"	3"	3"	3"	3"	3"	3"	3"					3"
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	61	61	61	60	60	60	60					45	45	45	45	38	38	38	38					38
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10					10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	40	40	40	40					30	30	30	30	30	30	30	30					30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-3-67

#7

8-2-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	12103100		
0000	12104400	1300	
0100	12120000	1300	
0200	12121800	1200	
0300	12123000	1200	
0400	12124200	1200	
0500	12125500	1300	
0600	12134300	1200	
0700	12127900	1200	
0800	12129100	1200	
0900	12130300	1200	
1000	12131600	1300	
1100	12132900	1300	
1200	12104400	1300	
1300	12105600	1100	
1400	12106800	1200	
1500	12108100	1300	
1600	12109400	1300	
1700	12110600	1200	
1800	12111900	1300	
1900	12113200	1300	
2000	12114300	1100	
2100	12115500	1300	
2200	12116800	1300	
2300	12118100	1300	
2400	12119300	1200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	1581		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	208100		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3076 (REV. 11-50) BACK

REMARKS

0000-0400
#1 EVAP DIST TO #3 & POT
SHIFTED TO #3 PORT 0300 TO FWD
PEAK 0345
SIGNED M. Roy Hill

0400-0800
#1 Evap. dist. to FWD peak
Added 8 oz chlorine per 1000 gals
#1 part 22 - 1000 gals
#1 6166 - 1000 gals
#2 part - 2300 gals
#2 5166 - 1000 gals
SIGNED R. Shippard

0800-1200
#1 EVAP. DIST. TO
Forward Peak -
Added 8 oz chlorine
per 1000 gals DIST
SIGNED E. J. McCallum

Stocked in CDS

1200-1600
#1 EVAP DIST TO #3 & POT
Added 8 oz chlorine per 1000 GALS
SIGNED M. Roy Hill

1600-2000
#1 Evap. dist. to #3 &
Added 8 oz chlorine per 1000 gals dist.
SIGNED R. Shippard

2000-2400
#1 EVAP. DIST. TO
#3 &
Added 8 oz. chlorine
per 1000 gals DIST
SIGNED E. J. McCallum

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. JOHN POPE

PLANT NO.

1

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

20 min

MINUTES AT 2300-0100-0500

DATE

8-13

19

67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	8	8	9	9					4	3	9	1	9	9	10	9					9
STEAM FROM REG. VALVE, PRESSURE, #G	1	1	1	1	1	1	1					1	1	1	1	1	1	1	1					1
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	6	6	6	6	6	6	6					2	1	1	1	0	0	0	0					2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	230	230	235	235					210	210	220	220	235	235	235	235					235
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	194	194	195	200	200	200	200					195	195	195	195	200	200	200	200					195
1ST EFFECT SHELL PRESSURE, #HG	13	13	13	13	13	13	13					11	11	11	11	13	13	13	13					13
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	166	166	166	166					161	161	161	165	164	164	164	164					164
2D EFFECT SHELL PRESSURE, #HG	10	10	10	10	10	10	10					12	12	12	12	15	15	15	15					15
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	152	152	152	152	152					150	150	150	150	154	154	154	154					152
3D EFFECT SHELL PRESSURE, #HG	23	23	23	23	23	23	23					23	23	23	23	23	23	23	23					23
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	130	130	130	130					130	130	130	130	130	130	130	130					130
CONDENSATE FROM COOLER, TEMPERATURE, °F	99	99	99	98	98	98	98					99	99	99	99	99	99	99	99					99
BRINE OVERBOARD, TEMPERATURE, °F	125	125	125	125	125	125	125					125	125	125	125	125	125	125	125					125
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92					92	92	92	92	92	92	92	92					92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	86	86	86	87	87	87	87					86	86	86	86	87	87	87	87					86
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	86	86	86	87	87	87	87					86	86	86	86	87	87	87	87					86
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	160	164	164	164	162					160	160	160	164	164	164	162	162					160
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	108	108					108	108	108	108	110	110	110	110					108
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3					3	3	3	3	3	3	3	3					3
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12					12	12	12	12	13	13	13	13					12
BRINE PUMP SUCTION PRESSURE, #G	24	24	24	24	24	24	24					24	24	24	24	24	24	24	24					24
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20					20	20	20	20	20	20	20	20					20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	62	62	62	62	62	62	62					62	62	62	62	62	62	62	62					62
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10					10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.03	1.03	1.03	1.03	1.03	1.03	1.03					1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03					1.03
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2					0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2					0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-4-67

#1

8-3-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	12132900		
0000			
0100	12141900		1300
0200	12151100		1400
0300	12162100		1000
0400	12153300		1200
0500	12154600		1300
0600	12155800		1200
0700	12156800	1000	
0800	12157900	1100	
0900	12159200		1300
1000	12160500		1300
1100	12161800	1300	
1200	12134200	1300	
1300	12135400	1200	
1400	12136600	1200	
1500	12137800	1200	
1600	12139000	1200	
1700	12140300	1300	
1800	12141400	1300	
1900	12142900	1300	
2000	12144000	1400	
2100	12145300		1300
2200	12146600		1300
2300	12147400		800
2400	12148400		1200

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	1605		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	239200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

0000-0400

#1 - EVAP DIST TO #1 - S FEED

0200 SHIFTED TO #1 R FEED

4 HR 40 MIN

SIGNED

Mc Roy Hill

0400-0800

#1 Evap. Dist to #1 Std-Feed

@ 0230 shifted to #2 std-feed

@ 0400 shifted Dist. to fwd-peak.

#1 port 23-7-5t 2 Drops
 #1 std 23-7-5t 2 Drops
 40 MIN #12 port 23-7-5t 2 Drops
 #2 std 23-7-5t 2 Drops

SIGNED

R. Sheppard

0800-1200

#1 Evap. Dist. to

#1 Std FEED @

1000 shifted Dist. to

Fwd. PEAK - ...

SIGNED

E. J. Magallanes

Stocked in CDS

1200-1800

#1 EVAP DIST TO FWD PEAK

SIGNED

Mc Roy Hill

1800-2000

#1 Evap. Dist. to Fwd peak

Added 80z chlorine per 1000 gals.

SIGNED

R. Sheppard

2000-2400

#1 Evap. Dist. to

#1 Std FEED -

SIGNED

E. J. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

TENN. CLOTH POPA

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
BACK

MINUTES AT 2300-0100-0500

DATE

8-3

19

67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	4	4	4	4	4	4	4					7	7	7	7	8	8	8	8					8
STEAM FROM REG. VALVE, PRESSURE, #G	4"	4"	4"	4"	4"	4"	4"					4"	4"	4"	4"	4"	4"	4"	4"					4"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0					1	1	1	1	0	0	0	0					0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	235	235	235	235	240	240					235	235	235	235	235	235	235	235					235
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	195	195	195	195	195	195					195	195	195	195	195	195	195	195					195
1ST EFFECT SHELL PRESSURE, "HG	6"	6"	6"	6"	6"	6"	6"					6"	6"	6"	6"	5"	5"	4"	4"					6"
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	166	166	166	166	164	164					170	170	170	170	174	174	170	170					166
2D EFFECT SHELL PRESSURE, "HG	21	21	21	20"	20"	20"	20"					21	21	21	21	20"	20"	20"	20"					21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	152	152	152	152	152					152	152	152	152	160	160	154	154					152
3D EFFECT SHELL PRESSURE, "HG	20	20	20	20"	20"	20"	20"					20	20	20	20	23"	23"	23"	23"					20
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	136	136	140	140					142	142	144	144	136	136	138	138					136
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	102	102					100	100	100	100	100	100	100	100					98
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	130	130	130	132					132	132	132	132	128	128	128	128					128
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92					92	92	92	92	94	94	94	92					92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	87	87	87	87	87	87	87					86	86	86	86	87	87	88	88					87
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	87	87	87	87	87	87	87					86	86	86	86	87	87	88	88					87
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	156	156	154	154					164	164	164	164	168	168	156	156					152
FEED TO 1ST EFFECT, TEMPERATURE, °F	172	172	172	174	174	172	172					176	176	176	176	180	180	176	176					172
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	104	104	104	104	104					108	108	108	108	104	104	104	108					104
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2					3	3	3	3	2	2	2	2					2
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18					18	18	18	18	18	18	18	18					18
BRINE PUMP SUCTION PRESSURE, #G	23	23	23	22"	22"	22"	22"					21	21	21	21	22"	22"	22"	22"					22"
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20					18	18	18	18	18	18	18	20					20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3"	3"	3"	3"	3"	3"	3"					2"	2"	2"	2"	3"	3"	3"	3"					3"
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35					35	35	35	35	35	35	35	35					35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10					10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	22	22	22	20	20	20	20					20	20	20	20	20	20	20	20					20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-4-67

#2

8-3-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	06958500		
0000			
0100	06974900		1300
0200	06976200		1300
0300	06977000		800 40 MIN
0400	06978200		1200
0500	06979500		1300
0600	06980700		1200
0700	06981700	1000	
0800	06982900	1200	
0900	06984200	1300	
1000	06985600	1400	
1100	06987000	1400	
1200	06988500	1500	
1300	06989900		1100
1400	06991800		1100
1500	06993000		1100
1600	06994100		1000
1700	06995200		1100
1800	06996300		1100
1900	06997400		1300
2000	06998900		1300
2100	06970700		1300
2200	06971500		1300
2300	06972300		800
2400	06973600		1300

#2 - EVAP DIST TO #1 S. FEED
SHIFTED TO #1 PORT 0100
40 MIN.
SIGNED McRay

#2 - EVAP DIST TO FWD PEAK
SHIFTED TO #1 - S. FEED 1320
SIGNED McRay

#2 Evap. Dist. to #1 Std. Feed
@ 0430 shifted to #2 Std. Feed
@ 0600 shifted Dist. to Fwd. peak
SIGNED R. Sheppard

#2 Evap. Dist. to #1 Std. Feed
SIGNED R. Sheppard

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	12		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	15500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

#2 EVAP. DIST.
TO FWD. PEAK
Add 80Z of Freine
per 1000 gals Dist.
SIGNED E. J. Marshall

#2 EVAP. DIST. TO
#1 STD FEED
SIGNED E. J. Marshall

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

TEN. JOHN POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE

8-4

19

67

	8-5-67							HOUR ENDING																8-4-67						
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400						
STEAM TO REG. VALVE, PRESSURE #G	8	5	5	8	8	8	5					8	7	7	7	8	8	8	8					7						
STEAM FROM REG. VALVE, PRESSURE #G	4"	4"	4"	4"	4"	4"	4"					4"	4"	4"	4"	4"	4"	4"	4"					4"						
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0						
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	235	240	240	240	240	240					250	240	240	240	240	240	240	240					232						
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	195	195	195	195	195	195	195					194	194	194	194	194	194	194	194					190						
1ST EFFECT SHELL PRESSURE, *HG	6	6	6	6"	6"	6"	6"					6	6	6	6	6"	6"	6"	6"					6						
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	164	164	164	164					160	160	160	160	166	166	170	168					164						
2D EFFECT SHELL PRESSURE, *HG	20	20	20	20"	20"	20"	20"					20	20	20	20	20"	20"	20"	20"					20						
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	152	152	152	152	152					154	154	154	154	154	154	158	158					156						
3D EFFECT SHELL PRESSURE, *HG	25	25	25	25"	25"	25"	25"					25	25	25	25	25"	25"	25"	25"					25						
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	140	140	140	140					140	140	140	140	140	140	140	140					140						
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	100	100	100	102					102	102	102	102	102	102	102	102					100						
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130					127	127	127	127	130	130	130	130					130						
STEAM TO AIR EJECTOR, PRESSURE, #G	76	92	92	92	92	92	92					92	92	92	92	92	92	92	92					92						
AIR EJECTOR DRAINS, TEMPERATURE, °F																														
CIRC. WATER INJECTION, TEMPERATURE, °F	86	86	86	86	86	86	86					70	87	87	87	86	86	87	87					86						
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	86	86	86	86	86	86	86					70	87	87	87	86	86	87	87					86						
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																														
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																														
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																														
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	154	154	154	154	154	156	156					154	154	154	154	154	154	160	160					164						
FEED TO 1ST EFFECT, TEMPERATURE, °F	170	170	170	170	170	172	170					168	168	168	168	172	174	180	178					176						
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	104	104	104	104	104					102	104	104	104	104	104	104	104					104						
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2					3	3	3	3	2	2	2	2					2						
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18					18	18	18	18	18	18	18	18					18						
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22"	22"	22"	22"					21	21	21	21	22"	22"	22"	22"					22						
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20					20	20	20	20	22	22	20	20					20						
FEED PUMP SUCTION PRESSURE, #G																														
FEED PUMP DISCHARGE PRESSURE, #G																														
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3"	3"	3"	3"					2	2	2	2	3"	3"	3"	3"					3						
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35					35	35	35	35	35	35	35	35					36						
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10					10						
FEED DENSITY, 32NDS																														
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05					1.05						
Chemical Tests	30	30	30	30	20	20	20					30	30	30	30	30	30	30	30					30						
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2					0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2					0.2						
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0					0						
CONDENSATE FROM COOLER, SALINITY—E. P. M.																														

8-5-67

#2

8-4-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	06987000		
0100	07005800	1400	
0200	07007000	1200	
0300	07008300	1300	
0400	07009700	1400	
0500	07010900	1200	
0600	07012200		1300
0700	07013400		1200
0800	07014700		1300
0900	07016000		1300
1000	07017200	1200	
1100	07018500	1300	
1200	06988400	1400	
1300	06989800	1200	
1400	06991000	1300	
1500	06992500	1400	
1600			
1700	06995100	2400	2400
1800	06996400	1300	
1900	06997700	1300	
2000	06999000	1300	
2100	07000400	1400	
2200	07001700	1300	
2300	07003000	1300	
2400	07004400	1400	

0000-0400
#1 EVAP DIST TO #3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M. R. M. Hill

1200-1600
#1 EVAP DIST TO #3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M. R. M. Hill

0400-0800
#2 EVAP DIST TO #3 &
@ 0500 shifted dist. to #1 stbd.
#1 port- 23' - 7-st 2 drops
#1 stbd- 22' - 7-st 2 drops
#2 port- 23' - 7-st 2 drops
#2 stbd- 23' - 7-st 2 drops
SIGNED R. Shippard

1600-2000
#2 EVAP DIST. TO Fwd. peak
Added 8 OZ chlorine per 1000 gals.
SIGNED R. Shippard

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	35		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	44200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0800-1200
#2 EVAP DIST TO
#1 Stbd Feed...
@ 0900 Shifted Dist.
To # Fwd. Peak...
(Added 8 OZ chlorine per 1000 gals Dist.)
1000 GALS Dist.
SIGNED E. J. Magallanes

2000-2400
#2 EVAP DIST. TO
#3 &
(Added 8 OZ chlorine per 1000 gals Dist.)
SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. JOHN ROPE

PLANT NO.

2

AT ANCHOR BUCKNER BAY

TIME: ZONE DESCRIPTION - 8

SET CLOCKS AHEAD OR BACK

MINUTES AT

DATE

8-5

19

67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8					7	7	8	7	8	8	8	8	8				5
STEAM FROM REG. VALVE, PRESSURE #G	4"	4"	4"	4"	4"	4"	4"					4"	4"	4"	4"	4"	4"	4"	4"	4"				4"
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0	0				0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	230	230	215	210	215	225					230	225	225	220	230	230	240	240	240				230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	192	190	190	192					190	190	190	190	190	190	190	190	190				190
1ST EFFECT SHELL PRESSURE, #HG	6	6	6	6	6	6	6					6	6	6	6	6	6	6	6	6				6
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	166	166	166	164	166					164	164	164	164	166	166	168	168	168				166
2D EFFECT SHELL PRESSURE, #HG	20	20	20	20	20	20	20					20	20	20	20	20	20	20	20	20				20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	150	152	152	152	152					152	152	152	152	152	152	152	152	152				152
3D EFFECT SHELL PRESSURE, #HG	24	24	25	25	25	25	25					24	24	24	24	24	24	24	24	24				24
CONDENSATE TO COOLER, TEMPERATURE, °F	140	138	138	138	138	138	138					140	140	140	140	140	140	140	140	140				140
CONDENSATE FROM COOLER, TEMPERATURE, °F	130	130	130	130	130	130	130					130	130	130	130	130	130	130	130	130				130
BRINE OVERBOARD, TEMPERATURE, °F	130	130	128	128	128	128	128					130	130	130	130	130	130	130	130	130				130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92					92	92	92	92	92	92	92	92	92				92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	86	86	86	86	87	87	86					86	86	86	86	86	86	86	86	86				86
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	86	86	86									86	86	86	86	86	86	86	86	86				86
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	150	156	156	156	156					152	152	152	152	154	154	154	154	154				152
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	166	166	166	166	166					168	168	168	168	170	170	170	170	170				168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	106	106	106	107					104	104	104	104	104	104	104	104	104				102
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	3	3	3	3					2	2	2	2	2	2	2	2	2				2
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18					18	18	18	18	18	18	18	18	18				18
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22	22	22	22					22	22	22	22	22	22	22	22	22				22
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	19	19	19	20					20	20	20	20	20	20	20	20	20				20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	35	35	35	38	38	38	38					35	35	35	35	35	35	35	35	35				35
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	38	38	38	38					35	35	35	35	35	35	35	35	35				35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10					10	10	10	10	10	10	10	10	10				10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.5	1.5	1.5	1.5					1.05	1.05	1.05	1.05	1.5	1.5	1.5	1.5	1.5				1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	2	2	2	2					20	20	20	20	20	20	20	20	20				20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.1	0.1	0.1	0.1	0.1	0.1	0.1					0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1				0.1
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0					0	0	0	0	0	0	0	0	0				0

8-6-67

#2

8-5-67

DISTILLED WATER RECORD			
HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	07018500		
0000			
0100	07036600	1300	
0200	07037500	1200	
0300	07039100	1300	
0400	07040100	1000	
0500	07041400	1300	
0600	07042800	1400	
0700	07044000	1200	
0800	07045200	1200	
0900	07046500		1300
1000	07047800		1300
1100	07049100		1300
1200	07019500	1300	
1300	07021100	1300	1
1400	07022400	1300	
1500	07023700	1300	
1600	07025000	1300	
1700	07026300		1300
1800	07027600		1300
1900	07028900		1300
2000	07030100		1200
2100	07031400	1300	
2200	07032700		1300
2300	07034000		1300
2400	07035300	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD			
	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	59		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	75700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS	
0000-0400	1200-1600
#2-EVAP DIST TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS	#2 EVAP DIST TO #3 & POT ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED <u>McRay Hill</u>	SIGNED <u>McRay Hill</u>
0400-0800	1600-2000
@1400 shifted dist to #1 still feed Dist. to #3 & Added 8 oz. chlorine/1000 gal. #2 F.W. meter stops occasionally. You have to turn the pump off and on to get it moving again.	@1600 shifted dist to #1 S
SIGNED <u>R. Shippard</u>	SIGNED _____
0800-1200	2000-2400
#2 EVAP. DIST. TO #1 Still FEED	#2 EVAP. DIST. TO #1 Still FEED.
SIGNED <u>E. D. McCallum</u>	SIGNED <u>E. D. McCallum</u>

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

Crest of the 1000

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

MINUTES AT

DATE

8-6

1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	235	235	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	192	192	192	192	190	190	190	190	190	190	192	192	192	192	192	192	192	192	192
1ST EFFECT SHELL PRESSURE, #HG	7	7	7	7	7	7	7	7	7	7	7	6	6	6	6	6	6	6	6	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	165	165	165	165	165	165	165	165	165
2D EFFECT SHELL PRESSURE, #HG	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, #HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	138	138	138	138	138	140	140	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
CONDENSATE FROM COOLER, TEMPERATURE, °F	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	128	128	130	130	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128
STEAM TO AIR EJECTOR, PRESSURE, #G	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18
BRINE PUMP SUCTION PRESSURE, #G	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP DISCHARGE PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

8-7-67

#2

8-6-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	07049100		
0000			
0100	07066800	1300	
0200	07068200	1400	
0300	07069500	1400	
0400	07071000	1500	
0500	07072200	1200	
0600	07073500	1300	
0700	07074800	1300	
0800	07076000	1200	
0900	07077300		1300
1000	07078600		1300
1100	07079900		1300
1200	07081200		1200
1300	07082500		1200
1400	07083800		1200
1500	07085000		1300
1600	07086300		1300
1700	07087600		1400
1800	07088900	1200	
1900	07090200	1300	
2000	07091500	1300	
2100	07092800	1300	
2200	07094100	1300	
2300	07095400	1300	
2400	07096700	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	83		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	106300		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

#2 EVAP DIST TO #3 & PCT
ADDED 80Z CHLORINE PER 1000 GALS
SIGNED McRoy Hill

#2 Evap. Dist. to #3
Added 80z chlorine per 1000 gals Dist.
#1 port. 22' - Test 2 drops
#1 stbd. 18' - Test 2 drops
#2 port. 23' - Test 2 drops
#2 stbd. 21' - Test 2 drops
SIGNED R. Sheppard

#2 EVAP. DIST. TO
#1 STBD FEED...
(Added 2 GALS. of Chlorine
TO (FT. PEAK.
SIGNED E. J. Magallanes

Stocked in CDS

#2 EVAP DIST TO #1 & #2
SIGNED McRoy Hill

#2 Evap. Dist. to #2 stbd. feed
@ 1700 shifted Dist. to #3
Added 80z chlorine per 1000 gals.
SIGNED R. Sheppard

#2 EVAP. DIST. TO
#3 CENTER
(Added 80z of Chlorine
PER 1000 gals. Dist...
SIGNED E. J. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

THEIR CLOTHING PEOPLE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

20 min

MINUTES AT 2300-0100-0500 DATE

8-7

19

67

	8-7-67												8-7-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7	8	9	7	7	7	7	7	7	7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	240	240	235	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164
2D EFFECT SHELL PRESSURE, "HG	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	156	156	156	154	154	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	84	84	84	84	83	83	84	83	83	83	83	84	84	84	84	84	84	84	84	83	83	83	83	83
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	84	84	84	84	83	83	84	83	83	83	83	84	84	84	84	84	84	84	84	83	83	83	83	83
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	154	154	154	154	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	172	170	170	170	170	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
BRINE PUMP SUCTION PRESSURE, #G	21	21	21	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
BRINE PUMP DISCHARGE PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	30	20	20	20	20	20	20	30	30	20	20	20	20	20	20	20	20	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

8-8-67

#-2

8-7-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
	07079900		
0800			
0100	07096900		1200
0200	07098100		1300
0300	07098900	700	
0400	07100200	1300	
0500	07101400		1200
0600	07102200		800
0700	07103500		1300
0800	07104700		1200
0900	07106000		1300
1000	07107300	1300	
1100	07108600	1300	
1200	07109100	1200	
1300	07109300	1400	
1400	07109500	1300	
1500			
1600	07084400	2400	
1700	07087700	1300	
1800	07088900		1200
1900	07090100		1300
2000	07091200		1100
2100	07092400		1200
2200	07093600		1200
2300	07094500		1000
2400	07095700		1200

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	107		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	197300		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

#2-EVAP DIST TO #1 STBD FEED

#2-EVAP DIST TO #3 & POT

ADDED 802 CHLORINE 1000 GALS

40 min.

SIGNED

McRay Hill

SIGNED

McRay Hill

0400-0800

@ 0400 shifted dist. to #1 stbd-feed

1200-1600

#2 Evap. Dist. to #3

#1700 #2 Evap. Dist. to #2 stbd-feed

@ 1930 #2 Evap Dist to #1 stbd-feed.

#1 port-22-Test 2 drops

#1 stbd-22-Test 2 drops

#2 port-23-Test 2 drops

#2 stbd-22-Test 2 drops

SIGNED

R. Shippard

SIGNED

R. Shippard

0800-1200

#2 EVAP. DIST. TO
#1 STBD FEED...@ 0900 shifted Dist.
to #3 CENTER...Added 802 CHLORINE
per 1000 gals Dist.

SIGNED

E. J. Gallane

2000-2400

#2 EVAP. DIST. TO
#1 STBD FEED...

SIGNED

E. J. Gallane

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

C. F. D. W. L. O. F. H. D. W. L. D. O. P. P. E. PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS MINUTES AT

DATE

8-8

19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"	4"
STEAM TO 1ST EFFECT, PRESSURE, #HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, #HG	7	7	7	7"	7"	7"	7"	7	7	7	7	7	7	7	7	7"	7"	7"	7"	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	168	168	168	168	166	166	166	166	166
2D EFFECT SHELL PRESSURE, #HG	20	20	20	20"	20"	20"	20"	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	154	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, #HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	134	134	134	134	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	81	81	82	82	82	82	83	83	83	83	83	83	83	83	83	82	82	81	81	81	81	81	81	81
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	81	81	82	82	82	82	83	83	83	83	83	83	83	83	83	82	82	81	81	81	81	81	81	81
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154
FEED TO 1ST EFFECT, TEMPERATURE, °F	174	174	174	174	172	172	174	174	174	174	174	174	174	174	174	174	174	174	174	174	174	174	174	174
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22"	22"	22"	22"	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-9-67

#2

8-8-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07108600		
0100	07126200	1100	
0200	07127800	1300	
0300	07129100	1300	
0400	07130400	1300	
0500	07131700	1300	
0600	07133000	1300	
0700	07134300	1300	
0800	07135600	1300	
0900	07136900	1300	
1000	07138200	1300	
1100	07139600	1400	
1200	07140000	1400	
1300	07141200	1400	
1400	07142500	1400	
1500	07143800	1300	
1600	07145100	1300	
1700	07146400	1300	
1800	07147700	1300	
1900	07149000	1300	
2000	07120200	1200	
2100	07121500		1300
2200	07122800		1300
2300	07124100		1300
2400	07125300		1100

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	130		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	226400		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

#2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

M. Roy Hill

0000-0400

#2 Evap. Dist. to #3 &

Added 80Z chlorine per 1000 gals

SIGNED

R. Shippard

0400-0800

#2 EVAP. DIST. TO

#3 CENTER

(Added 2 GALS @ 2000
TO #3 CENTER @ 0820

SIGNED

J. D. Magallanes

Stocked in CDS

#2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

M. Roy Hill

1200-1600

#2 Evap. Dist. to #3 &

Added 80Z chlorine per 1000 gals.

SIGNED

R. Shippard

1600-2000

#2 EVAP. DIST. TO

#1 STBD FEED

Shifted to #3 @

@ 2300. (Added 80Z @ 2000

per 1000 gals

SIGNED

J. D. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY _____

U. S. S.

U.S.S. CHENE MOBILE HOPPE PLANT NO. 2

AHEAD

AT ANCHOR _____

TIME: ZONE DESCRIPTION

SET CLOCKS

ON BACK 20M

MINUTES AT 2200-0100-0500

DATE _____

P. 4

196

	HOUR ENDING																									
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400		
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	4"	4"	4"	4"	4	4	4	4	4"	4"	4"	4"	4"	4"	4"	4"	4	4	4	4	4	4	
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	235	235	235	235	240	240	240	240	240	240	235	236	235	235	240	235	235	235	240	240	235	240	240	240	
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	196	190	190	190	192	192	192	190	192	192	192	192	190	
1ST EFFECT SHELL PRESSURE, *HG	7	7	7	7"	7"	7"	7"	7	7	7	7	7	7	7	7	7	7"	7"	7"	7"	7	7	7	7	7	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	164	164	164	164	164	164	166	168	168	168	164	164	164	164	164	168	168	168	168	166	166	166	166	166	
2D EFFECT SHELL PRESSURE, *HG	20	20	20	20"	20"	20"	20"	20	20	20	20	20	20	20	20	20	20"	20"	20"	20"	20	20	20	20	20	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	152	154	154	154	154	154	154	154	154	152	152	152	152	152	154	154	154	154	152	152	152	152	152	
3D EFFECT SHELL PRESSURE, *HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25	
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	136	136	136	136	136	136	136	136	136	136	136	136	136	138	138	138	138	136	136	136	136	136	
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	98	98	98	98	98	98	98	98	96	96	96	96	96	96	
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	94	94	94	94	92	92	92	92	92	
AIR EJECTOR DRAINS, TEMPERATURE, °F																										
CIRC. WATER INJECTION, TEMPERATURE, °F	79	79	79	78	78	77	79	78	78	78	78	82	82	82	82	82	82	82	82	82	79	79	79	79	79	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	79	79	79	78	78	77	79	78	78	78	78	82	82	82	82	82	82	82	82	82	79	79	79	79	79	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																										
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																										
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																										
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	152	152	152	154	154	154	154	154	154	154	154	154	154	156	154	154	154	152	152	152	152	152	
FEED TO 1ST EFFECT, TEMPERATURE, °F	170	170	170	170	170	170	172	170	170	170	170	172	172	170	170	170	172	172	170	170	170	170	170	170	170	
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	98	98	98	98	98	98	98	98	98	98	102	102	102	102	102	100	100	100	100	102	102	102	102	100	
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22"	22"	22"	22"	22	22	22	22	22	22	22	22	22	22"	22"	22"	22"	22	22	22	22	22	
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	18	18	18	18	20	20	20	20	20	20	20	20	20	20	
FEED PUMP SUCTION PRESSURE, #G																										
FEED PUMP DISCHARGE PRESSURE, #G																										
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1"	2"	1"	1"	0	0	0	0	0	
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	36	36	36	36	36	36	36	36	38	
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	
FEED DENSITY, 32NDS																										
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	20	30	30	30	20	20	20	30	30	30	30	30	20	20	20	20	20	20	20	20	20	
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

8-10-67

#2

8-9-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07139600		
0100	07157800	1300	
0200	07158300	1300	
0300	07159100	800	40 MIN
0400	07160400	1300	
0500	07161700	1300	
0600	07162600	900	40 MIN
0700	07163900	1300	
0800	07165200	1300	
0900	07166500	1300	
1000	07167700		1200
1100	07169000		1300
1200	07141200	1400	
1300	07142300	1300	
1400	07143600	1300	
1500	07144900	1300	
1600	07146200	1300	
1700	07147500	1300	
1800	07148700		1200
1900	07149900		1200
2000	07151100		1200
2100	07152300		1200
2200	07153500		1200
2300	07154400		900
2400	07155700	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	154		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	257300		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

0000-0400 #2 EVAP DIST TO #3 PORT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED McRoy Hill

0400-0800 #2 Evap. Dist. to #3 &
Added 8 oz chlorine per 1000 Gals.
#1 part. 22' - Test 2 Drops
#1 stbd. 17' - Test 2 Drops
#2 part. 23' - Test 2 Drops
#2 stbd. 20' - Test 2 Drops
40 MIN
SIGNED R. Sheppard

0800-1200 #2 EVAP. DIST. TO
#3 PORT.
(Added 3 gals @ Chlorine
to #3 PORT & 3 gals to
#3 Stbd...
@ 0900 Shifted Dist.
to #1 Stbd Feed...
SIGNED E. A. Magallanes

Stocked in CDS

1200-1600 #2 EVAP DIST TO #3 & PORT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED McRoy Hill

1600-2000 #2 Evap. Dist. to #2 stbd feed
@ 1700 Shifted Dist to #1 stbd feed
SIGNED R. Sheppard

2000-2400 #2 EVAP. DIST. TO
#1 Stbd FEED...
SIGNED E. A. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. GEN. MOHAMED POPP

PLANT NO. _____

AT ANCHOR _____

TIME: ZONE DESCRIPTION

**AHEAD
OR
SET CLOCKS BACK**

MINUTES AT

DATE _____

8-10

13

[illegible]

8-11-67

#2

8-10-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07169000		
0100	07186100	1200	
0200	07187400	1300	
0300	07188700	1300	
0400	07189800	1400	
0500	07191000	1200	
0600	07192200	1200	
0700	07193400	1200	
0800	07194700	1300	
0900	07196000	1300	
1000	07197300	1300	
1100	07198500	1200	
1200	07199300	1300	
1300	07199300	1200	
1400	07199300	1300	
1500	07199300	1200	
1600	07199300	1200	
1700	07199300	1200	
1800	07199300		1200
1900	07199300		1400
2000	07199300		1200
2100	07199300		1200
2200	07199300		1200
2300	07199300		1300
2400	07199300	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	177		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	286700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

#2 - EVAP DIST TO #3 STBD PORT

ADDED 802 CHLORINE PER 1000 GALS

SIGNED

M. Roy Hill

0400-0800

#2 Evap. Dist. to #3 stbd

Added 802 chlorine per 1000 gals

#1 port. 22' - Test 2 Drops
 #1 stbd. 20' - Test 2 Drops
 #2 port. 23' - Test 2 Drops
 #2 stbd. 19' - Test 2 Drops

SIGNED

R. Shippard

0800-1200

#2 EVAP. DIST. TO

#3 PORT.

(Added 802 chlorine

per 1000 gals. Dist.

@ 1045 shifted Dist

to #3 &

SIGNED

E. J. Magallanes

#2 - EVAP DIST TO #3 STBD PORT

ADDED 802 CHLORINE PER 1000 GALS

SIGNED

M. Roy Hill

1200-1600

#2 Evap. Dist. to #3 stbd

@ 1700 shifted Dist. to #1 stbd. feed

SIGNED

R. Shippard

2000-2400

#2 EVAP. DIST. TO

#1 STBD FEED.

SIGNED

E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. JOHN POPE

PLANT NO.

1

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

MINUTES AT 2300-0100-0500

DATE

8-11

19

67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	9	10	9	9	9	9	9	9	9	9	8	8	9	9	10	10	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	235	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170
1ST EFFECT SHELL PRESSURE, "HG	15.6	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
2D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
2D EFFECT SHELL PRESSURE, "HG	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18
3D EFFECT COIL DRAIN, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
CONDENSATE FROM COOLER, TEMPERATURE, °F	82	82	82	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
BRINE OVERBOARD, TEMPERATURE, °F	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
STEAM TO AIR EJECTOR, PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	74	74	74	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	74	74	74	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75	75
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	100	100	100	98	98	98	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	1	1	1	1	2	2	2	2	1	1	1	1	1	1	1	1	1
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-12-67

#1

8-11-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12164100		
0100	12184100	1500	
0200	12182200	1400	
0300	12186600	1100	NO MIN.
0400	12188000	1400	
0500	12189500	1500	
0600	12190500	1000	40 MIN.
0700	12191900	1400	
0800	12193400	1500	
0900	12194900	1500	
1000	12196400	1500	
1100	12197800	1400	
1200	12165600	1500	
1300	12167100	1500	
1400	12168500	1400	
1500	12169900	1400	
1600	12171400	1500	
1700	12172900	1500	
1800	12174300	1400	
1900	12175800	1500	
2000	12177200	1400	
2100	12178700	1500	
2200	12180200	1500	
2300	12181200	1000	40 MIN.
2400	12182600	1400	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400 #1 EVAP DIST TO #3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M^o Roy Hill

1200-1600 #1 EVAP DIST TO #3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
SIGNED M^o Roy Hill

0400-0800 #1 Evap. Dist. to #3 &
Add. 8 oz chlorine per 1000 gals
SIGNED R. Shippard

1600-2000 #1 EVAP. DIST. TO #3 &
SIGNED R. Shippard

0800-1200 #1 EVAP. DIST. TO
#3 CENTER
(Added 8 oz chlorine
per 1000 gals Dist.)
SIGNED E. J. Sagallanes

2000-2400 #1 EVAP. DIST. TO
#3 CENTER
(Added 8 oz chlorine
per 1000 gals Dist.)
SIGNED E. J. Sagallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

STEAL. C/O/H/AI Pope

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS 20 Min

MINUTES AT 2300-0100-0100

DATE

8-11

1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	230	230	230	230	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	192	192	192	192	192	192	192	190	190	190	190	192	192	192	192	192	192	192	192	190
1ST EFFECT SHELL PRESSURE, *HG	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	166	166	166	166	166	166	166	166	166	166	164	164	164	168	168	168	168	168	166	166	164
2D EFFECT SHELL PRESSURE, *HG	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	152	152	152	152	152	152	152	152	154	154	154	154	154	154	152	152	152	152	152	152	150
3D EFFECT SHELL PRESSURE, *HG	25	25	25	25	25	25	25	25	25	25	25	25	25	24	24	24	24	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	136	136	136	136	136	136	136	138	138	138	138	136	136	136	136	136	136	136	136	136	136	136	136	136
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
BRINE OVERBOARD, TEMPERATURE, °F	126	126	126	125	125	125	125	125	125	125	125	130	130	130	130	130	130	130	126	126	126	126	126	126
STEAM TO AIR EJECTOR, PRESSURE #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	75	75	74	75	75	75	75	75	75	75	75	77	77	76	76	77	77	77	78	78	78	78	78	75
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	75	75	74	75	75	75	75	75	75	75	75	77	77	76	76	77	77	77	78	78	78	78	78	75
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	154	154	154	156	156	156	156	156	158	158	158	158	160	160	160	160	160	160	160	160	160
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	168	170	170	170	170	170	170	170	168	170	170	170	170	170	170	170	170	170	170	170	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	98	98	98	98	98	98	98	98	98	100	100	100	100	98	98	98	98	98	98	98	98	98	98	98
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
BRINE PUMP DISCHARGE PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
FEED PUMP SUCTION PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	20	20	18	16	16	16	16	16	12
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	1	1	1	2	2	2	2	2	2	2	2	3	3	3	3	3	3	2	1	1	1	1	1	1
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	38	38	38	38	38	38	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-12-67

2

8-17-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07198500		
0100	07214500		1300
0200	07230500		1200
0300	07246500		1100
0400	07262500		1100
0500	07278500		1200
0600	07294500		800
0700	07310500		1200
0800	07326500		1100
0900	07342500		1300
1000	07358500		1200
1100	07374500		1200
1200	07390500	1300	
1300	07406500	1300	
1400	07422500	1000	
1500	07438500	1300	
1600	07454500	1200	
1700	07470500	1100	
1800	07486500		1200
1900	07502500		1100
2000	07518500		1100
2100	07534500		1200
2200	07550500		1200
2300	07566500		900
2400	07582500		1100

0000-0400

2 - EVAP DIST TO #1 S-FEED

40 mi

SIGNED

McRay Hill

0400-0800

2 Evap. Dist. To # 1 & 2 stbd-feed

40 min.)

1 port - 22' - Test 2 Drops
 # 1 stbd - 20' - Test 2 Drops
 # 2 port - 23' - Test 2 Drops
 # 2 stbd - 21' - Test 2 Drops

SIGNED

R. Shepard

1200-1800

2 - EVAP DIST TO #3 & #4 POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

McRay Hill

1800-2400

2 Evap. Dist. To # 3 &
@ 1700 shifted Dist. To # 1 & 2 stbd-feed

SIGNED

R. Shepard

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	201		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	315200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0800-1200

2 EVAP. DIST. TO
 # 1 STBD FEED...
 @ 10:30 # 2 EVAP.
 SHIFTED DIST. TO
 # 3 CENTER

SIGNED

E. J. Nagallman

2000-2400

2 EVAP. DIST. TO
 # 1 STBD FEED...

SIGNED

E. J. Nagallman

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

ETENEA HOVING HOPE

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

MINUTES AT

DATE

8-12-67

	HOUR ENDING																								
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	
STEAM TO REG. VALVE, PRESSURE #G	7	7	9	9	9	9	9	9	9	9	9	9	9	9	9	8	8	8				9	9	9	
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	5"	5"	5"	5"	5	5	5	5	5	4	4	4	5"	5"	5"				2	2	4	
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	12	12	12	12"	12"	12"	12"	12	12	12	12	12	12	12	12	12"	12"	12"				12	12	12	
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	235	235	240	240	240	240	240	240	240	240	240	230	235	235	235	225	230				235	235	240	
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	167	167	167	170	170	170	170	170	170	170	170	170	168	167	167	167	170	170	170				170	170	170
1ST EFFECT SHELL PRESSURE, "HG	18	18	18	17"	17"	17"	17"	18	18	18	18	18	18	18	18	18"	18"	18"				18	18	18	
2D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	148	148	148	148	148	148	146	148	148	148	148	148	148	148	148				148	148	148	
2D EFFECT SHELL PRESSURE, "HG	18	18	18	18"	18"	18"	18"	18	18	18	18	18	18	18	18	18"	18"	18"				18	18	18	
3D EFFECT COIL DRAIN, TEMPERATURE, °F	134	134	134	132	132	132	132	132	132	132	132	132	132	132	132	130	130	130				130	130	130	
3D EFFECT SHELL PRESSURE, "HG	25	25	25	26"	26"	26"	26"	26	26	26	26	26	25	25	25	25	25	25				25	25	25	
CONDENSATE TO COOLER, TEMPERATURE, °F	106	106	106	108	108	108	108	108	108	108	108	108	108	108	108	108	108	108				108	108	108	
CONDENSATE FROM COOLER, TEMPERATURE, °F	80	80	80	82	82	82	82	82	83	83	83	83	84	84	84	84	83	83	82				82	82	82
BRINE OVERBOARD, TEMPERATURE, °F	104	104	104	105	105	105	105	105	105	105	105	105	105	105	105	100	100	100				102	102	102	
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92				92	92	92	
AIR EJECTOR DRAINS, TEMPERATURE, °F																									
CIRC. WATER INJECTION, TEMPERATURE, °F	72	72	72	73	73	73	73	74	74	74	74	74	74	74	74	74	74	74				73	73	73	
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	72	72	72	73	73	73	73	74	74	74	74	74	74	74	74	74	74	74				73	73	73	
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																									
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																									
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																									
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																									
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	164	158	158	158	158	158	158	158	158	158	158	158	158	156	156	156				158	158	158	
CIRC. WATER OVERBOARD, TEMPERATURE, °F	98	98	98	98	98	98	98	98	100	100	100	100	100	100	100	98	98	98				98	98	98	
CIRC. PUMP SUCTION PRESSURE, #G	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				1	1	1	
CIRC. PUMP DISCHARGE PRESSURE, #G	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12				12	12	12	
BRINE PUMP SUCTION PRESSURE, #G	24	24	24	24"	24"	24"	24"	26	26	26	26	26	26	26	26	26	26	26				26	26	26	
BRINE PUMP DISCHARGE PRESSURE, #G	14	14	14	14	14	14	15	15	15	15	15	15	15	15	15	15	15	15				15	15	15	
FEED PUMP SUCTION PRESSURE, #G																									
FEED PUMP DISCHARGE PRESSURE, #G																									
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	9	9	9	9"	9"	9"	9"	9	9	9	9	9	9	9	9	9	9	9				9	9	9	
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	55	55	55	55	53	53	53	55	55	55	55	55	55	55	55	55	55	55				55	55	55	
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10				10	10	10	
FEED DENSITY, 32NDS																									
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05				1.05	1.05	1.05	
AIR EJECTOR DRAINS, SALINITY—E. P. M.	100	100	100	2.6r	2.6r	2.0	2.0	100	100	100	100	100	100	100	100	100	100	100				100	100	100	
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02				02	02	02	
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0	0	0	

8-13-67

#-1

8-12-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12197800		
0100	12214400	1600	1600
0200	12215800	1400	
0300	12217200	1400	
0400	12218700	1500	
0500	12220100	1400	
0600	12221600	1500	
0700	12223000	1400	
0800	12224500	1500	
0900	12225900	1400	
1000	12227400	1500	
1100	12228900	1500	
1200	12199400	1600	
1300	12200900	1400	
1400	12202300	1500	
1500	12203800	1600	
1600	12205200	1400	
1700	12206700	1500	
1800	12208200	1500	
1900	12209600	800	
2000	12208500	500	
2100	12209800	1300	
2200			
2300	12211300	1500	
2400	12212800	1500	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	23		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	33700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

0000-0400 #1 EVAP DIST TO H 3 & POT
ADDED 801 CHLORINE PER 1000 GALS
SIGNED McRay Hill

1200-1800 #1 EVAP DIST TO H 3 & POT
ADDED 801 CHLORINE PER 1000 GALS
SIGNED McRay Hill

0400-0800 #1 Evap. Dist. to H 3 &
#1 port- 22 - Test 2 drops
#1 stbd- 22 - Test 2 drops
#2 port- 22 - Test 2 drops
#2 stbd- 22 - Test 2 drops
SIGNED R. Shppard

1800-2000 #1 Evap. Dist. to H 3 &
Added 807 chlorine per 1000 Gals.
@ 1830 lost the load - secured #1 Evap
SIGNED R. Shppard

0800-1200 #1 EVAP. DIST.
TO H. 3 @ CENTER
(Added 802 @ Chlorine
per 1000 gals DIST.)
SIGNED E. J. Magallanes

2000-2400 #1 EVAP ON LINE
@ 2045 DIST. TO
H. 3 @ CENTER
(Added 802 @ Chlorine
per 1000 gals DIST.)
SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

DET FAN 11 LOU-111111 110000 PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

MINUTES AT

DATE

8-12-67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	5	8	5	7	7	7	7	7	7	8	8	8	8	8	8	8	8	8				5	8	8
STEAM FROM REG. VALVE, PRESSURE #G	4	4	4	3"	3"	3"	3"	4	4	4	4	4"	4"	4"	4"	4"	4"	4"				4	4	4
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	230	240	240	240	240	240	240	240	240	230	230	230				230	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194				194	194	194
1ST EFFECT SHELL PRESSURE, "HG	7	7	7	6"	6"	6"	6"	7	7	7	7	7	7	7	7	7	7	7				7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	166	166	166	170	170	170	170	166	166	166	166	166	166	166	166	166	166	166				166	166	166
2D EFFECT SHELL PRESSURE, "HG	20	20	20	20"	20"	21"	21"	20	20	20	20	20	20	20	20	20	20	20				20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	152	152	152	152	150	150	150	150	150	150	150	150	150	150	150				150	150	150
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25				25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134				134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90				90	90	90
BRINE OVERBOARD, TEMPERATURE, °F	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125				125	125	125
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92				92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	72	72	72	73	73	73	73	74	74	74	74	74	74	74	74	75	75	75				75	75	75
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	72	72	72	73	73	73	73	74	74	74	74	74	74	74	74	75	75	75				75	75	75
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	152	152	152	154	154	154	154	154	154	154	154	154	154	154	154	152	152	152				152	152	152
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	170	170	170	170	170	170	166	166	166	166	166	166	168	168	168				168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	100	100	98	98	98	98	100	100	100	100	100	100	100	100	98	98	98				100	100	100
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4				4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	26	26	26	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20				20	20	20
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	23"	23"	23"	23"	23	23	23	23	23	23	23	23	22	22	22				22	22	22
BRINE PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18				18	18	18
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	1	1	1	1"	1"	1"	1"	1	1	1	1	1	1	1	1	1	1	1				1	1	1
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	34	34	34	34	36	36	36	36	36	36	36	36	36	36	36				36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10				10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05				1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-13-67

#2

8-12-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07226000		
0100	07240200		1200
0200	07241200		1200
0300	07241800		1000
0400	07243800	1000	
0500	07244900		1100
0600	07246000		1100
0700	07247100		1100
0800	07248300		1200
0900	07249500		1200
1000	07250700		1200
1100	07251900	1200	
1200	07253200	1200	
1300	07254400	1200	
1400	07255600	1200	
1500	07256800	1200	
1600	07258000	1200	
1700	07259200	1200	
1800	07260400		1200
1900	07261600		600
2000	07262800	600	600
2100	07264000	1300	
2200			
2300	07265200		1300
2400	07266400		1200

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	224		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	342700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

2 - EVAP DIST TO #13 FEED

0320 SHIFTED #2 - DIST TO #34 POT

SIGNED McRay Hill

0400-0800 #2 Evap. dist to #14 2 stbd feed

SIGNED R. Shippard

0800-1200 #2 Evap. Dist to #1 stbd FEED...

@ 10:00 Shifted Dist. to #3 CENTER

SIGNED E. J. Magallanes

#2 EVAP DIST TO #34 POT

ADDED 50 LBS CHLORINE PER 1000 GALS

SIGNED McRay Hill

1200-1600 #2 Evap. dist. to #3 &

@ 1700 Shifted Dist. to #1 stbd feed

@ 1830 Lost the load secured #2 Evap.

SIGNED R. Shippard

2000-2400 #2 Evap. on line @

2030 Dist. to #3 &

@ 2130 Shifted Dist. to #1 stbd Feed...

SIGNED E. J. Magallanes

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEM. WOLMAN BPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE

*8-14*19*67*

	8-14-67												8-14-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3"	3"	3"	3"	3	3	3	3	4	4"	4"	4"	3"	3"	3"	3"	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	246	246	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	192	192	192	192	192	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194
1ST EFFECT SHELL PRESSURE, "HG	7	7	7	7"	7"	7"	7"	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	166	166	166	166	166	166	166	166	166	166	168	168	168	168	168	168	168	166	166	166	166	166
2D EFFECT SHELL PRESSURE, "HG	20	20	20	21"	21"	21"	21"	21	21	21	21	21	20	20	20	21"	21"	21"	21"	21	20	20	20	20
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	152	152	152	152	152	152	152	152	152	152	154	154	154	154	152	152	152	152	154
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	24	24	24	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	140	140	140	140	140	140	140
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	74	74	74	73	73	73	73	72	72	72	72	72	72	72	72	74	74	74	74	75	75	75	75	75
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	74	74	74	73	73	73	73	72	72	72	72	72	72	72	72	74	74	74	74	75	75	75	75	75
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	154	154	154	152	152	152	152	150	150	150	150	150	150	150	150	154	154	154	154	154	154	154	154	154
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	168	168	168	168	162	162	162	162	162	162	162	162	168	168	168	168	168	168	168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	22	22	22	23"	23"	23"	23"	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23
BRINE PUMP DISCHARGE PRESSURE, #G	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	5"	5"	5"	5"	5"	5"	5"	5	5	5	5	5	5	5	5	5"	5"	5"	5"	5	5	5	5	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-14-67

#-2

8-14-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07278900		
0100	07294800	1200	1200
0200	07295300	1100	1100
0300	07297100	1200	1100
0400	07298200		1100
0500	07299300		1100
0600	07300400		1100
0700	07301500		1100
0800	07302700	1200	
0900	07303900	1200	
1000	07305100	1200	
1100	07306300	1200	
1200	07280000	1100	
1300	07281200	1200	
1400	07282300	1100	
1500	07283400	1100	
1600	07284600	1200	
1700	07285700	1100	
1800	07286800		1100
1900	07287900		1100
2000	07289000		1100
2100	07290100		1100
2200	07291300		1200
2300	07292400		1100
2400	07293600		1200

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	270		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	375600		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			

APPROVED

(Engineer Officer, U. S. N.)

REMARKS

0000-0400

#2 EVAP DIST TO #1 S. FEED

SIGNED

McRoy Hill

0400-0800

@0400 shifted dist. to #2 stbd. feed

@0700 shifted dist to #3 &

#1 port - 23' - Test 2 drops

#1 stbd - 23' - Test 2 drops

#2 port - 23' - Test 2 drops

#2 stbd - 23' - Test 2 drops

SIGNED

R. Shupard

0800-1200

#2 EVAP. DIST. TO

#3 & ...

(Added 8 oz chlorine
per 1000 gals. Dist. ...)

SIGNED

E. J. Magallanes

1200-1800

#2 EVAP DIST TO #3 & Pot

ADDED 80Z CHLORINE PER 1000 GAL

SIGNED

McRoy Hill

1800-2400

#2 Evap. Dist. to #3 &

@1700 shifted Dist. to #2 port - feed

@1800 shifted Dist. to #2 stbd - feed

@1930 shifted Dist. to #1 stbd - feed

SIGNED

R. Shupard

2000-2400

#2 EVAP. DIST. TO

#1 Stbd. FEED ...

SIGNED

E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. C. JOHN POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

DATE LINE

SET CLOCKS

AHEAD
OR
BACK

MINUTES AT

DATE

8-14

1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G											7	7	7	7	7	7	7	7	7	7	-			
STEAM FROM REG. VALVE, PRESSURE #G											4	4	4	4	4	2"	2"	2"	2"					
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G											2	1	1	1	1	2	0	0	0					
STEAM TO 1ST EFFECT, TEMPERATURE, °F											240	240	240	240	240	240	240	240	240					
1ST EFFECT COIL DRAIN, TEMPERATURE, °F											190	190	190	190	190	190	190	190	190					
1ST EFFECT SHELL PRESSURE, "HG											8	8	8	8	8	7"	7"	7"	7"					
2D EFFECT COIL DRAIN, TEMPERATURE, °F											160	160	160	160	160	170	170	170	170					
2D EFFECT SHELL PRESSURE, "HG											20	20	20	20	20	21"	21"	21"	21"					
3D EFFECT COIL DRAIN, TEMPERATURE, °F											152	152	152	152	152	152	152	152	152					
3D EFFECT SHELL PRESSURE, "HG											20	20	20	20	20	25"	25"	25"	25"					
CONDENSATE TO COOLER, TEMPERATURE, °F											142	142	142	142	142	142	142	142	142					
CONDENSATE FROM COOLER, TEMPERATURE, °F											94	94	94	94	94	98	98	98	98					
BRINE OVERBOARD, TEMPERATURE, °F											132	132	132	132	132	132	132	132	132					
STEAM TO AIR EJECTOR, PRESSURE, #G											92	92	92	92	92	92	92	92	92					
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F											69	71	72	72	72	72	72	72	72					
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F											69	71	72	72	72	72	72	72	72					
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F											150	150	150	150	150	152	152	152	152					
FEED TO 1ST EFFECT, TEMPERATURE, °F											160	160	160	160	160	166	166	166	166					
CIRC. WATER OVERBOARD, TEMPERATURE, °F											104	102	102	102	102	102	102	102	102					
CIRC. PUMP SUCTION PRESSURE, #G											4	4	4	4	4	4	4	4	4					
CIRC. PUMP DISCHARGE PRESSURE, #G											21	21	21	21	21	21	21	21	21					
BRINE PUMP SUCTION PRESSURE, #G											25	22	22	22	22	22"	22"	22"	22"					
BRINE PUMP DISCHARGE PRESSURE, #G											22	14	14	14	14	20	20	20	20					
FEED PUMP SUCTION PRESSURE, #G											5	5	5	5	5	5"	5"	5"	5"					
FEED PUMP DISCHARGE PRESSURE, #G											35	35	35	35	35	35	35	35	35					
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G											10	10	10	10	10	10	10	10	10					
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G																								
F. W. PUMP DISCHARGE PRESSURE																								
FEED DENSITY, 32NDS											1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5					
BRINE OVERBOARD DENSITY, 32NDS											40	20	20	20	20	20	20	20	20					
AIR EJECTOR DRAINS, SALINITY—E. P. M.											02	02	02	02	02	02	02	02	02					
1ST EFFECT DRAINS, SALINITY—E. P. M.											0	0	0	0	0	0	0	0	0					
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-15-67

2

8-14-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS *	FEED TANKS *
0000	07306300		
0100			
0200			
0300			
0400			
0500			
0600			
0700			
0800			
0900			
1000	07318800		
1100	07320200	1400	
1200	07309500	1200	
1300	07308600	1100	
1400	07309500	1200	
1500	07310600	1500	
1600	07312100	1100	
1700	07313300	1200	
1800	07314500	1200	
1900	07315700		1200
2000	07316900		1200
2100	07317200		700
2200			
2300			
2400			

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	294		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	323000		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			

APPROVED

(Engineer Officer, U. S. N.)

REMARKS

0000-0400

1200-1600

2 - EVAP DIST TO # 3 ~~4~~ AFT PEAK

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

SIGNED

0400-0800

1600-2000

@ 1400 shifted dist. to # 3 &
@ 1800 shifted dist. to # 1 st 66-ft and

SIGNED

SIGNED

0800-1200

2000-2400

2 EVAP Lit off @
9:30 ... DIST. TO # 3 &# 2 EVAP. DIST TO # 3 &..
@ 2030 # 2 EVAP. SECURED
Lit off @ 2320

SIGNED

SIGNED

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels
of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GREEN. MOUNT IDOL

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

20 MIN

MINUTES AT 2300-0100-0500

DATE

8-15

19

67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3"	3"	3"	3"	3	3	3	3	4"	4"	4	4	3	3"	3"	3"	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0	2	2	2	2	2	2	2	2	0	0	0	0	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	235	235	240	240	235	235	235	235	240	240	240	240	235	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194
1ST EFFECT SHELL PRESSURE, *HG	8	8	8	8"	8"	8"	8"	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166
2D EFFECT SHELL PRESSURE, *HG	21	21	21	21"	21"	21"	21"	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, *HG	24	24	24	23"	23"	23"	23"	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23
CONDENSATE TO COOLER, TEMPERATURE, °F	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	128	128	128	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	71	71	70	71	71	71	71	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	71	71	70	71	71	71	71	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	148	148	146	146	146	146	146	148	148	148	148	150	150	150	150	150	150	150	150	150	150	150	150	150
FEED TO 1ST EFFECT, TEMPERATURE, °F	160	160	158	158	158	158	158	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	5	5	5	5"	5"	5"	5"	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-16-67

#2

8-15-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07320200		
0100	07337800	1300	
0200	07339100	1300	
0300	07339900	800	HOMIN-
0400	07341100	1200	
0500	07342300	1200	
0600	07343100		800
0700	07344400		1300
0800	07345700		1300
0900	07347000		1300
1000	07348300		1300
1100	07349600		1300
1200	07321600	1300	
1300	07322800	1300	
1400	07324100	1300	
1500	07325300	1200	
1600	07326700	1400	
1700	07327900	1200	
1800	07329100	1200	
1900	07330300	1200	
2000	07331700	1400	
2100	07333000		1300
2200	07334300		1300
2300	07335100		800
2400	07336500	1400	1400

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	304		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	335700		
GALLONS THIS DATE			
GALLONS TO DATE			

CHECKED (Signature)

APPROVED

(Engineer Officer, U. S. N.)

REMARKS

0000-0400 #2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

40 min

SIGNED

McRay Hill

0400-0800 #2 Evap. Dist. to #3 &
@ 0500 shifted Dist. to #1 stbd feed

#1 port - 23' - Test 2 drops.
 #1 stbd - 15' - Test 2 drops.
 #2 port - 23' - Test 2 drops.
 #2 stbd - 20' - Test 2 drops.

SIGNED

R. Shippard

0800-1200

- 2 EVAP. DIST. TO

- 1 STBD FEED.....

SIGNED

B. J. Nagallanor

1200-1800 #2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED

McRay Hill

1200-2000 #2 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 gals.

SIGNED

R. Shippard

2000-2400

- 2 EVAP. DIST. TO

- 3 @

@ 2100 shifted Dist. to

- 1 STBD FEED

SIGNED

B. J. Nagallanor

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY _____

U. S. S.

PLANT NO

2

AT ANCHOR _____

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

MINUTES AT 2300-0100-0500

DATE _____

8-16

— 1

6

[illegible]

8-17-67

#-2

8-16-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07349600		
0100	07360700	1200	
0200	07367700	1200	
0300	07368600	9100	140 MIN-
0400	07369700	1100	
0500	07371000	1300	
0600	07371800	8000	40 min
0700	07373000	1200	
0800	07374200	1200	
0900	07375500	1300	
1000	07376800	1300	
1100	07378000	1200	
1200	07350800		1200
1300	07352000		1200
1400	07353300		1300
1500	07354600		1300
1600	07355800		1200
1700	07357000		1200
1800	07358200		1200
1900	07359400		1200
2000	07360700		1300
2100	07362000		1300
2200	07363300		1300
2300	07364000		700
2400	07365300	1300	

2- EVAP DIST TO # 3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

McRay Hill

2- EVAP DIST TO # 1 STBD FEED

SIGNED

McRay Hill

2 Evap. Dist. to # 3
Add. 8 oz chlorine per 1000 gals.

2 Evap. Dist. to # 1 STBD FEED
@ 1700 Shifted Dist. to # 2 STBD FEED.

1 port-23' - Test 2 drops
10 min) # 1 STBD-21 - Test 2 drops
2 port-23' - Test 2 drops
2 STBD-23' - Test 2 drops

SIGNED

R. Sheppard

SIGNED

R. Sheppard

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	327		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	365100		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

#- 2 EVAP. DIST. TO
#- 3 & ...
(Added 8 oz chlorine
per 1000 gals Dist.)

SIGNED

E. J. Gallanous

#- 2 EVAP. DIST. TO
#- 2 STBD FEED ...
@ 22:00 Shifted Dist
to #- 3 &
(Added 8 oz chlorine
per 1000 gals Dist.)

SIGNED

E. J. Gallanous

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

G. E. IV. NO. 101111 POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OF
SET CLOCKS BACK

20 min

MINUTES AT 2000-0100-0800

DATE

8-17

1967

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	232	235	240	240	240	240	240	240	240	240	240	230	230	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192
1ST EFFECT SHELL PRESSURE, "HG	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
2D EFFECT COIL DRAIN, TEMPERATURE, °F	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164
2D EFFECT SHELL PRESSURE, "HG	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	90	90	90	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
BRINE OVERBOARD, TEMPERATURE, °F	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126	126
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	68	67	67	65	64	63	63	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	68	67	67	65	64	63	63	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	142	142	142	142	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140
FEED TO 1ST EFFECT, TEMPERATURE, °F	154	154	152	152	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154	154
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	98	100	100	98	94	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

8-18-67

#2

P. 17-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07378000		
0100	07394800	1200	
0200	07396000	1200	
0300	07396900	900	40 min
0400	07398200	1300	
0500	07399500	1300	
0600	07400400	900	40 min
0700	07401600	1200	
0800	07402800	1200	
0900	07404100	1300	
1000	07405400	1300	
1100	07406700	1300	
1200	07399200	1200	
1300	07380400	1200	
1400	07381600	1200	
1500	07382800	1200	
1600	07384000	1200	
1700	07385300	1300	
1800	07386600	1300	
1900	07387800	1200	
2000	07389000	1200	
2100	07390200	1200	
2200	07391400	1200	
2300	07392300	900	40 min
2400	07393600	1300	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	350		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	393700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

0000-0400 #2 - EVAP DIST TO #3 & Pot
ADDED 80Z CHLORINE PER 1000 GALS
SIGNED McRay Hill

0400-0800 #2 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 Gals
#1 port - 23' - Test 2 drops
#1 stbd - 12' - Test 2 drops
#2 port - 23' - Test 2 drops
#2 stbd - 22' - Test 2 drops
SIGNED R. Shippard

0800-1200 #2 EVAP. DIST. TO
#3 &
(Added 80Z chlorine
per 1000 gals Dist.)
SIGNED E. J. Magallanes

1200-1600 #2 - EVAP DIST TO #3 & Pot
ADDED 80Z CHLORINE PER 1000 GALS
SIGNED McRay Hill

1600-2000 #2 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 Gals
SIGNED R. Shippard

2000-2400 #2 EVAP. DIST. TO
#3 &
(Added 80Z chlorine
per 1000 gals Dist.)
SIGNED E. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

AHEAD OR S BACK

PLANT NO

MINUTES AT

DATE _____

8-18-67

TIME: ZONE DESCRIPTION

SET CLOCKS **OR** BACK

HOUR ENDING

	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	192	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194
1ST EFFECT SHELL PRESSURE, *HG	8	8	8	8	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	161	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168
2D EFFECT SHELL PRESSURE, *HG	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	148	148	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
3D EFFECT SHELL PRESSURE, *HG	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
CONDENSATE FROM COOLER, TEMPERATURE, °F	84	84	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86
BRINE OVERBOARD, TEMPERATURE, °F	124	124	128	128	130	130	130	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128	128
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	67	68	68	73	72	72	72	71	71	71	71	65	65	65	65	62	62	62	62	62	62	62	62	65
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	67	68	68	73	72	72	72	71	71	71	71	65	65	65	65	62	62	62	62	62	62	62	62	65
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	138	138	140	141	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140	140
FEED TO 1ST EFFECT, TEMPERATURE, °F	156	156	158	154	154	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156	156
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	100	100	100	98	98	98	100	100	100	100	100	100	100	100	100	98	98	98	100	100	100	100	100
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
BRINE PUMP DISCHARGE PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	30	30	30	30	30	30	30	30	20	30	30	30	30	30	30	30	30	30	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

8-19-67

2 1

8-18-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07402700		
0100	07423100	1200	
0200	07423300	1200	
0300	07426400	1700	
0400	07427500	1400	
0500	07428700	1200	
0600	07429900	1200	
0700	07431100	1200	
0800	07432200	1200	
0900	07433400	1200	
1000	07434700		1300
1100	07435900	1200	
1200	07407900	1200	
1300	07409200	1300	
1400	07410500	1300	
1500	07411700	1200	
1600	07412900	1200	
1700	07414200	1300	
1800	07415500	1300	
1900	07416800	1300	
2000	07418000	1200	
2100	07419300	1300	
2200	07420500	1200	
2300	07421700	1200	
2400	07422900	1200	

2 = EVAP DIST TO # 3 & POT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

M^c Ray 7610

0400-0800

2 Evap. Dist. to # 3 &

Add 8 OZ chlorine per 1000 GALS

1 port. - 21' - Test 2 drops

1 stbd. - 1' - Test

2 port. - 23' - Test 2 drops

2 stbd. - 21' - Test 2 drops

SIGNED

R. Sheppard

0800-1200

2 EVAP. DIST. TO

3 & ...

(Added 8 OZ chlorine
per 1000 gals Dist.)

SIGNED

E. J. Gallanias

1200-1800

2 - EVAP DIST TO # 3 & POT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED

M^c Ray 7610

1600-2000

2 Evap. Dist. to # 3 &

Add 8 OZ chlorine per 1000 GALS Dist.

SIGNED

R. Sheppard

2000-2400

2 EVAP. DIST. TO

3 &

(Added 8 OZ chlorine
per 1000 gals Dist.)

SIGNED

E. J. Gallanias

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	373		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	422500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

THE U.S. NAVY. *HOCHMAN* *DOBLE*

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS AHEAD OR BACK

MINUTES AT

DATE

8-19

19 67

	HOUR ENDING																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, PRESSURE, *HG OR #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192
1ST EFFECT SHELL PRESSURE, *HG	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
2D EFFECT COIL DRAIN, TEMPERATURE, °F	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162	162
2D EFFECT SHELL PRESSURE, *HG	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
3D EFFECT SHELL PRESSURE, *HG	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	68	65	65	64	63	63	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	68	65	65	64	63	63	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138	138
FEED TO 1ST EFFECT, TEMPERATURE, °F	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148
CIRC. WATER OVERBOARD, TEMPERATURE, °F	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
CIRC. PUMP SUCTION PRESSURE, #G	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
CIRC. PUMP DISCHARGE PRESSURE, #G	18	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24
BRINE PUMP DISCHARGE PRESSURE, #G	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

8-20-67

4-2

8-19-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07435900		
0100	07452300		1200
0200	07453500		1200
0300	07454600		1100
0400	07455700		1400
0500	07456800		1100
0600	07457900		1100
0700	07458900		1000
0800	07460100		1200
0900	07461200		1700
1000	07462300		1100
1100	07463400		1700
1200	07437100	1400	1200
1300	07438300		1200
1400	07439400		1100
1500	07440400		1000
1600	07441400		1000
1700	07442500		1100
1800	07443700		1200
1900	07444900		1200
2000	07446100		1200
2100	07447300		1200
2200	07448600		1300
2300	07449800		1200
2400	07451100		1300

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	397		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	451700		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

REMARKS

0000-0400 #2 - EVAP DIST TO #1 S-FEED

1200-1600 #2 - EVAP DIST TO #1 S-FEED

SIGNED

M^e Roy Hill

SIGNED

M^e Roy Hill

0400-0800

#2 - EVAP. DIST. TO
#1 S-FEED...

1600-2000

#2 - EVAP DIST TO #1 S-FEED

SIGNED

E. J. Magallanes

SIGNED

M^e Roy Hill 1600-1500

0800-1200

#2 - EVAP. DIST. TO
#1 S-FEED...
#1 PORT "

2000-2400

#2 - EVAP. DIST. TO
#1 S-FEED...

SIGNED

E. J. Magallanes

SIGNED

E. J. Magallanes