

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GUESS - MOUNTAIN POPE

PLANT NO.

II

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE

9-7

1967

	9-8-67												9-11-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	160	160	160	162	160	160	160	160	160	160	160	160	160	160	160	160	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23
3D EFFECT COIL DRAIN, TEMPERATURE, °F	144	144	144	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	144	144	144	144	144
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	128	128	128	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	128	128	128	128	128
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	80	80	80	81	81	81	81	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	80	80	80	81	81	81	81	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164
CIRC. WATER OVERBOARD, TEMPERATURE, °F	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102	102
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	15	15	15	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.78	1.78	1.78	1.6	1.6	1.6	1.6	1.7	1.7	1.7	1.7	1.78	1.78	1.78	1.78	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7	1.7
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	30	30	30	30	20	20	20	20	40	40	40	40	40	40	40	40	20	20	20	20	20
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

9-8-67

II

9-7-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07700400		
0100	07720700	1500	
0200	07722100	1500	
0300	07723500	1400	
0400	07725100	1600	
0500	07726400	1500	
0600	07728000	1400	
0700	07729500	1500	
0800	07730900	1400	
0900	07732200		1400
1000	07734700		1500
1100	07735100		1400
1200	07702000	1600	
1300	07703600	1600	
1400	07705100	1600	
1500	07706300	1100	
1600	07707700	1400	
1700	07709200	1500	
1800	07710700	1500	
1900	07712100	1400	
2000	07713500	1500	
2100	07714800	1300	
2200	07716200	26,200	1400
2300	07717700		1500
2400	07719200		1400
			8,700

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	144		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	225400		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

0000-0400
#2 - EVAP DIST TO #3 & POT
ADDED 10 OZ CHLORINE PER 1000 GALS
SIGNED *McRay Hill*

1200-1800
#2 - EVAP DIST TO #3 & POT
ADDED 10 OZ CHLORINE PER 1000 GALS
SIGNED *McRay Hill*

0400-0800
#2 Evap. Dist. to #3 &
Added 10 oz chlorine per 1000 gals
SIGNED *R. Shippard*

1800-2000
#2 Evap. Dist. to #3 &
Added 10 oz chlorine per 1000 gals Dist
SIGNED *R. Shippard*

0800-1200
#- 2 EVAP. DIST. TO
#- 1 STBD FEED
SIGNED *E. J. Magallanes*

2000-2400
#- 2 EVAP. DIST. TO
#- 1 STBD FEED
SIGNED *E. J. Magallanes*

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

119
24
104

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GREEN. HOTHAM. MOORE

PLANT NO.

11

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

SET CLOCKS

MINUTES AT

DATE

9-7

19 67

	9-7-67												9-7-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	8	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	5	5	5	4"	4"	4"	4"	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164
2D EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16
3D EFFECT COIL DRAIN, TEMPERATURE, °F	150	150	150	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152	152
3D EFFECT SHELL PRESSURE, "HG	24	24	24	24"	24"	24"	24"	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132
CONDENSATE FROM COOLER, TEMPERATURE, °F	93	93	93	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	80	80	80	81	81	81	81	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	80	80	80	81	81	81	81	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80	80
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	164	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
CIRC. PUMP DISCHARGE PRESSURE, #G	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14
BRINE PUMP SUCTION PRESSURE, #G	15	26	26	26	26"	26"	26"	26"	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	12	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14
FEED PUMP SUCTION PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
FEED PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G																								
F. W. PUMP DISCHARGE PRESSURE																								
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02	1.02
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
1ST EFFECT DRAINS, SALINITY—E. P. M.																								
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. *USSC (M) 1001*PLANT NO. *1*

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
OR
BACK

20 MIN

MINUTES AT 2300-0100-0500

DATE

9-6

19

67

	9-7-67												9-6-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE, #G	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	6	6	6	6"	6"	6"	6"	6	6	6	6	6	6	6	6	6"	6"	6"	6"	6	6	6	6	6
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	194	194	188	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	15	15	15	15"	15"	15"	15"	15	15	15	15	15	15	15	15	15"	15"	15"	15"	15	15	15	15	15
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	154	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	10	10	10	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	144	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	148	148	148	148	148
3D EFFECT SHELL PRESSURE, "HG	24	24	24	24"	24"	24"	24"	24	24	24	24	24	24	24	24	24"	24"	24"	24"	24	24	24	24	24
CONDENSATE TO COOLER, TEMPERATURE, °F	128	128	128	128	128	128	128	130	130	130	130	130	130	130	130	130	130	130	130	126	126	126	126	126
CONDENSATE FROM COOLER, TEMPERATURE, °F	91	91	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	90	90	90	90	90
BRINE OVERBOARD, TEMPERATURE, °F	119	119	119	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	78	78	79	79	79	80	80	80	80	80	80	80	80	80	80	80	80	80	80	78	78	78	78	78
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	78	78	79	79	79	80	80	80	80	80	80	80	80	80	80	80	80	80	80	78	78	78	78	78
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	164	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	15	15	15	14	14	14	14	14	14	14	14	14	15	15	15	15	15	15	15	15	15	15	15	15
BRINE PUMP SUCTION PRESSURE, #G	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13
BRINE PUMP DISCHARGE PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
FEED PUMP SUCTION PRESSURE, #G	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13	13
FEED PUMP DISCHARGE PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	9	9	9	9"	9"	9"	9"	9	9	9	9	9	9	9	9	9"	9"	9"	9"	9	9	9	9	9
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.75	1.75	1.75	1.6	1.6	1.6	1.6	1.7	1.7	1.7	1.7	1.75	1.75	1.75	1.75	1.6	1.6	1.6	1.6	1.7	1.7	1.7	1.7	1.75
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

9-7-67

9-1

9-6-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12427900		
0100	12447100	1400	
0200	12448600	1400	
0300	12450300	1700	1HR-20 MIN
0400	12451700	1400	
0500	12453100	1400	
0600	12454900	1800	1HR-20 MIN
0700	12456300	1400	
0800	12457600	1300	
0900	12459000		1400
1000	12460300		1300
1100	12461600		1300
1200	12429200	1300	
1300	12430600	1400	
1400	12431900	1300	
1500	12433200	1300	
1600	12434400	1200	
1700	12435800	1400	
1800	12437200	1400	
1900	12438600	1400	
2000	12439900	1300	
2100	12441200	23,800	1300
2200	12442600		1400
2300	12443900		1300
2400	12445700		1300

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	119		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	157900		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			

(Engineer Officer, U. S. N.)

NAVSHIPS 3876 (REV. 11-50) BACK

0000-0400
#1 EVAP DIST TO #30 POT
ADDED 10 OZ CHLORINE PER 1000 GALS
SIGNED *[Signature]*

0400-0800
#1 EVAP. Dist. 20 #3 &
Added 10 OZ chlorine per 1000 Gals.
#1 port. 23' - Test 2 drops
#1 18' 16' - 18' - Test 2 drops
#1 20' 4' - 2 port - 23' - Test 2 drops
#1 28' 16' - 19' - Test 2 drops
SIGNED *[Signature]*

0800-1200
#1 EVAP. Dist. TO
#1 STBD FEED
SIGNED *[Signature]*

1200-1600
#1 EVAP DIST TO #30 POT
ADDED 10 OZ CHLORINE PER 1000 GALS
SIGNED *[Signature]*

1600-2000
#1 EVAP. Dist. 70 #3 &
Added 10 OZ chlorine per 1000 Gals
SIGNED *[Signature]*

2000-2400
#1 EVAP. Dist. TO
#1 STBD FEED
SIGNED *[Signature]*

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

94
25
1/9

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

USS. McHAH Pope

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK*20 min*MINUTES AT *2000-0100-0300*

DATE

*9-6**1967*

	9-7-67												9-6-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	3	3	3	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3"	3"	3"	3"	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	1	1	1	0	0	0	0	0	0	0	0	2	2	2	2	2	2	2	2	0	1	1	1	1
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	194	194	192	192	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194
1ST EFFECT SHELL PRESSURE, "HG	10	10	9	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	158	162	164	164	164	160	160	160	160	158	158	158	158	160	164	164	164	160	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	23	23	23	23"	23"	23"	23"	23	23	23	23	23	23	23	23	23"	23"	23"	23"	23	23	23	23	23
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	144	144	144	144	144	144	144	144	144	144	144	144	144	146	146	146	146	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
CONDENSATE FROM COOLER, TEMPERATURE, °F	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96	96
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	78	78	79	79	79	80	80	80	80	80	80	80	79	79	79	79	79	79	79	78	78	78	78	78
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	78	78	79	79	79	80	80	80	80	80	80	80	79	79	79	79	79	79	79	78	78	78	78	78
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	104	102	102	102	102	102	102	102	102	102	104	104	104	104	104	104	104	104	104	104	104	104
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26"	26"	26"	26"	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3"	1"	1"	1"	2	2	2	2	2
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125	2.125
AIR EJECTOR DRAINS, SALINITY—E. P. M.	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

PLANT NO.

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS BACK

MINUTES AT

DATE _____

— 13 —

— 13 —

[illegible]

427900
392000
30900

9-6-67

A-1

9-5-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12395600		
0100	12411300	1300	
0200	12415000	1300	
0300	12417200	1600	18420 MIN
0400	12418400	1200	
0500	12419800	1400	
0600	12421500	1700	1 Hr 20 min
0700	12422900	1400	
0800	12424100	1200	
0900	12425300		1200
1000	12426600		1300
1100	12427900		1300
1200	12397000	1400	
1300	12398300	1300	
1400	12399600	1300	
1500	12400900	1300	
1600	12402200	1300	
1700	12403500	1300	
1800	12404800	1300	
1900	12406100	1300	
2000	12407400	1300	
2100	12408700	22,800	1300
2200	12410000		1300
2300	12411700		1700
2400	12413000		1400

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	94		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	125500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

0000-0800
#1 EVAP DIST TO #3 POT
ADDED 802 CHLORINE PER 1000 GALS
SIGNED M. Roy Hill

0800-0800
#1 Evap. Dist. To #3
Added 802 chlorine per 1000 Gals
#1 port-23' - Test 2 drops
#1 std-17 - Test 2 drops
#2 port-23' - Test 2 drops
#2 std-21' - Test 2 drops
SIGNED R. Shippard

0800-1200
#1 EVAP. DIST. TO
#1 STD FEED...

SIGNED

Stocked in CDS

1200-1800
#1 EVAP DIST TO #3 POT
ADDED 802 CHLORINE PER 1000 GALS
SIGNED M. Roy Hill

1800-2400
#1 Evap. Dist. To #3
Added 2 Gallons of chlorine To #3
SIGNED R. Shippard

2400-2400
#1 EVAP. DIST. DIST.
TO #1 STD FEED...

SIGNED

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GEN. HONAN POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

20 min

MINUTES AT 2300-0100-0500

DATE

9-5

19

67

	9-6-67																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	3	2	3	5"	5"	5"	5"	5	5	5	5	5	5	5	5	5"	5"	5"	5"	5	5	5	5	5
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2"	2"	2"	2"	2	2	2	2	2	2	2	2	2"	2"	2"	2"	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	101	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
3D EFFECT COIL DRAIN, TEMPERATURE, °F	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144	144
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25	25	25	25	25	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132	132
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122	122
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
FEED TO 1ST EFFECT, TEMPERATURE, °F	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104	104
CIRC. WATER OVERBOARD, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
BRINE PUMP DISCHARGE PRESSURE, #G	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03
AIR EJECTOR DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

61600
29000
37600

9-6-67

#2

9-5-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07622300		
0100	07645600	1600	
0200	07647100	1500	
0300	07649200	1800	1 HR-20 min
0400	07650400	1400	
0500	07652100	1700	
0600	07654100	2000	1 HR-20 min
0700	07655600	1500	
0800	07657000	1400	
0900	07658500	1500	
1000	07660000	1500	
1100	07661600	1600	
1200	07663000	1700	
1300	07665700	1700	
1400	07667300	1600	
1500	07668900	1600	
1600	07630400	1500	
1700	07632000	1620	
1800	07633700	1700	
1900	07635300	1600	
2000	07636800	1500	
2100	07638400	1600	
2200	07640100	1700	
2300	07642200	2100	1 HR 20 min
2400	07643900	1600	
		37900	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	94		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	151400		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

0000-0400
#2 - EVAP DIST TO #34POT

ADDED 50Z CHLORINE PER 1000 GALS

SIGNED McRory Hill

0400-0800
#2 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 Gals

SIGNED R. Shppard

0800-1200
#- 2 EVAP. DIST. TO
#- 3 CENTER

SIGNED E. J. Vagallanes

1200-1600
#2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED McRory Hill

1600-2000
#2 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 Gals Dist.

SIGNED R. Shppard

2000-2400
#- 1 EVAP. DIST. TO
#- 3 CENTER
(Added 80Z chlorine
per 1000 gals Dist.

SIGNED E. J. Vagallanes

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

PLATE NO. 11613 (BACK)

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

U. S. S. *CHINA MONITOR DOPE*PLANT NO. *2*

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ^{AHEAD} OR _{BACK}

MINUTES AT

DATE

19*67*

	9-5-67																							
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	5	5	5	5"	5"	5"	5"	5	5	5	5	5	5	5	5	5"	5"	5"	5"	5	5	5	5	5
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2"	2"	2"	2"	2	2	2	2	2	2	2	2	2"	2"	2"	2"	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	186	186	184	184	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	158	160	160	160	160	160	160	160	160	158	156	156	156	160	160	160	160	160	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	23	23	22	22"	22"	22"	22"	22	22	22	22	23	23	23	23	22"	22"	23	23	23	23	23	23	23
3D EFFECT COIL DRAIN, TEMPERATURE, °F	144	144	144	144	144	144	144	144	144	144	144	138	138	138	138	142	142	144	144	144	144	144	144	144
3D EFFECT SHELL PRESSURE, "HG	25	25	25	24"	25"	25"	25"	25	25	25	25	26	26	26	26	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	130	130	130	132	132	132	132	132	132	132	132	126	126	126	128	128	128	128	132	130	130	130	130	130
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	96	96	96	96	90	90	90	92	92	92	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	110	110	110	120	120	120	120	120	120	120	120	116	116	116	116	120	120	120	120	116	116	116	116	116
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	94	94	94	94	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	74	74	73	74	74	74	73	74	74	74	74	72	72	73	74	74	74	73	73	73	73	73	73	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	74	74	73	74	74	74	73	74	74	74	74	72	72	73	74	74	74	73	73	73	73	73	73	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	140	140	140	146	146	146	146	146	146	146	146	142	142	142	144	144	144	144	146	146	146	146	146	146
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	160	166	166	166	166	166	166	166	166	164	164	164	166	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	104	104	104	104	106	104	104	104	108	108	108	108	100	100	104	104	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	4	4	4	4	3	3	3	3	3	3	3	3	3	3	4	4	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	18	18	18	20	20	20	20	20	20	20	20	18	18	18	18	18	18	20	20	20	20	20	20	20
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26"	26"	26"	26"	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	18	18	18	18	18	18	18	18	20	20	20	20	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3"	3"	3"	3"	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	35	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	2.0	2.0	2.0	1.5	1.5	1.5	1.5	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.5	1.5	1.5	1.5	2.0	2.0	2.0	2.0	2.0
AIR EJECTOR DRAINS, SALINITY—E. P. M.	20	20	20	30	30	30	30	30	30	30	30	40	40	40	40	40	40	40	40	20	20	20	30	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

622300
585600
36700

9-5-67

#-2

9-1-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07582000		
0100	07605900	1700	
0200	07607300	1600	
0300	07609100	1800	
0400	07610800	1700	
0500	07612500	1700	
0600	07614200	1700	
0700	07615900	1700	
0800	07617500	1600	
0900	07619100	1600	
1000	07620700	1600	
1100	07622300	1600	
1200	07585600	1800	
1300	07585600	1800	
1400	07587300	1700	
1500	07589100	1800	
1600	07590800	1700	
1700	07592500	1700	
1800	07594100	1600	
1900	07595900	1800	
2000	07597600	1700	
2100	07599200	33,700	1600
2200	07600800		1600
2300	07602400		1600
2400	07604000		1600

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	70		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	111100		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3576 (REV. 11-50) BACK

0000-0800
2 EVAP DIST TO # 3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED McRoy Hall

0800-1200
2 EVAP DIST. TO # 3 &
ADDED 80Z CHLORINE PER 1000 GALS.

SIGNED R. Sheppard

0800-1200
#-2 EVAP. DIST. TO
#-3 &

(Added 80Z CHLORINE TO #-3 CENTER -
per 1000 gals DIST.

SIGNED E. J. Magallanes

Stocked in CDS

1200-1600
2-EVAP DIST TO # 3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED McRoy Hall

1600-2000
2 EVAP. DIST. TO # 3 &
ADDED 80Z CHLORINE PER 1000 GALS

SIGNED R. Sheppard

2000-2400
#-2 EVAP. DIST. TO
#-1 STD FEED - - -
@ 23:00 SHIFTED DIST.
(Added 80Z CHLORINE per
1900 GALS DIST.

SIGNED E. J. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S. *USSA-100*PLANT NO. *1*

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ^{AHEAD} OR _{BACK}

MINUTES AT

DATE *9-4*19 *67*

	9 - 5 - 67												9 - 21 - 67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	9	9	9	8	8	8	8	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3"	3"	3"	3"	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	8	8	8	8"	8"	8"	8"	8	8	8	8	8	8	8	8	8"	8"	8"	8"	8	8	8	8	8
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	180	180	180	180	182	182	182	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
1ST EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16"	16"	16"	16"	16	16	16	16	16
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	160	160	160	160	158	158	158	158	158	158	158	158	160	160	160	160	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	17	17	17	17"	17"	17"	17"	17	17	17	17	17	17	17	17	17"	17"	17"	17"	17	17	17	17	17
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	148	148	148	148	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	20	20	20	24"	24"	24"	24"	20	20	20	20	20	20	20	20	24"	24"	24"	24"	20	20	20	20	20
CONDENSATE TO COOLER, TEMPERATURE, °F	126	126	126	126	126	126	126	126	128	128	128	128	128	128	128	126	126	126	126	126	126	126	126	126
CONDENSATE FROM COOLER, TEMPERATURE, °F	89	89	89	88	88	88	88	88	88	88	88	88	88	88	88	89	88	88	88	88	88	88	88	89
BRINE OVERBOARD, TEMPERATURE, °F	116	116	116	118	118	118	118	118	118	118	118	118	118	118	118	118	118	120	120	118	118	118	118	118
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	74	74	73	74	74	74	73	74	74	74	74	73	72	73	74	74	74	73	73	73	73	73	73	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	74	74	73	74	74	74	73	74	74	74	74	73	72	73	74	74	74	73	73	73	73	73	73	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	166	164	164	164	166	166	166	166	166	164	164	164	164	166	166	166	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	104	104	104	104	104	104	104	104	106	106	106	106	106	106	106	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
CIRC. PUMP DISCHARGE PRESSURE, #G	16	16	16	17	17	17	17	17	17	17	17	16	16	16	16	16	16	16	16	16	16	16	16	16
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26"	26"	26"	26"	26	26	26	26	26	26	26	26	26"	26"	26"	26"	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	17	17	17	16	16	16	16	16	16	16	16	14	14	14	14	16	16	17	17	17	17	17	17	
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	10	10	10	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.8	1.8	1.8	1.5	1.5	1.5	1.5	1.8	1.8	1.8	1.8	1.75	1.75	1.75	1.75	1.5	1.5	1.5	1.5	1.8	1.8	1.8	1.8	1.8
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	40	30	30	30	20	20	20	20	30	30	30	40	40	30	30	20	20	20	20	20	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

95600
65500
30100

9-5-67

H-1

9-4-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12364200		
0100	12382600	1300	
0200	12383800	1200	
0300	12385100	1300	
0400	12386500	1400	
0500	12387800	1300	
0600	12389200	1400	
0700	12390500	1300	
0800	12391800	1300	
0900	12393100		1300
1000	12394300		1300
1100	12395600		1300
1200	12365500	1300	
1300	12366900	1400	
1400	12368200	1300	
1500	12369500	1300	
1600	12370800	1300	
1700	12372200	1400	
1800	12373500		1300
1900	12374800	1300	
2000	12376100	1300	
2100	12377400	21100	1300
2200	12378700		1300
2300	12380000		1300
2400	12381300		1300

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	70		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	94000		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

0000-0400
#1 EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED McRay Hill

0400-0800
#1 Evap. Dist. to #3 &
Add'd 80z chlorine per 1000 Gals

#1 port-23'-Test 2 Drops
#1 stbd-20'-Test 2 Drops

#2 port-23'-Test 2 Drops
#2 stbd-22'-Test 2 Drops

SIGNED R. Shppard

0800-1200
#-1 EVAP. DIST. TO
#3 & 1 STBD FEED

SIGNED E. J. Magallanes

1200-1600
#1 EVAP DIST TO #3 POP

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED McRay Hill

1600-2000
#1 Evap. Dist. to #3 &
@ 1700 #1 Evap. Dist. to #1 stbd. feed
@ 1800 #1 Evap. Dist. to #3 &
Add'd 80z chlorine per 1000 Gals

SIGNED R. Shppard

2000-2400
#-1 EVAP. DIST. TO
#1 STBD. FEED...
@ 23:00 Shifted Dist
TO #3 CENTER...
ADDED 80Z CHLORINE PER 100
GALS DIST.
SIGNED E. J. Magallanes

Stocked in CDS

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

U. S. S. GREEN, LORAIN DORIS PLANT NO. 1

SET CLOCKS ~~BACK~~ ^{AHEAD} 20 min MINUTES AT 2300-0100-0500

DATE 9-3, 1967

PLATE NO. 11613

39800
32,100

64200
12332100
32100

9-4-67

#1

9-3-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12330700		
0100	12350100	1400	
0200	12351500	1400	
0300	12353300	1800	1 Hr 20 MIN
0400	12354500	1200	
0500	12355900	1400	
0600	12357700	1800	1 Hr 20 MIN
0700	12359000	1360	
0800	12360300	1300	
0900	12361600		1300
1000	12362900		1300
1100	12364200		1300
1200	12365100	1400	
1300	12333500	1400	
1400	12334800	1300	
1500	12336200	1400	
1600	12337500	1300	
1700	12338900	1400	
1800	12340200	1300	
1900	12341400	1400	
2000	12342900	1300	
2100	12344300	1300	1 Hr 20 MIN
2200	12345600		1300
2300	12347900		1700
2400	12348900		1400

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	45		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	60500		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

#1 EVAP DIST TO #3 & POT
ADDED 80Z CHLORINE PER 1000 GALS
SIGNED McRoy Hill

#1 Evap. Dist. to #3 &
Added 80Z chlorine per 1000 Gals
#1 part - 23-7 test 2 drops
#1 Stbd - 16-7 test 2 drops
#2 part - 23-7 test 2 drops
#2 Stbd - 23-7 test 2 drops
SIGNED R. Shippard

#-1 EVAP. DIST. TO
#-1 Stbd FEED...
SIGNED E. J. Hagallman

#1 EVAP DIST TO #3 & POT
ADDED 80Z CHLORINE PER 1000 GALS
SIGNED McRoy Hill

#1 Evap. Dist. to #3 &
Add-d 80Z chlorine per 1000 Gals
#-1 EVAP. DIST. TO
#-1 Stbd FEED...
SIGNED R. Shippard

#-1 EVAP. DIST. TO
#-1 Stbd FEED...
SIGNED E. J. Hagallman

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

GREEN, LOTHOM POPE

PLANT NO.

2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
FOR
BACK

20 MIN

MINUTES AT

2300-0100-0500

DATE

9-3

19

67

	9-4-67												9-3-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	162	162	162	162	158	158	158	158	158	158	158	158	160	160	162	162	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	132	132	132	132	132	132	132	126	126	126	126	132	132	132	132	132	132	132	132	132	132	132	132	132
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
BRINE OVERBOARD, TEMPERATURE, °F	125	125	125	125	125	125	125	125	115	115	115	115	128	128	130	128	128	128	128	125	125	125	125	125
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	73	73	73	72	72	72	73	73	73	73	73	73	73	73	73	73	73	73	72	72	72	72	72	72
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	73	73	73	72	72	72	73	73	73	73	73	73	73	73	73	73	73	73	72	72	72	72	72	72
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	148	148	148	150	150	150	150	148	148	148	148	148	148	148	148	148	148	148	150	150	148	148	148	148
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	170	170	170	170	168	168	168	168	168	168	168	168	168	168	168	170	170	168	168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	106	106	106	106	100	100	100	100	106	106	106	106	106	106	106	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18	18
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	30	30	30	30	30	30	30	40	40	40	40	50	50	50	50	50	50	50	30	20	20	20	20	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

82000
42200
29800

9-4-67

#-2

9-3-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07540700		
0100	0756400	1600	
0200	07563700	1700	
0300	07568000	2200	1 Hr. 20 MIN.
0400	07569400	1400	
0500	07571300	1700	
0600	07573600	2300	1 Hr. 20
0700	07575300	1700	
0800	07576800	1500	
0900	07578400	1600	
1000	07580100	1700	
1100	07582000	1900	
1200	07582200	1500	
1300	07583900	1700	
1400	07585500	1600	
1500	07587200	1700	
1600	07588700	1500	
1700	07590300	1400	
1800	07591900	1600	
1900	07593400	1700	
2000	07595200	1600	
2100	07596900	1700	
2200	07598500	43,700	1600
2300	07600700		2200 (1 Hr 20 MIN)
2400	07602400		1700
			5,500

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	45		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	69900		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400
#2 - EVAP DIST TO #3 & POT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED McRay Hill

0400-0800
#2 Evap. Dist. to #3 &
Added 8 oz chlorine per 1000 gals

SIGNED R. Shippard

0800-1200
#-2 EVAP. DIST. TO
#-3 CENTER
(Added 8 oz chlorine
per 1000 gals Dist.)

SIGNED L. J. Magallanes

1200-1600
#2 - EVAP DIST TO #3 POT

ADDED 8 OZ CHLORINE PER 1000 GALS

SIGNED McRay Hill

1600-2000
#2 Evap. Dist to #3 &
Added 8 oz chlorine per 1000 gals

SIGNED R. Shippard

2000-2400
#-2 EVAP. DIST. TO
#-2 PORT & #2 STBD
FEED.
@ 23:00 Shifted Dist.
to #-1 STBD FEED.

SIGNED L. J. Magallanes

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

THEAT. (NO POINT) DORT PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS

AHEAD
OR
BACK

20 min

MINUTES AT 2300-0100-0500

DATE

9-2

19

67

	9-3-67												9-2-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	8	8	7	7	7	8	8	8	8	8	8	7	7	7	8	8	9	7	8	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE, #G	5	4	4	4	4	5	5	5	5	5	5	4	4	4	4	5	5	5	5	5	5	5	5	5
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160	160
2D EFFECT SHELL PRESSURE, "HG	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	148	148	148	148	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
CONDENSATE TO COOLER, TEMPERATURE, °F	132	132	132	132	132	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134	134
CONDENSATE FROM COOLER, TEMPERATURE, °F	94	96	96	94	94	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95
BRINE OVERBOARD, TEMPERATURE, °F	124	126	126	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125	125
STEAM TO AIR EJECTOR, PRESSURE, #G	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	73	73	73	74	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	73	73	73	74	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148
FEED TO 1ST EFFECT, TEMPERATURE, °F	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168	168
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	40	40	40	40	40	40	40	50	50	50	50	50	50	50	50	50	50	50	50	20	20	20	20	40
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

40700
07501700
39000

9-3-67

#2

9-2-67

DISTILLED WATER RECORD

REMARKS

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	07500000		
0100	07523400	1700	
0200	07524900	1700	
0300	07527100	2200	
0400	07528700	1600	
0500	07530400	1700	
0600	07532400	2200	
0700	07534200	1600	
0800	07535800	1600	
0900	07537400	1600	
1000	07539100	1700	
1100	07540700	1600	
1200	07541700	1700	
1300	07503100	1500	
1400	07504900	1700	
1500	07506200	1600	
1600	07508000	1500	
1700	07509400	1600	
1800	07511300	1700	
1900	07512900	1600	
2000	07514500	1600	
2100	07516100	1600	1600
2200	07517700	1600	1600
2300	07519900	2200	2200
2400	07521500	1600	1600

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	21		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	29200		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

0000-0400
#2 - EVAP DIST TO #3 POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED *M. R. Hill*

0400-0800
#2 Evap. Dist. To #3 &
Added 80Z chlorine per 1000 Gals.

1 HR 20 MIN

SIGNED *R. Shippard*

0800-1200
#2 EVAP. DIST. TO
#3 CENTER -

SIGNED *E. J. Magallanes*

1200-1600
#2 - EVAP DIST TO #3 & POT

ADDED 80Z CHLORINE PER 1000 GALS

SIGNED *M. R. Hill*

1600-2000
#2 Evap. Dist. To #3 &
Added 80Z chlorine per 1000 Gals.

SIGNED *R. Shippard*

2000-2400
#2 EVAP. DIST. TO
#2 STD FEED.

SIGNED *E. J. Magallanes*

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY ✓

U. S. S.

USNSC 1054111 DopePLANT NO. 1

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ^{10 AHEAD} BACK20 min

MINUTES AT

2300-0100-0500

DATE

9-21967

	9-3-67												9-2-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	8	8	9	9	9	9	9	9	9	9	9	8	8	8	5	9	9	8	9	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	3	3	3	3"	3"	3"	3"	3	3	3	3	3	3	3	3	3"	3"	3"	3"	3	3	3	3	3
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	8	8	9	8"	8"	8"	8"	5	8	8	8	8	8	8	8	8"	8"	8"	8"	8	8	8	8	8
STEAM TO 1ST EFFECT, TEMPERATURE, °F	240	239	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	180	180	180	180	182	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
1ST EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16"	16"	16"	16"	16	16	16	16	16
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	140	140	140	140	140	150	150	150	150	150	150	150	160	160	160	160	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	17	17	17	17"	17"	17"	17"	17	17	17	17	17	17	17	17	17"	17"	17"	17"	17	17	17	17	17
3D EFFECT COIL DRAIN, TEMPERATURE, °F	146	146	148	150	150	148	148	146	146	146	146	146	146	146	146	148	150	150	150	146	146	146	146	146
3D EFFECT SHELL PRESSURE, "HG	20	20	20	24"	24"	24"	24"	20	20	20	20	20	20	20	20	24"	24"	24"	24"	20	20	20	20	20
CONDENSATE TO COOLER, TEMPERATURE, °F	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124
CONDENSATE FROM COOLER, TEMPERATURE, °F	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
STEAM TO AIR EJECTOR, PRESSURE, #G	94	94	94	94	94	94	94	94	94	94	94	94	94	94	94	95	95	95	95	94	94	94	94	94
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	73	73	73	74	73	73	73	73	73	73	73	70	91	92	73	72	72	73	73	72	72	72	72	73
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	73	73	73	74	73	73	73	73	73	73	73	70	91	92	73	72	72	73	73	72	72	72	72	73
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	164	164	166	166	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164	164
CIRC. WATER OVERBOARD, TEMPERATURE, °F	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106	106
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
BRINE PUMP SUCTION PRESSURE, #G	26	26	26	26"	26"	26"	26"	26	26	26	26	26	26	26	26	26"	26"	26"	26"	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	10	10	10	10"	10"	10"	10"	10	10	10	10	10	10	10	10	10"	10"	10"	10"	10	10	10	10	10
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05	1.05
AIR EJECTOR DRAINS, SALINITY—E. P. M.	40	40	40	30	20	20	20	20	20	40	40	30	30	30	20	20	20	20	30	20	20	20	20	30
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

330700 39
12298500 71,200
32,200 9-3-67

REMARKS

9-2-67

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000	12297100		
0100	12316400	1300	
0200	12317800	1400	
0300	12319600	1800	
0400	12321000	1400	
0500	12322300	1300	
0600	12324100		1800
0700	12325400		1300
0800	12326700		1300
0900	12328000		1300
1000	12329400	1400	
1100	12330700	1300	
1200	12298500	1400	
1300	12301800	1300	
1400	12301400	1400	
1500	12302600	1200	
1600	12303800	1200	
1700	12305200	1400	
1800	12306500	1300	
1900	12307900	1400	
2000	12309200	1300	
2100	12310600	1400	
2200	12311900	20,9	1300
2300	12313700		1800
2400	12315100		1400
			13,000

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD	21		
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD	27100		
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3076 (REV. 11-50) BACK

#1 EVAP DIST TO #34 POT
ADDED 802 CHLORINE PER 1000 GALS
SIGNED M^c Roy Hill

#1 EVAP. DIST TO #34
@ 0500 shifted dist to #1 still feed
#1 port - 23' - Test 2 drops
#1 still - 19' - Test 2 drops
1 Hr 20 min
#2 port - 21' - Test 2 drops
#2 still - 22' - Test 2 drops
SIGNED R. Skypood

#1 EVAP. DIST. TO
#1 STILL FEED...
@ 0900 Shifted Dist.
TO #3 CENTR...
SIGNED E. J. Yagallane

Stocked in CDS

#1 EVAP DIST TO #34 POT
ADDED 802 CHLORINE PER 1000 GALS
SIGNED M^c Roy Hill

#1 EVAP. DIST. TO #34
Added 802 chlorine per 1000 gals.
SIGNED R. Skypood

#1 EVAP. DIST. TO
#2 STILL FEED...
SIGNED E. J. Yagallane

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

STEAM. LOHMAN POPPE PLANT NO. 2

AT ANCHOR

TIME: ZONE DESCRIPTION

SET CLOCKS ^{AWARD} _{BACK} 20 MIN.

MINUTES AT 2300-2100-0500 DATE 9-1

1967

	9-2-67											9-1-67												
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE #G	7	7	7	7	7	7	7	7	7	7	7		4	4	4	0	0	7	7	8	8	8	8	8
STEAM FROM REG. VALVE, PRESSURE #G	5"	5"	5"	5"	5"	5"	5"	5	5	5	5		2"	0	0	0	0	10"	10"	5	5	5	5	5"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	2	2	2	2"	2"	2"	2"	2	2	2	2		1	0	0	0	0	5"	6"	3	3	3	3	2
STEAM TO 1ST EFFECT, TEMPERATURE, °F	230	230	230	225	230	240	240	240	240	240	240		240	180	230	230	230	230	230	240	240	240	240	220
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	190	190	190	190	190	190	190	190	190	190	190		190	170	190	110	110	180	180	180	180	180	180	180
1ST EFFECT SHELL PRESSURE, "HG	10	10	10	10"	10"	10"	10"	10	10	10	10		8	8	8	16"	16"	10"	11"	10	10	10	10	10
2D EFFECT COIL DRAIN, TEMPERATURE, °F	158	158	158	160	160	160	160	158	158	158	158		158	150	150	104	104	150	150	158	158	158	158	158
2D EFFECT SHELL PRESSURE, "HG	22	22	22	22"	22"	22"	22"	22	22	22	22		21	22	22	22"	22"	23"	23"	22	22	22	22	22
3D EFFECT COIL DRAIN, TEMPERATURE, °F	144	144	144	146	146	146	146	146	146	146	146		144	140	140	140	140	140	140	140	140	140	140	144
3D EFFECT SHELL PRESSURE, "HG	25	25	25	25"	25"	25"	25"	25	25	25	25		25	25	25	25"	25"	25"	25"	25	25	25	25	25
CONDENSATE TO COOLER, TEMPERATURE, °F	134	134	134	134	134	134	134	134	134	134	134		139	132	132	132	132	132	132	136	136	136	136	136
CONDENSATE FROM COOLER, TEMPERATURE, °F	92	92	92	94	94	92	92	92	92	92	92		90	90	90	90	90	90	90	92	92	92	92	92
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	125	125	125	125	125	125	125	125		128	128	128	128	128	128	128	118	118	118	118	120
STEAM TO AIR EJECTOR, PRESSURE, #G	96	96	96	92	92	92	92	92	92	92	92		96	96	96	92	92	92	92	96	96	96	96	92
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	67	67	68	69	69	68	68	68	68	68	68		67	67	61	61	61	62	62	62	62	62	62	65
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	67	67	68	69	69	68	68	68	68	68	68		67	67	61	61	61	62	62	62	62	62	62	65
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F	150	150	150	150	150	148	148	148	148	148	148		150	140	140	80	130	144	144	148	148	148	148	150
FEED TO 1ST EFFECT, TEMPERATURE, °F	170	170	170	170	170	168	168	168	168	168	168		168	160	160	80	140	146	146	168	168	168	168	170
CIRC. WATER OVERBOARD, TEMPERATURE, °F	108	108	108	108	108	104	104	104	104	104	104		104	104	104	70	100	104	104	108	108	108	108	108
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5		5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	21	21	21	21	21	22	22	22	22	22	22		21	21	21	21	21	21	22	22	22	22	22	22
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	24"	24"	24	24	24	24		25	25	25	24"	24"	24"	24"	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	26	26	26	26	26	26	26	26	26	26	26		26	26	26	26	26	26	26	26	26	26	26	26
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	3	3	3	3"	3"	3"	3	3	3	3	3		1	1	1	1	1	1	1	3	3	3	3	3
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	35	35	35	35	35	35	35	35	35	35	35		42	42	42	42	42	42	42	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10		0	10	10	0	0	0	0	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0		1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
AIR EJECTOR DRAINS, SALINITY—E. P. M.	40	40	40	5.0	5.0	4.0	4.0	5.0	5.0	5.0	5.0		40	40	40	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
1ST EFFECT DRAINS, SALINITY—E. P. M.	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4		0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
CONDENSATE FROM COOLER, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0		0	0	0	0	0	0	0	0	0	0	0	0

07500000
 7410800
 29200

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	07482100	1900	
0200	07483700	1600	
0300	07486000	2300	1 Hr 20 min
0400	07487600	1400	
0500	07489300	1700	
0600	07491600	2300	1 Hr 20 min
0700	07493500	1900	
0800	07495000	1500	
0900	07496700	1700	
1000	07498400	1700	
1100	07500000	1600	
1200			
1300			
1400			
1500			
1600	07470800		
1700	07470900	100	
1800	07470900		
1900	07471600	700	
2000	07473000	1200	
2100	07474400	1400	
2200	07476000	1600	
2300	07478500	2500	1 Hr 20 min
2400	07480200	1700	
		36200	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			
CHECKED (Signature)			
APPROVED			
(Engineer Officer, U. S. N.)			

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

9-2-67
 #2 - EVAP DIST TO #3 & POT
 ADDED 80Z CHLORINE PER 1000 GALS
 SIGNED M^C Roy Hill

0800-0900
 #2 Evap. Dist to #3 &
 Added 80Z Chlorine per 1000 gals
 SIGNED R. Shyppard

0800-1200
 # - 2 EVAP. DIST. TO
 # - 3 @
 Added 80Z Chlorine
 per 1000 gals Dist.
 SIGNED E. J. Nagallanus

Stocked in CDS

9-1-67
 #2 - EVAP DIST TO #3 & POT
 ADDED 80Z CHLORINE PER 1000 GALS
 LITE OFF 1300
 SIGNED M^C Roy Hill

1200-1600
 #2 Dist to #3 & Pot
 Elect. working on it,
 SIGNED R. Shyppard

2000-2400
 # - 2 EVAP. DIST. TO
 # - 3 CENTER
 Added 80Z Chlorine
 per 1000 gals Dist.
 SIGNED E. J. Nagallanus

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.

LOW PRESSURE DISTILLING PLANT OPERATING RECORD

UNDERWAY

U. S. S.

THE LITTLE HOPE PLANT NO. I

AT ANCHOR

TIME: ZONE DESCRIPTION

AHEAD
ON
BACK

20 MIN

MINUTES AT 2300-2400-2500

DATE

9-2

1957

	9-2-67												9-1-67											
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400
STEAM TO REG. VALVE, PRESSURE, #G	9	9	9	9	9	8	8	8	8	8	8	5	6	6	6	8	8	8	8	8	8	8	8	9
STEAM FROM REG. VALVE, PRESSURE, #G	2"	2"	2"	3"	3"	3"	3"	3	3	3	3	3	6"	0	0	2"	2"	2"	2"	3	3	3	3	2"
STEAM TO 1ST EFFECT, PRESSURE, "HG OR #G	8	8	8	8"	8"	8"	8"	8	8	8	8	8	9	7	7	9"	9"	8"	9	9	9	9	9	8
STEAM TO 1ST EFFECT, TEMPERATURE, °F	235	232	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	230
1ST EFFECT COIL DRAIN, TEMPERATURE, °F	180	180	180	180	180	180	180	180	180	180	180	180	170	175	175	175	175	175	175	175	180	180	170	180
1ST EFFECT SHELL PRESSURE, "HG	16	16	16	16"	16"	16"	16"	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16	16
2D EFFECT COIL DRAIN, TEMPERATURE, °F	156	156	156	160	160	160	160	156	156	156	156	156	158	158	158	158	158	158	158	158	158	158	158	156
2D EFFECT SHELL PRESSURE, "HG	17	17	17	16"	16"	17"	17"	17	17	17	17	17	16	16	16	17"	17"	17"	17"	17	17	17	17	17
3D EFFECT COIL DRAIN, TEMPERATURE, °F	148	148	148	150	150	150	150	146	146	146	146	148	148	148	148	148	148	148	148	148	148	148	148	146
3D EFFECT SHELL PRESSURE, "HG	25	25	25	24"	24"	24"	24"	24	24	24	24	24	25	25	25	25"	25"	25"	25"	25	25	25	25	24
CONDENSATE TO COOLER, TEMPERATURE, °F	129	129	128	128	128	128	128	128	128	128	128	128	126	128	128	128	128	128	128	128	128	128	128	124
CONDENSATE FROM COOLER, TEMPERATURE, °F	86	86	88	88	88	88	86	86	86	86	86	86	85	86	86	86	86	86	86	86	86	86	86	84
BRINE OVERBOARD, TEMPERATURE, °F	120	120	120	124	125	125	125	125	125	125	125	125	118	118	128	128	128	128	128	118	118	118	118	120
STEAM TO AIR EJECTOR, PRESSURE, #G	96	96	96	96	96	96	96	96	96	96	96	96	89	90	90	94	94	94	94	96	96	96	96	96
AIR EJECTOR DRAINS, TEMPERATURE, °F																								
CIRC. WATER INJECTION, TEMPERATURE, °F	67	67	68	69	69	68	68	68	68	68	68	68	67	67	61	58	55	53	62	62	62	62	62	65
CIRC. WATER TO CONDENSATE COOLER, TEMPERATURE, °F	67	67	68	69	69	68	68	68	68	68	68	68	67	67	61	58	55	53	62	62	62	62	62	65
CIRC. WATER TO DISTILLER CONDENSER, TEMPERATURE, °F																								
FEED TO AIR EJECTOR CONDENSER, TEMPERATURE, °F																								
FEED TO 2D EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT VAP. FD. HEATER, TEMPERATURE, °F																								
FEED TO 1ST EFFECT, TEMPERATURE, °F	166	166	168	166	166	166	166	166	166	166	166	166	162	162	162	162	162	164	166	166	166	166	166	166
CIRC. WATER OVERBOARD, TEMPERATURE, °F	104	104	106	106	106	106	106	106	104	104	104	104	104	104	104	102	102	102	104	104	104	104	104	104
CIRC. PUMP SUCTION PRESSURE, #G	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
CIRC. PUMP DISCHARGE PRESSURE, #G	17	17	17	18	18	18	18	18	18	18	18	18	17	17	17	17	17	17	18	18	18	18	18	18
BRINE PUMP SUCTION PRESSURE, #G	25	25	25	25"	25"	25"	25"	25	25	25	25	25	26	26	26	26"	26"	26"	26"	26	26	26	26	26
BRINE PUMP DISCHARGE PRESSURE, #G	20	20	20	20	20	20	20	20	20	20	20	20	27	27	27	20	20	20	20	20	20	20	20	20
FEED PUMP SUCTION PRESSURE, #G																								
FEED PUMP DISCHARGE PRESSURE, #G																								
1ST EFFECT DRAIN PUMP SUCTION PRESSURE, #G	9	9	9	9"	9"	9"	9	9	9	9	9	9	7	7	7	9"	9"	9"	9"	10	10	10	10	10
1ST EFFECT DRAIN PUMP DISCHARGE PRESSURE, #G	38	38	38	38	38	38	38	38	38	38	38	38	0	35	35	35	35	35	36	36	36	36	36	36
F. W. PUMP DISCHARGE PRESSURE	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
FEED DENSITY, 32NDS																								
BRINE OVERBOARD DENSITY, 32NDS	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
AIR EJECTOR DRAINS, SALINITY—E. P. M.	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1ST EFFECT DRAINS, SALINITY—E. P. M.	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CONDENSATE FROM COOLER, SALINITY—E. P. M.																								

12297100
12270000
27100

I

DISTILLED WATER RECORD

HOUR ENDING	METER READING	GALLONS	
		SHIPS TANKS*	FEED TANKS*
0000			
0100	12283100	1300	
0200	12284400	1300	
0300	12286100	1700	1 hr 20 min
0400	12287400	1300	
0500	12288700	1300	
0600	12290500		1 800
0700	12291900		1400
0800	12293000		1100
0900	12294300		1300
1000	12295700	1200	
1100	12297100		1400
1200			7,000
1300			
1400			
1500			
1600	12270000		
1700	12271400	1400	
1800	12272700	1400	
1900	12274100	1400	
2000	12275500	1400	
2100	12277000	1500	
2200	12278500	1500	
2300	12280400	1900	1 hr 20 min
2400	12281700	1300	
		20,100	

* Indicate under REMARKS number of tanks being filled.

SCALING RECORD

	EFFECT		
	NO. 1	NO. 2	NO. 3
DATE LAST SCALED			
HOURS BROUGHT FORWARD			
HOURS THIS DATE			
HOURS TO DATE			
GALLONS BROUGHT FORWARD			
GALLONS THIS DATE			
GALLONS TO DATE			

CHECKED (Signature)

APPROVED

(Engineer Officer, U. S. N.)

NAVSHIPS 3676 (REV. 11-50) BACK

REMARKS

9-2-67
I EVAP DIST TO # 3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
NR-20 min
SIGNED McRoy Hill

0000-0400
1 EVAP. DIST. TO # 3 &
@ 0000 shifted dist. to # 1 std. feed
1 port-23'-7" st 2 drops
1 std-14'-7" st 2 drops
2 port-21'-7" st 2 drops
2 std-15'-7" st 2 drops
SIGNED R. Shaffer

0400-1200
1 EVAP. DIST. TO
1 STD FEED....
@ 0900 shifted to
3 & @ 1000 DIST. TO
1 STD FEED
SIGNED E. J. Magallanes

Stocked in CDS

9-1-67
I EVAP DIST TO # 3 & POT
ADDED 8 OZ CHLORINE PER 1000 GALS
NOTE OFF 1400
SIGNED McRoy Hill

1200-1800
1 EVAP. DIST. TO # 3 &
ADDED 8 OZ chlorine per 1000 gals dist.
SIGNED R. Shaffer

1800-2400
1 EVAP. DIST. TO
3 CENTER
Added 8 oz chlorine
per 1000 gals Dist....
SIGNED E. J. Magallanes

For disposal of this record see current Records Disposal Instructions for Vessels of the U. S. Navy.