

USNS GEN

WengelDATE 6-6-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	6-2	4	M-800K F1-5M-FR1.5M
CARGO WINCHES			#1 #2 COLD 1.6M HOT 3 COLD 200K HOT 200K
ANCHOR WINDLASS	4th	1	4 Megs
CAPSTAN	4th	1	#1-20M #2-30M
FIRE ALARMS	Daily		
EMERG. BATTERIES	6-2		1.210 on charge 0730
DIESEL BATTERIES	6-2		OK 1.230
PUMP PUMP BATTERIES			
DIESEL GENERATORS	5th	1/2	NO 10A &
LAUNDRY SUPPLY	5th	1 hr.	LO. Hi.
RECTIFIERS	Daily		
Engine Rm. Vent. 1	4th	3M	6/5/69
2	4th	200K	6/5/69
3	4th	3M.	6/5/69
4	4th	250K	6/5/69

Signature

Electrician

USNS GEN JOHN POPE (TAP110) DATE 26 MAY 1969

ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	5/28/69	4 HRS	2 MEGGS
CARGO WINCHES	5/28/69	1 HR.	#5-4 MEGGS #66 MEGGS
ANCHOR WINDLASS	5/28/69	1 HR	8 MEGGS
CAPSTAN	5/28/69	1 HR	#1-1 MEGGS #25 MEGGS
FIRE ALARMS	DAILY		
EMERG. BATTERIES	5/28/69	OK	
DIESEL BATTERIES	5/28/69	OK	
FIRE PUMP BATTERIES	5/28/69	OK	
DIESEL GENERATORS	5/28/69	2 HRS.	6 MEGGS
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

TESTED ALL BILGE AIR VALVES 5-28-69

TEST RUN #2 FIRE PUMP (DIESEL EMERG) 5-28-69

Signature

R. J. [Signature]
Electrician

USNS GEN

Werge

DATE

MAY 29thROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	26 th	4	M-200K F1.5M FP-1.5
CARGO WINCHES	29 th	1/4	#1-20M #2-300K
ANCHOR WINDLASS	28 th	1	4M.
CAPSTAN	28 th	1	#1-50M #2-30M
FIRE ALARMS	DA. 1/4		
EMERG. BATTERIES	26 th		1.240
DIESEL BATTERIES	26 th		1.230
FIRE PUMP BATTERIES			
DIESEL GENERATORS	28	2	UNDER LOAD OK.
LAUNDRY SUPPLY	29 th	1	LO-2.3 H. 30M.
RECTIFIERS	DA. 1/4		

Signature

W. C. Brooks

Electrician

USNS GEN JOHN PIPE (TAP110)

DATE 18 MAY 1964

ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	5/19/69	4 HRS	2 MEGGS.
CANPO WINCHES	5/23/69	1 HR.	#5 - 3 MEGGS #6 - 6 MEGGS
ANCHOR WINDLASS	5/21/69	1 HR	8 - MEGGS.
CAPSTAN	5/21/69	1 HR	#1 - 105M #2 - 20-MEGGS
FIRE ALARMS		DAILY	
ENGINE BATTERIES	5/19/69	OK	
DIESEL BATTERIES	5/19/69	OK	
FIRE PUMP BATTERIES	5/19/69	OK	
DIESEL GENERATOR	5/21/69	1/2 HR.	6 MEGGS.
LAUNDRY SUPPLY		WEIGH ONLY	
RECTIFIERS		DAILY	

TESTED ALL BILGE AIR VALVES 5-22-69

FIRE PUMP #1 OUT REPAIRS

TESTED # 2 PUMP FIRE WEEKLY TEST.

Signature

Electro: an

USNS GEN

Weigel

DATE

5.23-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	19th	4	M-800K FI 5M FP-1.5M
CABLE WINCHES	23rd	1/2	#1-5M #2-200K
ANCHOR WINDLASS	1-HR		Cold-4M Ht 800K
CAPSTAN	1-HR		#1-30M #2-30M
FIRE ALARMS	Daily		
EXT'L BATTERIES	19th		Charged. OK
DIESEL BATTERIES	19th		Charged to 1.260
FIRE PUMP BATTERIES			
DIESEL GENERATORS			
LAUNDRY SUPPLY	29th	1	100K to 30M-H
RECTIFIERS	Daily		

Signature

W. Brooks

Electrician

USNS GEN

JOHN POPE (TAP110)

DATE

21 APR 1969


ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/12/69	4 Hrs.	2 meggs.
CARGO WINCHES	4/16/69	1 HR.	#5-2 meggs #6-6 meggs
ANCHOR WINDLASS	4/13/69	1 HR.	7- meggs.
CAPSTAN	4/13/69	1 HR.	#1-1-Meggs #2-15-Meggs
FIRE ALARMS	DAILY		
EMERG. BATTERIES	4/12/69	8 AT.	
DIESEL BATTERIES	4/12/69	8 AT.	
FIRE PUMP BATTERIES	4/12/69	8 AT.	
DIESEL GENERATORS	4/14/69	1/2 HR.	6 meggs.
LAUNDRY SUPPLY	WEIBEL ONLY		
RECTIFIERS	DAILY		

TESTED ALL BILGE AIR VALVES

TEST. #2 FIRE PUMP #1 FIRE PUMP UNDER REPAIRS

Signature



Electrician

USNS GEN

Weigel.

DATE

May. 16thROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	13 th	4	Cold - M-100K FI 4M FP 1.5M Hot - M-100K FI 20M FP 800K
CARGO WINCHES	16 th		#1 - 2M - #2 - 200K
ANCHOR WINDLASS	14 th	1	4 Megs
CAPSTAN	14 th		#1 - 20M #2 - 30M.
FIRE ALARMS	Daily		
EMERG. BATTERIES	12 th	OK	1240
DIESEL BATTERIES	12 th	OK	1240
FIRE PUMP BATTERIES	—		
DIESEL GENERATORS	14 th	1/2	
LAUNDRY SUPPLY	14	1 1/2	40 - 300K H. - 50M
RECTIFIERS	Daily		

Signature

W. C. Brooks.

Electrician

USNS GEN

POPE (TAP 110)

DATE

5 MAY 1969


ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4-5-69	4 HRS	2 MEGGS
CARGO WINCHES	4-9-69	1 HR	#5-2 MEGGS #6-6 MEGGS
ANCHOR WINDLASS	4-7-69	1 HR	2 17 MEGGS
CAPSTAN	4-7-69	1 HR	#1-1 MEGG #2-15 MEGGS
FIRE ALARMS	DAILEY		
EMERG. BATTERIES	4-5-69		
DIESEL BATTERIES	4-5-69		
FIRE PUMP BATTERIES	4-5-69		
DIESEL GENERATORS	4-7-69	1/2 Hr.	6 MEGGS
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILEY		

TESTED ALL BILGE AIR VALVES 5-7-69

TEST RUN EMERG. FIRE PUMPS - 5-7-69

Signature



Electrician

USNS GEN Gen. WeigelDATE 5-9-74ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	5 th	4	M-600K F1.5M FP-1.5M
CARGO WINCHES	9 th		#1-2M - #2-200K
ANCHOR WINDLASS	7 th	1	4 Megs
CAPSTAN	7 th	1	#1-20M #2-30M
FIRE ALARMS	Daily		
EMERG. BATTERIES	5 th		OK - 1.240
DIESEL BATTERIES	5 th		Charged Approx 24hrs*
FIRE PUMP BATTERIES			
DIESEL GENERATORS	7 th	1/2	No load.
LAUNDRY SUPPLY	7 th	1 hr	Lo. 2M Hi-15M
RECTIFIERS	Daily		

* Reading after charging
1.240

Signature

W.C. Brooks.

Electrician

USNS GEN


JOHN POPE (TAP 110)DATE 28 APRIL 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4-28-69	4 HRS.	2 MEGGS.
CABLE WINCHES	5-2-69	1 HR.	#5 52 meggs #6 6 meggs.
ANCHOR WINDLASS	4-30-69	1 HRS.	7-14 meggs
CAPSTAN	4-30-69	1 HRS.	#1 1.5-11 meggs #2-15-14 meggs
FIRE ALARMS	DAILEY		
EMERG. BATTERIES	4-28-69		
DIESEL BATTERIES	4-28-69		
FIRE PUMP BATTERIES	4-28-69		
DIESEL GENERATORS	4-30-69	2 HRS.	6 MEGGS.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILEY		

TESTED ALL BILGE AIR VALVES 4-30-69

TEST RUN EMERG. FIRE PUMPS. 4-30-69

Signature



Electrician

USNS GEN WeigelDATE May 2ndROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	28 th	4	Hot M 100K 1 20M EF 500K Cold M 100K 1 0M EF 1.5M
CARGO WINCHES	5-2	1/4	#1-2M #2-200K
ANCHOR WINDLASS	5-1	1 hr	2 Megs
CAPSTAN	5-1	1 hr	#1-20 Megs #2-30 Megs.
FIRE ALARMS	Daily		
EMERG. BATTERIES	28 th		1.210 Charge 6 hrs.*
DIESEL BATTERIES	28 th		1.240
FIRE PUMP BATTERIES			
DIESEL GENERATORS	5-1	2 hr	6 Megs.
LAUNDRY SUPPLY	5-1	1 hr	8 Megs.
RECTIFIERS	Daily		

* Battery after charge
1.240

Signature

W.C. Brooks
Electrician


USNS GEN JOHN POPE (TAP110)DATE 21 APR 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/21/69	4 HRS	2 MEGGS.
CARGO WINCHES	4/25/69	1 HR.	#5 2 MEGGS #6 6 MEGGS.
ANCHOR WINDLASS	4-23-69	1 HR.	7 - MEGGS.
CAPSTAN	4-23-69	1 HR.	#1 25-Meggs #2 - 15-Meggs
FIRE ALARMS	DAILY		
EMERG. BATTERIES	4-21-69	OK	
DIESEL BATTERIES	4-21-69	OK	
FIRE PUMP BATTERIES	4/21/69	OK	
DETAIL GENERATORS	4/23/69	1/2 HR.	6 MEGGS.
INVENTORY SUPPLY	WEEKLY ONLY		
RECTIFIERS	DAILY		

TESTED ALL BILGE AIR VALVES 4-23-69

TEST PUN LOCKS, FIRE PUMPS. 4-23-69

Signature



Electrician

USNS GEN

Weigel

DATE

4-25-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	21 st	4	HOT M-400K F1-50M FP-1M COLD M-100K F1-20M FP-1M
CARGO WINCHES	25 th		#1-2M - #2-300K
ANCHOR WINDLASS	23 rd	1	Cold-4M Hot 600K
CAPSTAN	23 rd		#1-30M #2-25M
FIRE ALARMS	Daily		
EMERG. BATTERIES	21 st		1.240 Spec. Gravity
DIESEL BATTERIES	21 st		1.240 "
FIRE PUMP BATTERIES	—		
DIESEL GENERATORS	23 rd	1/2	No load
LAUNDRY SUPPLY	25 th	1 hr.	60.400K H. 1M.
RECTIFIERS	Daily		

Signature

W. C. Brooks

Electrician

USNS GEN

BPE (TAP 118)DATE 14 APRIL 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/14/69	4 HRS.	2 MEGGS.
CARGO WINCHES	4-18-69	1 HR	#5 1 meg. #6 5 MEGGS.
ANCHOR WINDLASS	4-16-69	1 HR	7 - MEGGS.
CAPSTAN	4-16-69	1 HR	#1 1.5-Meggs #2 15-Meggs
FIRE ALARMS		DAILY	
EMERG. BATTERIES	4/14/69		
DIESEL BATTERIES	4/14/69		
FIRE PUMP BATTERIES	4/14/69		
DIESEL GENERATORS	4/16/69	2 HR	6 MEGGS. 4-17-69 1 HR RUN. POWER FAILURE
LAUNDRY SUPPLY		WEIGEL ONLY	
RECTIFIERS		DAILY	

TESTED ALL BILGE AIR VALVES - 4-16-69

TBT RUN EMERG. DIESEL FIRE PUMPS - 4-16-69

Signature

Electrician

USNS GEN WeigelDATE 4-18-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	14 th	4	Cold M-10K FI-4M FP-1.5 Hot M100K FI-1M FB-800K
CARGO WINCHES	18 th	1/4	#1-1.5M. #2-200K
ANCHOR WINDLASS	16 th	1hr	4 Megs Cold 300 K. Hot
CAPSTAN	16 th	1hr	#1-30M #2-20M.
FIRE ALARMS	Daily	-	
ENG. BATTERIES	14 th		1240
DIESEL BATTERIES	14 th		1180 on Charge @ 0730
FIRE PUMP BATTERIES	17 th	1 1/2 hr	load - Power
DIESEL GENERATORS	16 th	1/2	No load. Failures
LAUNDRY SUPPLY	15 th		Lo 400K Hi 800K
RECTIFIERS	Daily		

Signature

W. C. Brooks.

Electrician

USNS GEN POPE (TAP 110)DATE 7 APRIL 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/7/69	4 HR.	2 MEGGS.
CARGO WINCHES	4/11/69	1 HR.	#5 - 1.5 Meggs #6 - 6 Meggs.
ANCHOR WINDLASS	4/9/69	1 HR.	7 - Meggs
CAPSTAN	4/9/69	1 HR.	#1 1.5-Meggs #2 15-Meggs
FIRE ALARMS	DAILY		
EMERG. BATTERIES	4/7/69	OK	
DIESEL BATTERIES	4/7/69	OK	
FIRE PUMP BATTERIES	4/7/69	OK	
DIESEL GENERATORS	4/9/69	1/2 HR.	6 MEGGS.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

TESTED ALL BILGE AIR VALVES 4-9-69

TEST RUN EMERG DIESEL FIRE PUMPS 4-9-69

Signature


Electrician

USNS GEN

Weigel

DATE

4-17ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4-7	4	Hot M-10K FI-5M FP 1.5M Cold M-100K FI-1M FP-800K
CARGO WINCHES	4-10		#1-7M - #2-200K
ANCHOR WINDLASS	4-9	1 hr	5 M.
CAPSTAN	4-9	1 hr	#1 30M #2-30M
FIRE ALARMS	Daily		
EMERG. BATTERIES	4-7		Charged. 6 hrs
DIESEL BATTERIES	4-7		Charged. 24 hrs.
FIRE PUMP BATTERIES			
DIESEL GENERATORS	4-9	1/2	No load.
LAUNDRY SUPPLY	4-11	1 hr	Lo - 400K Hot 1.5 Hi - 800K 30M
RECTIFIERS	Daily		

Signature


W.C. Brooks

Electrician

USNS GEN GEN JOHN POPE (TAP110)DATE 1 APRIL 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/1/69	4 HR	2 MEGGS
CARGO WINCHES	4/1/69	1 HR.	#1 5.2 MEGGS #2 4 MEGGS.
ANCHOR WINDLASS	4/2/69	1 HR.	8 - MEGGS
CAPSTAN	4/2/69	1 HR.	#1 10.5-Meggs. #2 15-Meggs.
FIRE ALARMS		DAILY	
ENGINE BATTERIES	4/1/69	OK	
DIESEL BATTERIES	4/1/69	OK	
FIRE PUMP BATTERIES	4/1/69	OK	
DIESEL GENERATORS	4/2/69	1/2 HR	6 MEGGS
LAUNDRY SUPPLY		WEIGER- ONLY	
RECTIFIERS		DAILY	

Signature



Electrician

USNS GEN

WEIGELDATE April 4thROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	4/1/69		G 10M R 110M EP 1.5 H 10M F 1.5M EP 700K
CARGO WINCHES	4-4-69	1/4	#1 - 30 Megs. #2 - 200 K
ANCHOR WINDLASS	4-2	1	5 M.
CAPSTAN	4-2	1	#1 C 50M. H 50M. #2 C 50M. H 50M.
FIRE ALARMS	Daily		
EMERG. BATTERIES	4/1/69		1240 S.G.
DIESEL BATTERIES	4/1/69		1210 S.G.
FIRE PUMP BATTERIES			
DIESEL GENERATORS	4-2	1/2	
LAUNDRY SUPPLY	4-2	1	T. C 820K E 10M T. H. 1.5M T. L. H. 100H.
RECTIFIERS	Daily		

Signature

W.C. Brooks

Electrician

USNS GEN

POPE (TAP110)

DATE 24 MARCH 1969


ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DE-ICING	3/24/69	4 HR.	1.5 MEGGS.
CARGO WINCHES	3/24/69	1 HR.	#5 1.5 #6 2 MEGGS
ANCHOR WINDLASS	3/26/69	1 HR	6 - MEGGS.
CAPSTAN	3/26/69	1 HR	#1 1.5-MEGGS. #2 15-MEGGS.
FIRE ALARMS	DAILY		
EMERG. BATTERIES	3/24/69		
DIESEL BATTERIES	3/24/69		
FIRE PUMP BATTERIES	3/24/69		
DIESEL GENERATORS	3/26/69	2 HR	6 MEGGS. MONTHLY TEST.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

TESTED ALL BILGE AIR VALVES, 3/24/69

TEST RUN EMERG. DIESEL FIRE PUMPS - 3-24-69

Signature



Electrician

USNS GEN

Weigel.

DATE

3-28-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	24 th	4	Cold M. 5K FI 5-M FP 1.5M Hot M. 10K FI 65M FP 700K
CARGO WINCHES	4 hr		#1 30M #2 200K
ANCHOR WINDLASS	1 hr		5 Megs.
CAPSTAN	1 hr		#1 50M. #2 100M.
FIRE ALARMS	Daily		Charged Zon. te Batteries 24 hrs
EMER. BATTERIES	24 th		
DIESEL BATTERIES	24 th		
FIRE PUMP BATTERIES			
DIESEL GENERATORS	26 th	2 hr	Under load
LAUNDRY SUPPLY	26 th		T1 30M T11 100M
RECTIFIERS	Daily		

Signature

W. C. Brooks.

Electrician

USNS GEN

POPE (TAP110)DATE 17 MARCH 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	17 MARCH	4 HRS.	2 MEGGS
CARGO WINCHES	21 MARCH	1 HR.	#5 1.5 MEGGS #6 1.5 MEGGS
ANCHOR WINDLASS	19 MARCH	1 HR	8 - MEGGS
CAPSTAN	19 MARCH	1 HR	#1 1.5-Megs #2 15-Megs
FIRE ALARMS	DAILY		
EMERG. BATTERIES	17 MARCH		
DIESEL BATTERIES	17 MARCH		
FIRE PUMP BATTERIES	17 MARCH		
DIESEL GENERATORS	19 MARCH	1 HR	8 MEGGS
LAUNDRY SUPPLY	WEIGEL	ONLY	
RECTIFIERS	DAILY		
✓ TESTED ALL BILGE AIR VALVES 19 MARCH 1969			
✓ TEST RUN #1 & 2 DIESEL FIRE PUMPS FOR 1/2 HR			
19 MARCH 1969			

Signature

Electrician

USNS GEN

Weigel

DATE

MARCH
17 to 21stROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	17 th	4	Hot - M-100K FI-2M FP-800K Cold - M-5K FI-5M FP-1M
CARGO WINCHES	21 st	1/4	1 & 2 - 200K
ANCHOR WINDLASS	19 th	1	Cold 5megs Hot 300K
CAPSTAN	19 th	1	#1 - 50M Cold 20M Hot #2 - 30M Cold 15M Hot
FIRE ALARMS	Daily		
EMERG. BATTERIES	17 th		OK
DIESEL BATTERIES	17 th		ON charge 0715-0715 ^{17th}
FIRE PUMP BATTERIES			
DIESEL GENERATORS	19 th	1/2	No load.
LAUNDRY SUPPLY	19 th		A - 5 J... L... T6.2M T11.5M
RECTIFIERS	Daily		

Signature


W. C. Brooks.

Electrician

USNS GEN JOHN PIPE (TAP110)DATE 3/10/69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	3/10/69	4 HRS	2 MEGGS.
CARGO WINCHES	3/14/69	1 HR	5 # 6M #6 = 6M
ANCHOR WINDLASS	3/12/69	2 HR.	7 - Meggs.
CAPSTAN	3/12/69	1 HR	#1. 1-Meggs. ^{star.} #15-Meggs. ^{port.}
FIRE ALARMS	DAILY TEST.		
EMERG. BATTERIES	3-18-69		
DIESEL BATTERIES	3/10/69		
FIRE PUMP BATTERIES	3/10/69		
DIESEL GENERATORS	3/12/69	1 1/2 HR.	8 MEGGS.
LAUNDRY SUPPLY	WEIGHED ONLY		
RECTIFIERS	READ DAILY		

Signature


Electrician

USNS GEN

Weigel

March

DATE

10th-14thROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	10 th	4	M-5K F1-10M EP-1M
CARGO WINCHES	14 th	1/4	*1-200k *2-200k
ANCHOR WINDLASS	12 th	1	6M cold 600K Hot
CAPSTAN	12 th	1	*1-15M *2-20M
FIRE ALARMS	Daily		
ENGINE BATTERIES	10 th		
DIESEL BATTERIES	10 th		
FIRE PUMP BATTERIES			
DIESEL GENERATORS	12 th	1/2	
LAND DRY SUPPLY	12 th		LS-5M HS-8M
RECTIFIERS	Daily		

Signature

W.C. Brooks.

Electrician

TRANS GEN

POPE (TAP 110)

DATE 3 MAR 69

ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	3/3/69	4 HRS	1.5 MEGGS
CARGO WINCHES	3/7/69	1 HR	#5-8 MEGGS. #6-6 MEGGS.
ANCHOR WINDLASS	3/5/69	1 HR.	6. - MEGGS
CAPSTAN	3/5/69	1 HR.	STBD. 1.5 meg. Port 20-meggs
FIRE ALARMS	DAILY		
EMERG. BATTERIES	3/3/69	—	
DIESEL BATTERIES	3/3/69	—	
FIRE PUMP BATTERIES	3/3/69	—	
DIESEL GENERATORS	3/5/69	1/2 HR.	8 MEGGS.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

Signature



Electrician

USNS GEN

Wolfe

DATE

3-7-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	3-3	4	Hot 11 600K F+10M F P1-M 100K 1.5 400K
CABLE WINCHES	3-7	1/4	#1-300K. #2-200K.
ANCHOR WINDLASS	3-5	1	700K
CAPSTAN	3-5	1	#1 30M #2 30M
FIRE ALARMS	Daily		
EMERG. BATTERIES	3-3		on charge 2HRS.
DIESEL BATTERIES	3-3		on charge 4HRS.
FIRE PUMP BATTERIES			
DIESEL GENERATORS	3-5	1/2	
LAUNDRY SUPPLY	3-5	1	T1 10M T2 50M T3 20M
RECTIFIERS	Daily		

Signature

Archie L. Garrett

Electrician

USNS GEN

Weigel

DATE

2-28-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING		
DEGAUSSING	24 th	4 hrs.	110K F1-5M	FP	900K
			150K	3M	800K
CARGO WINCHES	28 th		#1-200K	#2-700K	
ANCHOR WINDLASS	26 th	1 hr.	C-5 Mgs	Hot	900K
CAPSTAN	26 th	1 hr.	#1-30M	#2-30M.	
FIRE ALARMS	Daily				
ENGINE BATTERIES	24 th		OK		
DIESEL BATTERIES	24 th		OK		
FIRE PUMP BATTERIES	—		—		
DIESEL GENERATORS	26 th	2 hrs.	Monthly load test.		
LAUNDRY SUPPLY	26 th	4 hr.	T1 30M	T2 30M	T3 30M.
RECTIFIERS	Daily				

Signature


W.C. Brooks.

Electrician

USNS GEN POPE (TAP119)DATE 27 FEB 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	2/24/69	4 HRS	2 MEGGS
CARGO WINCHES #5 & 6	2/28/69	1 HR.	#5 8 MEGGS. #6 6 MEGGS.
ANCHOR WINDLASS	2/26/69	1 HR.	8-MEGGS.
CAPSTAN	2/26/69	1 HR.	#1 1.5-Meggs. #2 - 20-Meggs.
FIRE ALARMS	DAILY		
EMERG. BATTERIES	2-24/69		
DIESEL BATTERIES	2/24/69		
FIRE PUMP BATTERIES	2/24/69		
DIESEL GENERATORS	2/26/69	4 HRS.	8 MEGGS
LAND RAY SUPPLY	WEIGH ONLY		
RECTIFIERS	DAILY		

Signature


Electrician

USNS GEN GEN JOHN POPEDATE 20 Jan 1969ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	2-17-69	4 HRS	2 M.
CARGO WINCHES	2-20-69	1 HR.	#5-6 M #6-8 M
ANCHOR WINDLASS	2-19-69	1 HR.	6-M.
CAPSTAN	2-19-69	1 HR.	STBD. 1.5-M. PORT 15-M.
FIRE ALARMS	DAILY		
EMER. BATTERIES	2-17-69		
DIESEL BATTERIES	2-17-69		
FIRE PUMP BATTERIES	2-17-69		
DIESEL GENERATORS	2-19-69	1/2 Hr	8 M.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

Signature


Electrician

USNS GEN

Weigel

DATE

2-17-69
THRU.ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS2-20-69

UNIT	DATE	HRS	Hot MEGGER READING	Cold
DEGAUSSING	2-17	4	M 100K E 600K	400K 3M
CARGO WINCHES	2-19	1/4	#1-200K	#2-300K
ANCHOR WINDLASS	2-19	1	5 Megs	
CAPSTAN	2-19	1	#1-20 Megs	#2-30 Megs
FIRE ALARMS	Daily			
ENGINE BATTERIES	2-17		OK.	
DIESEL BATTERIES	2-17		Charged 6 hours.	
PUMP BATTERIES				
DIESEL GENERATORS	2-17	1		
LAUNDRY SUPPLY	2-17	1	T 11.0K T 2.80K T 3.30K T 11.4K T 12.4K T 13.4K	
RECTIFIERS	DAILY			

Signature

W. E. Brooks

Electrician

USNS GEN John Pope (ZAP 110)DATE 2-14-68ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	2-10-69	4 HRS.	1.5 MEGG'S
CARGO WINCHES 5 & 6	2-14-69	1 HR.	5-7 M 6-8 M
ANCHOR WINDLASS	2/13/69	1 HR.	9 MEGG'S
CAPSTAN	2/13/69	1 HR.	std. 1.5 meg Port 20 meg
FIRE ALARMS	DAILY		
EMER. BATTERIES	2-10-69		
DIESEL BATTERIES	2-10-69		
FIRE PUMP BATTERIES	2-10-69		
DIESEL GENERATORS	2-13-69	1/2 HR.	8 MEGG'S
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

Signature

Electrician

USNS GEN WEIGELDATE 2/13/69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING			M 10 F 15M F 10K
CARGO WINCHES			INCLEMENT WEATHER
ANCHOR WINDLASS	2/13/69	1	6M
CAPSTAN	2/13/69	1	H 1 H 50M +12H 100M. C 60M. G 100M
FIRE ALARMS	DAILY		
EMERG. BATTERIES	2/10/69		
DIESEL BATTERIES	2/10/69		
ENGINE PUMP BATTERIES	2/10/69		
DIESEL GENERATORS	2/10/69		
LAUNDRY SUPPLY	2/10/69		
RECTIFIERS	DAILY		

Signature


Archie B. C. Garrett
Electrician

USNS GEN JOHN POPE (TAP110)DATE 3 FEB 1964ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	3 FEB 1964	4 HRS.	2 MEGG'S.
CARGO WINCHES	2-7-64	1 HR.	#5-6M #6-8M
ANCHOR WINDLASS	2-5-68	1/2 HR.	7-MEGG'S
CAPSTAN	2-5-68	1/2 HR.	STBD. 1 MEG. PORT 15 MEG.
FIRE ALARMS	3 FEB - 7 FEB. 1964		
ELECT. BATTERIES	3 FEB 1964	—	
DIESEL BATTERIES	3 FEB 1964	—	
FIRE PUMP BATTERIES	3 FEB 1964	—	
DIESEL GENERATORS	5 FEB 1964	1/2 HR.	10 MEGG'S.
LAUNDRY SUPPLY	WEIGEL ONLY		
RECTIFIERS	DAILY		

Signature

Electrician



USNS GEN

Weigel

DATE

2-7-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEROISSING	2-3-69	4	M-10K FI-5M- FP-1M.
CARGO WINCHES	2-7-69	1/4	#1-200K #2-600K
ANCHOR WINDLASS	2-5-69	1	6 Megs
CAPSTAN	2-5-69	1	#1-20 Megs #2-30 Megs.
FIRE ALARMS	Daily		
EMERG. BATTERIES	2-3-69		
DIESEL BATTERIES	2-3-69		
FIRE PUMP BATTERIES	—		
DIESEL GENERATORS	2-6-69	1/2	50 Megs
LAUNDRY SUPPLY	2-7-69	1/4	T1 25M T2 30M T3 3 Megs
RECTIFIERS	Daily		

Signature

W.C. Brooks

Electrician

USNS GEN Wedge 1DATE 1-31-69ROUTINE WEEKLY AND DAILY TEST FOR ELECTRICIANS

UNIT	DATE	HRS	MEGGER READING
DEGAUSSING	1-27	4	M 10,000 FI 2M FCA 2M
CARGO WINCHES	1-31	1/4	300K 800K
ANCHOR WINDLASS	1-29	1	4 Megs.
CAPSTAN	1-29	1	1-40M 2-20M
FIRE ALARMS	Daily		
EMERG. BATTERIES	1-27		
DIESEL BATTERIES	1-27		
FIRE PUMP BATTERIES	—		
DIESEL GENERATORS	1-29	2	50 Megs.
LAUNDRY SUPPLY	1-28	1/2	T ¹ 2M T ² 2M T ³ 4M
RECTIFIERS	Daily		

Signature

Electrician

WC Brooks
G. J. Turner