

6/13/69 WUEBEL

VENTILATION SYSTEM # 51-186-2 RHEOSTAT.
CUTLER HAMMER. OHMS 380. NO 87901256.
BRIDGED THREE CONTACTS ON RHEOSTAT TO
CLOSE OPEN IN RHEOSTAT. OVERHAUL
CONTRACTOR. RENEWED HOLDING COIL IN CON-
TRACTOR. COIL NO 9-1151-4. REMOVED JUMPER
PLACED RHEOSTAT IN SYSTEM

VENTILATION SYSTEM 51-186-2. RHEOSTAT
WORD LEONARD ELECT CO. OHMS 500. CAT NO.
64-4042. SER NO 1945. AMPS 21-0-112. WTS 600
MIX. REMOVED JUMPER FROM CONTRACTOR TOOK OUT
RHEOSTAT CLEANED CONTACTS, REINSTALLED
RHEOSTAT AND PLACED BACK IN SERVICE.
RENEWED HOLDING COIL & R1 COIL. HOLDING
COIL # 9-1151-4. R1 COIL # 1088-4. RENEWED
LINE CONTRACTOR.